


F1 Issues

As of 15 September, 2015
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Total Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
6 Sep.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
7 Sep.	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	10	11
8 Sep.	< 1.0	< 1.0	< 1.0	1.9	–	–	–	9.0
9 Sep.	< 1.0	**No samples	< 1.0	No samples	–	–	–	No samples
10 Sep.	< 1.0	No samples	1.2	No samples	–	–	–	No samples
11 Sep.	No samples							
12 Sep.	< 1.0	No samples	< 1.0	No samples	–	–	–	No samples

*Total Beta includes K-40 occurring naturally in seawater.
**Due to bad weather unless otherwise specified.



Concentrations of Cs-134, Cs-137, H-3 and total Beta remained low.
Details of monitoring results are indicated in the following URL:
<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>