

2F | 105X-7- KHR(B) 1:2X 2011/3/14 9:00

時間 警報値	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W		S/C 圧力(kPasbs)	S/C 水位(mm)		S/C 温度(°C)
				圧力(kPa)	温度(°C)		89	32	
	7.07	321(L3)		13.7	57				
			炉水温度						
2011/3/13 9:00	0.29	1528	137	164	115.3	286	6160	126	
2011/3/13 9:30	0.3	1528	134	169	115.6	294	6130	126	
2011/3/13 9:00	0.31	1180	135	174	116.1	298	6145	127	
2011/3/13 9:30	0.32	810	136	179	116.5	301	6116	123.3	
2011/3/13 10:00	0.31	1321	135	179	116.8	304	6122	124.9	
2011/3/13 10:30	0.32	1373	136	184	117.3	308	6155	125	
2011/3/13 11:00	0.32	1016	136	184	117.4	300	6205	123.8	
2011/3/13 11:30	0.31	1910	135	185	117.8	302	6371	130	
2011/3/13 12:00	0.32	1204	136	174	118.3	302	6476	129	
2011/3/13 12:30	0.31	900	135	169	119.8	299	6672	129	
2011/3/13 13:00	0.31	1127	135	161	120.5	295	6660	128	
2011/3/13 13:30	0.31	1382	133	158	120.6	294	7063	128	
2011/3/13 14:00	0.31	1075	135	164	120.3	300	7088	128	
2011/3/13 14:30	0.32	1238	136	187	119.5	304	7068	128	
2011/3/13 15:00	0.32	807	136	188	118.9	308	7089	128	
2011/3/13 15:30	0.32	865	136	173	118.7	312	7108	129	
2011/3/13 16:00	0.32	1130	137	177	118.9	318	7122	116	
2011/3/13 16:30	0.33	1375	136	180	118.8	319	7141	113	
2011/3/13 17:00	0.34	991	138	185	119	325	7145	115	
2011/3/13 17:30	0.35	1280	139	188	119.3	327	7157	116	
2011/3/13 18:00	0.34	1250	139	191	119.5	333	7168	117	
2011/3/13 18:30	0.35	890	139	195	119.9	337	7168	120	
2011/3/13 19:00	0.36	1017	140	198	120.1	342	7173	120	
2011/3/13 19:30	0.35	1236	138	200	120.4	344	7184	121	
2011/3/13 20:00	0.37	840	141	204	120.9	350	7180	122	
2011/3/13 20:30	0.37	985	141	208	121.0	354	7178	122	
2011/3/13 21:00	0.38	1236	142	209	121.4	357	7184	122	
2011/3/13 21:30	0.38	1250	142	211	121.8	361	7190	122	
2011/3/13 22:00	0.38	1150	142	220	121.4	365	7248	125	
2011/3/13 22:30	0.39	2018	143	222	121.9	368	7241	125	
2011/3/13 23:00	0.39	1847	143	222	122.5	372	7235	124	
2011/3/13 23:30	0.40	2000	144	230	122.2	378	7298	126	
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	128	
2011/3/14 0:30	0.40	889	144	232	123.5	378	7383	126	
2011/3/14 1:00	0.40	2001	144	233	123.7	378	7396	126	
2011/3/14 1:30	0.40	7011	144	235	124.1	383	7378	126	
2011/3/14 2:00	0.39	1840	143	236	124.2	381	7408	128	
2011/3/14 2:30	0.40	1650	144	238	124.3	378	7443	126	
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	126	
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5880	126	
2011/3/14 4:00	0.37	1167	141	237	124.5	356	5887	124	
2011/3/14 4:30	0.37	1727	141	233	124.5	352	5875	122	
2011/3/14 5:00	0.37	1109	141	227	124.3	348	5902	121	
2011/3/14 5:30	0.37	1258	141	223	124.4	345	5908	120	

2FZ W30 D2

2号機

時間 監視区	炉圧(Mpa)	炉水位(mm)	D/W		S/C圧力(kPaabs)	S/C水位(mm)		S/C温度(°C)
			圧力(kPa)	温度(°C)		83	32	
	7.07	321(L3)	13.7	57				
2011/3/13 8:00	0.33	1086	137	185.6	110.8	288	3100	132
2011/3/13 8:30	0.31	1284	136	183.7	111	287	3150	132
2011/3/13 9:00	0.31	1225	136	184.8	111.8	290	3200	132
2011/3/13 9:30	0.33	1073	137	180.9	111.8	285	3300	132
2011/3/13 10:00	0.32	1312	136	178.9	112	288	3400	131
2011/3/13 10:30	0.32	1054	136	181.8	112.2	289	3450	131
2011/3/13 11:00	0.33	1103	137	182.8	112.6	290	3500	132
2011/3/13 11:30	0.33	1308	137	180.8	113.3	287	3500	132
2011/3/13 12:00	0.34	1089	138	185.8	113.5	284	3600	132
2011/3/13 12:30	0.36	1064	139	181.2	113.4	280	3700	132
2011/3/13 13:00	0.33	1378	137	185.8	113.5	295	3750	132
2011/3/13 13:30	0.37	818	141	183.1	113.3	294	3800	132
2011/3/13 14:00	0.36	1182	140	180.8	113.8	292	3800	132
2011/3/13 14:30	0.34	1486	138	185.8	114.1	293	4000	132
2011/3/13 15:00	0.37	1180	141	180.8	113.6	293	4000	132
2011/3/13 15:30	0.37	1280	141	182.8	114.3	295	4050	132
2011/3/13 16:00	0.37	1079	141	185.3	114.2	299	4150	132
2011/3/13 16:30	0.39	1097	143	182.8	114.5	297	4200	132
2011/3/13 17:00	0.39	1163	143	190.8	115.3	306	4250	132
2011/3/13 17:30	0.38	1228	142	184.3	115.7	309	4300	133
2011/3/13 18:00	0.37	1258	141	188	116.2	314	4300	133
2011/3/13 18:30	0.37	1256	141	204	116.4	319	4300	134
2011/3/13 19:00	0.39	1130	143	208.0	117.0	324	4300	135
2011/3/13 19:30	0.40	1077	144	212.1	117.3	327	4300	135
2011/3/13 20:00	0.41	1022	145	211.8	117.8	328	4350	135
2011/3/13 20:30	0.40	1228	144	212.4	117.9	328	4400	135
2011/3/13 21:00	0.40	1132	144	214.8	118.2	332	4500	135
2011/3/13 21:30	0.41	1020	145	210.8	118.3	328	4550	136
2011/3/13 22:00	0.40	1170	144	210.8	118.6	329	4680	136
2011/3/13 22:30	0.40	1024	144	214.3	118.7	333	4700	135
2011/3/13 23:00	0.41	1023	145	209.8	118.8	330	4800	136
2011/3/13 23:30	0.40	1273	144	210.6	118.3	331	4800	136
2011/3/14 0:00	0.39	1152	143	220.9	118.7	341	4850	136
2011/3/14 0:30	0.40	1255	144	221.5	119.0	342	4950	135
2011/3/14 1:00	0.42	864	146	224.8	120.1	346	4950	136
2011/3/14 1:30	0.41	1217	145	230.8	120.8	361	4950	137
2011/3/14 2:00	0.42	1038	146	233.4	120.8	355	4950	137
2011/3/14 2:30	0.43	1070	147	238.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	146	238.9	121.5	362	5000	137
2011/3/14 3:30	0.41	1275	145	243.7	121.8	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.8	122.9	370	5050	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.45	1141	147	249.0	123.5	373	5200	138

2F311030-9

時間 警報値	B号機							
	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPa abs)	S/C水位(mm)	S/C温度(°C)
	7.07	821(L3)		13.7	57.0		60	32
2011/3/13 8:00	-0.01	1531	49.2	28	65.5	128	608	54
2011/3/13 8:30	-0.01	1531	64.5	28	65.4	127	602	52
2011/3/13 9:00	0.00	1631	71.4	28	65.2	126	610	49
2011/3/13 9:30	0.08	1531	66.8	28	65.5	128	634	46
2011/3/13 10:00	0.10	1531	60.0	28	65.7	128	652	44
2011/3/13 10:30	0.10	1532	62.0	28	66.0	126	660	43
2011/3/13 11:00	0.00	1531	65.0	28	66.6	128	583	51
2011/3/13 11:30	-0.03	4182	65.4	28	66.0	129	584	52
2011/3/13 12:00	-0.03	3848	66.7	28	65.2	128	601	51
2011/3/13 12:30	-0.03	3864	59.2	27	65.0	127	588	49
2011/3/13 13:00	-0.02	3958	65.2	28	64.7	128	600	47
2011/3/13 13:30	0.02	3918	76.1	27	64.7	129	598	47
2011/3/13 14:00	0.04	3731	62.9	28	64.8	129	600	47
2011/3/13 14:30	0.04	3841	55.4	28	65.0	128	589	47
2011/3/13 15:00	0.04	3687	48.8	28	64.6	129	598	47
2011/3/13 15:30	0.04	3549	45.9	28	64.6	128	588	47
2011/3/13 16:00	0.04	3527	43.3	28	64.4	128	598	46
2011/3/13 16:30	0.04	3504	41.4	28	64.3	128	598	46
2011/3/13 17:00	0.04	3497	40.5	28	64.1	129	600	46
2011/3/13 17:30	0.04	3490	40.0	28	64.0	128	599	46
2011/3/13 18:00	0.03	3478	39.1	28	63.8	128	598	46
2011/3/13 18:30	0.03	3489	38.2	28	63.8	128	598	46
2011/3/13 19:00	0.03	3484	38.1	28	63.8	128	599	46
2011/3/13 19:30	0.03	3458	37.8	28	63.5	128	600	46
2011/3/13 20:00	0.03	3457	38.4	28	63.4	128	598	46
2011/3/13 20:30	0.03	3461	38.8	28	63.3	128	598	46
2011/3/13 21:00	0.03	3454	37.3	28	63.2	128	598	46
2011/3/13 21:30	0.03	3442	35.2	28	63.3	128	598	46
2011/3/13 22:00	0.02	3433	35.4	28	63.2	128	599	46
2011/3/13 22:30	0.02	3428	34.9	28	63.0	130	598	46
2011/3/13 23:00	0.02	3423	34.5	28	62.8	129	600	46
2011/3/13 23:30	0.02	3419	34.2	28	62.6	129	606	46
2011/3/14 0:00	0.01	3418	33.9	29	62.8	130	588	48
2011/3/14 0:30	0.01	3414	33.7	29	62.4	130	598	48
2011/3/14 1:00	0.01	3414	33.6	29	62.4	130	597	46
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	583	48
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	598	48
2011/3/14 2:30	0.00	3410	33.1	29	62.3	130	598	48
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	599	48
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	46
2011/3/14 4:00	-0.01	3408	32.9	29	62.1	130	589	45
2011/3/14 4:30	-0.02	3406	32.8	29	62.0	130	607	45
2011/3/14 5:00	-0.02	3407	32.8	29	61.9	130	598	46
2011/3/14 5:30	-0.03	3408	32.7	29	61.9	130		

275105X-2

4号機

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)		S/C圧力(kPaabs)		S/C温度(°C)	
				13.7	57	-	50	32	
特報値	7.07	921(L3)							
2011/3/13 8:00	0.24	1497	130.7	102	80	218	4400	113	
2011/3/13 8:30	0.24	1488	130.8	103	81.8	217	4450	113	
2011/3/13 9:00	0.24	1114	130.8	104	98.3	218	4550	114	
2011/3/13 9:30	0.25	1487	130.5	104	100.1	219	4600	114	
2011/3/13 10:00	0.25	1497	131.2	105	100.5	221	4600	114	
2011/3/13 10:30	0.24	1488	131.1	105	100.8	222	4650	114	
2011/3/13 11:00	0.24	1497	131.0	106	101.3	224	4700	114	
2011/3/13 11:30	0.24	1393	131.0	107	101.8	225	4800	114	
2011/3/13 12:00	0.25	1093	131.0	113	102	231	4850	116	
2011/3/13 12:30	0.25	598	131.3	118	102.4	236	4850	116	
2011/3/13 13:00	0.26	3312	131.8	119	102.8	237	4900	116	
2011/3/13 13:30	0.26	2824	132.8	120	103.1	238	4900	118	
2011/3/13 14:00	0.26	2411	132.8	122	103.5	240	4850	117	
2011/3/13 14:30	0.26	1994	132.5	123	103.8	242	4850	117	
2011/3/13 15:00	0.26	1519	132.5	125	104.1	244	4800	118	
2011/3/13 15:30	0.26	982	132.5	126	104.3	246	4950	119	
2011/3/13 16:00	0.26	499	132.6	128	104.7	248	5000	119	
2011/3/13 16:30	0.26	3829	133.2	129	104.8	249	4900	120	
2011/3/13 17:00	0.28	3003	133.8	130	105.2	248	4900	120	
2011/3/13 17:30	0.29	2594	134.4	132	105.7	251	4950	120	
2011/3/13 18:00	0.29	2182	134.8	131	106.4	253	4950	121	
2011/3/13 18:30	0.29	1759	135.0	135	106.8	255	5000	121	
2011/3/13 19:00	0.28	1179	135.0	137	107.2	259	5050	122	
2011/3/13 19:30	0.27	681	134.8	139	107.6	260	5050	122	
2011/3/13 20:00	0.3	3391	134.2	140	108	260	5000	123	
2011/3/13 20:30	0.3	3080	134.8	142	107.9	262	5000	123	
2011/3/13 21:00	0.3	2702	135.4	143	108.5	264	5050	124	
2011/3/13 21:30	0.3	2319	135.7	146	108.8	268	5050	124	
2011/3/13 22:00	0.3	1899	135.9	147	109	268	5150	125	
2011/3/13 22:30	0.3	1448	136.1	148	109.1	270	5150	125	
2011/3/13 23:00	0.3	1000	136.3	151	109.3	272	5150	125	
2011/3/13 23:30	0.31	512	136.5	154	109.6	276	5200	126	
2011/3/14 0:00	0.31	3304	136.6	155	109.9	277	5050	126	
2011/3/14 0:30	0.31	2884	136.8	166	109.8	280	5150	127	
2011/3/14 1:00	0.31	2507	137.2	160	110.3	282	5160	127	
2011/3/14 1:30	0.31	2118	137.4	163	110.5	286	5150	128	
2011/3/14 2:00	0.32	1695	137.6	166	110.8	287	5150	128	
2011/3/14 2:30	0.32	1238	137.7	169	111.4	290	5200	128	
2011/3/14 3:00	0.32	784	137.8	170	111.9	292	5200	128	
2011/3/14 3:30	0.32	320	138.1	173	112.2	295	5200	130	
2011/3/14 4:00	0.33	3135	138.4	175	112.5	296	5150	130	
2011/3/14 4:30	0.33	2783	138.6	177	112.8	298	5150	131	
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131	
2011/3/14 5:30	0.33	2012	139.0	182	112.8	305	5200	132	

2F 1.1°3X-9

時間	1号機							
	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaaba)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L9)		13.7	57	-	83	32
			炉水温度					
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	869	144	232	123.5	376	7363	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7398	126
2011/3/14 1:30	0.40	1011	144	235	124.1	383	7379	126
2011/3/14 2:00	0.39	1940	143	239	124.2	361	7408	126
2011/3/14 2:30	0.40	1650	144	238	124.3	378	7443	126
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	126
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5880	126
2011/3/14 4:00	0.37	1167	141	237	124.5	366	5867	124
2011/3/14 4:30	0.37	1727	141	233	124.5	362	5875	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5802	121
2011/3/14 5:30	0.37	1258	141	223	124.4	345	5808	120
2011/3/14 6:00	0.35	1899	138	220	124.2	342	5950	119
2011/3/14 6:30	0.36	1324	140	219	124.2	341	5860	117
2011/3/14 7:00	0.36	827	140	218	124.2	340	5882	115
2011/3/14 7:30	0.36	2000	140	216	124.1	338	6018	114
2011/3/14 8:00	0.35	1537	139	213	124.1	336	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1861	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1318	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	139	206	123.8	329	6061	108
2011/3/14 10:30	0.34	4205	138	200	123.9	324	5839	101
2011/3/14 11:00	0.22	4284	123	198	123.1	322	5801	89
2011/3/14 11:30	0.16	4589	113	192	118.3	319	5848	95

2F2 157X-0

2F2

2号機

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L3)		13.7	57	-	8S	32
2011/3/14 0:00	0.38	1162	143	220.9	118.7	341	4950	135
2011/3/14 0:30	0.40	1265	144	221.5	118.9	342	4950	135
2011/3/14 1:00	0.42	964	146	224.8	120.7	346	4950	136
2011/3/14 1:30	0.41	1217	145	230.8	120.6	351	4950	136
2011/3/14 2:00	0.42	1039	148	233.4	120.9	355	4950	137
2011/3/14 2:30	0.43	1070	147	236.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	146	239.9	121.5	362	6000	137
2011/3/14 3:30	0.41	1275	145	243.7	121.8	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	6050	138
2011/3/14 4:30	0.43	1014	147	247.8	122.8	370	5050	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	248.0	123.5	373	5200	138
2011/3/14 6:00	0.42	1292	146	248.4	123.8	373	5250	139
2011/3/14 6:30	0.45	816	148	249.9	123.9	374	5260	139
2011/3/14 7:00	0.44	984	147	249.7	124.2	373	5300	139
2011/3/14 7:30	0.43	1240	147	255.3	124.7	380	5350	138
2011/3/14 8:00	0.43	1246	147	245.9	124.9	370	5400	129
2011/3/14 8:30	0.44	991	147	239.3	124.7	384	5400	126
2011/3/14 9:00	0.42	1209	146	227.5	124.8	351	5400	123
2011/3/14 9:30	0.40	1285	144	216.9	124.5	340	5400	120
2011/3/14 10:00	0.41	1103	145	207.8	124.3	331	5400	118
2011/3/14 10:30	0.40	1204	144	202.8	124.1	328	5400	114
2011/3/14 11:00	0.36	2931	140	193.8	124.0	316	5350	112
2011/3/14 11:30	0.37	4188	141	186.3	123.4	308	5200	112

2F3 1074-6

3号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L3)		13.7	57.0	-	50	32
2011/3/14 0:00	0.01	3418	33.9	29	62.6	128	598	46
2011/3/14 0:30	0.01	3414	33.7	29	62.6	130	598	46
2011/3/14 1:00	0.01	3414	33.6	29	62.4	130	598	46
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	597	46
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	598	46
2011/3/14 2:30	0.00	3410	33.1	29	62.3	130	598	46
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	598	46
2011/3/14 3:30	-0.01	3410	33.0	28	62.1	130	599	46
2011/3/14 4:00	-0.01	3409	32.9	28	62.1	130	598	46
2011/3/14 4:30	-0.02	3408	32.8	28	62.0	130	599	45
2011/3/14 5:00	-0.02	3407	32.8	29	61.9	130	597	45
2011/3/14 5:30	-0.03	3409	32.7	29	61.9	130	598	45
2011/3/14 6:00	-0.03	3405	32.6	29	61.9	130	597	45
2011/3/14 6:30	-0.03	3406	32.5	29	61.8	130	598	45
2011/3/14 7:00	-0.04	3407	32.4	29	61.8	130	599	45
2011/3/14 7:30	-0.04	3408	32.4	30	61.5	130	598	45
2011/3/14 8:00	-0.04	3406	32.3	30	61.4	130	599	46
2011/3/14 8:30	-0.04	3406	32.2	29	61.4	130	598	45
2011/3/14 9:00	-0.04	3408	32.1	29	61.4	130	597	45
2011/3/14 9:30	-0.05	3416	32.0	30	61.2	130	598	45
2011/3/14 10:00	-0.05	3414	32.0	29	61.3	130	599	46
2011/3/14 10:30	-0.05	3413	31.9	30	61.0	130	598	46
2011/3/14 11:00	-0.05	3416	31.9	30	61.0	131	600	45
2011/3/14 11:30	-0.05	3416	31.8	30	61.1	131	600	45

2F4 105x-0

時間	4号機							
	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L3)		13.7	57	-	50	32
2011/3/14 0:00	0.31	3304	136.6	155	109.9	277	5050	128
2011/3/14 0:30	0.31	2884	136.9	156	109.9	280	5150	127
2011/3/14 1:00	0.31	2507	137.2	160	110.3	282	5150	127
2011/3/14 1:30	0.31	2118	137.4	169	110.5	285	5150	128
2011/3/14 2:00	0.32	1695	137.6	165	110.9	287	5150	128
2011/3/14 2:30	0.32	1230	137.7	168	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	292	5200	129
2011/3/14 3:30	0.33	320	138.1	179	112.2	295	5200	130
2011/3/14 4:00	0.33	3135	138.4	175	112.5	298	5150	130
2011/3/14 4:30	0.33	2793	138.6	177	112.8	299	5150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.8	305	5200	132
2011/3/14 6:00	0.34	1648	139.2	185	112.8	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	645	139.7	192	113	316	5250	133
2011/3/14 7:30	0.36	3436	139.9	193	113.2	315	5200	133
2011/3/14 8:00	0.36	3107	140.4	197	113.5	319	5200	133
2011/3/14 8:30	0.35	2734	140.6	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:30	0.35	1949	141.2	207	114.3	329	5250	135
2011/3/14 10:00	0.36	1600	141.3	210	114.7	332	5250	135
2011/3/14 10:30	0.36	1144	141.6	214	115.1	335	5250	136
2011/3/14 11:00	0.37	693	141.9	218	115.6	339	5250	136
2011/3/14 11:30	0.38	3443	142.1	218	116	338	5200	136

1号楼

时间	炉压(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/C压力(kPaabs)	S/C水位(mm)	S/C温度(°C)
报警值	7.97	321(L3)		13.7	57	-	83	32
			炉水温度					
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	988	144	232	123.5	376	7363	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7398	126
2011/3/14 1:30	0.40	1011	144	235	124.1	383	7378	126
2011/3/14 2:00	0.39	1940	143	236	124.2	381	7408	126
2011/3/14 2:30	0.40	1660	144	238	124.3	378	7443	126
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	126
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5880	126
2011/3/14 4:00	0.37	1187	141	237	124.5	358	5887	124
2011/3/14 4:30	0.37	1727	141	233	124.5	352	5875	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5902	121
2011/3/14 5:30	0.37	1258	141	229	124.4	345	5908	120
2011/3/14 6:00	0.35	1898	139	220	124.2	342	5950	119
2011/3/14 6:30	0.36	1324	140	218	124.2	341	5980	117
2011/3/14 7:00	0.38	827	140	218	124.2	340	5992	115
2011/3/14 7:30	0.36	2000	140	218	124.1	338	6018	114
2011/3/14 8:00	0.35	1537	139	213	124.1	338	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1861	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1316	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	139	205	123.8	329	6051	108
2011/3/14 10:30	0.34	4205	138	200	123.8	324	5939	101
2011/3/14 11:00	0.22	4294	123	198	123.1	322	5901	99
2011/3/14 11:30	0.18	4588	113	192	119.9	319	5848	95
2011/3/14 12:00	0.11	4678	103	187	115.8	315	5972	94

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/G压力(kPaabs)	S/G水位(mm)	S/G温度(°C)
警報値	7.07	321(L3)		13.7	57		83	32
2011/3/14 0:00	0.39	1152	143	220.9	119.7	341	4950	136
2011/3/14 0:30	0.40	1255	144	221.5	119.9	342	4960	135
2011/3/14 1:00	0.42	964	148	224.6	120.1	348	4960	138
2011/3/14 1:30	0.41	1217	146	230.6	120.6	351	4950	137
2011/3/14 2:00	0.42	1039	146	233.4	120.9	356	5000	137
2011/3/14 2:30	0.43	1070	147	236.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	146	239.9	121.5	362	5000	138
2011/3/14 3:30	0.41	1275	145	243.7	121.8	365	5050	138
2011/3/14 4:00	0.43	1103	147	247.6	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.6	122.8	370	5100	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	249.0	123.6	373	5200	138
2011/3/14 6:00	0.42	1292	146	248.4	123.6	373	5250	139
2011/3/14 6:30	0.45	919	148	249.8	123.9	374	5250	139
2011/3/14 7:00	0.44	984	147	249.7	124.2	373	5300	139
2011/3/14 7:30	0.43	1240	147	255.3	124.7	380	5350	138
2011/3/14 8:00	0.43	1246	147	246.8	124.9	370	5400	129
2011/3/14 8:30	0.44	991	147	239.3	124.7	384	5400	128
2011/3/14 9:00	0.42	1209	148	227.5	124.6	351	5400	120
2011/3/14 9:30	0.40	1265	144	216.9	124.6	340	5400	118
2011/3/14 10:00	0.41	1103	145	207.8	124.3	331	5400	114
2011/3/14 10:30	0.40	1204	144	202.8	124.1	328	5400	114
2011/3/14 11:00	0.36	2931	140	183.8	124.0	318	5360	112
2011/3/14 11:30	0.37	4168	141	186.3	123.4	308	5200	112
2011/3/14 12:00	0.31	4020	135	186.0	121.5	306	5200	0

3号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/C压力(kPaabs)	S/C水位(mm)	S/C温度(°C)
客観値	7.07	321(L3)		13.7	57.0	-	50	32
2011/3/14 0:00	0.01	3418	33.9	29	62.6	129	598	48
2011/3/14 0:30	0.01	3414	33.7	29	62.8	130	598	48
2011/3/14 1:00	0.01	3414	33.6	29	62.4	130	598	48
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	597	48
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	598	48
2011/3/14 2:30	0.00	3410	33.1	29	62.3	130	598	48
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	598	48
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	48
2011/3/14 4:00	-0.01	3409	32.9	29	62.1	130	599	48
2011/3/14 4:30	-0.02	3408	32.8	29	62.0	130	599	49
2011/3/14 5:00	-0.02	3407	32.8	29	61.9	130	597	49
2011/3/14 5:30	-0.03	3409	32.7	29	61.9	130	598	49
2011/3/14 6:00	-0.03	3406	32.8	29	61.9	130	598	49
2011/3/14 6:30	-0.03	3406	32.5	29	61.8	130	598	49
2011/3/14 7:00	-0.04	3407	32.4	29	61.8	130	599	49
2011/3/14 7:30	-0.04	3408	32.4	30	61.5	130	599	49
2011/3/14 8:00	-0.04	3408	32.3	30	61.4	130	599	49
2011/3/14 8:30	-0.04	3408	32.2	29	61.4	130	597	49
2011/3/14 9:00	-0.04	3406	32.1	29	61.4	130	597	49
2011/3/14 9:30	-0.05	3416	32.0	30	61.2	130	598	49
2011/3/14 9:50	-0.05	3414	32.0	29	61.3	130	598	49
2011/3/14 10:00	-0.05	3413	31.9	30	61.0	131	600	49
2011/3/14 10:30	-0.05	3413	31.9	30	61.0	131	600	49
2011/3/14 11:00	-0.05	3418	31.8	30	61.1	131	600	49
2011/3/14 11:30	-0.05	3412	31.8	30	61.0	131	600	49
2011/3/14 12:00	-0.05	3412	31.8	30	61.0	131	600	49

4号機

時間	炉压(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/C压力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L3)		13.7	57	-	50	32
2011/3/14 0:00	0.31	3304	138.6	155	109.9	277	6050	128
2011/3/14 0:30	0.31	2884	136.9	158	109.9	280	6150	127
2011/3/14 1:00	0.31	2507	137.2	160	110.3	282	6160	127
2011/3/14 1:30	0.31	2119	137.4	163	110.6	285	6150	128
2011/3/14 2:00	0.32	1895	137.6	165	110.9	287	6150	128
2011/3/14 2:30	0.32	1236	137.7	168	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	292	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3135	138.4	175	112.5	298	6160	130
2011/3/14 4:30	0.33	2783	138.6	177	112.6	299	6150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	6150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.9	305	5200	132
2011/3/14 6:00	0.34	1848	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	648	138.7	192	113	315	5250	133
2011/3/14 7:30	0.36	3438	139.9	193	113.2	315	5200	133
2011/3/14 8:00	0.36	3107	140.4	197	113.6	319	6200	133
2011/3/14 8:30	0.36	2734	140.8	200	113.7	322	5200	134
2011/3/14 8:30	0.36	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:00	0.36	1949	141.2	207	114.3	329	5250	135
2011/3/14 9:30	0.36	1800	141.3	210	114.7	332	5250	135
2011/3/14 10:00	0.36	1144	141.8	214	115.1	336	5250	136
2011/3/14 10:30	0.37	883	141.9	218	115.8	339	5250	136
2011/3/14 11:00	0.38	3443	142.1	218	116	338	5200	138
2011/3/14 11:30	0.38	3080	142.7	223	116.4	342	5200	138

1号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/G圧力(kPaabs)	S/G水位(mm)	S/G温度(°C)
実報値	7.07	321(L9)		13.7	57	-	63	32
			炉水温度					
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	128
2011/3/14 0:30	0.40	989	144	232	123.5	378	7363	128
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7396	128
2011/3/14 1:30	0.40	1011	144	235	124.1	383	7378	128
2011/3/14 2:00	0.39	1940	143	236	124.2	381	7408	128
2011/3/14 2:30	0.40	1650	144	236	124.3	378	7443	128
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	128
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5880	128
2011/3/14 4:00	0.37	1187	141	237	124.5	358	5887	124
2011/3/14 4:30	0.37	1727	141	233	124.5	352	5875	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5902	121
2011/3/14 5:30	0.37	1258	141	223	124.4	345	5908	120
2011/3/14 6:00	0.35	1898	139	220	124.2	342	5950	118
2011/3/14 6:30	0.36	1324	140	218	124.2	341	5980	117
2011/3/14 7:00	0.36	827	140	218	124.2	340	5992	115
2011/3/14 7:30	0.36	2000	140	218	124.1	338	6018	114
2011/3/14 8:00	0.35	1537	139	219	124.1	336	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1861	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1318	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	139	205	123.8	329	6081	108
2011/3/14 10:30	0.34	4205	138	200	123.8	324	5938	101
2011/3/14 11:00	0.22	4284	123	188	123.1	322	5901	99
2011/3/14 11:30	0.18	4588	113	182	119.3	319	5848	85
2011/3/14 12:00	0.11	4578	103	187	115.6	316	5872	84
2011/3/14 12:30	0.11	4588	103	182	112.8	311	5858	81
2011/3/14 13:00	0.10	4587	102	178	110.7	308	5846	89

13
 13 310
 23 325
 43 326

13 13 = 40
 冷気停

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/G圧力(kPaabs)	S/O水位(mm)	S/C温度(°C)
発報後	7.07	321(L3)		13.7	57	-	83	32
			RECORDING					
2011/3/14 0:00	0.39	1152	143	220.9	119.7	341	4950	135
2011/3/14 0:30	0.40	1259	144	221.5	119.9	342	4950	135
2011/3/14 1:00	0.42	984	148	224.8	120.1	348	4950	135
2011/3/14 1:30	0.41	1217	145	230.8	120.8	351	4950	138
2011/3/14 2:00	0.42	1039	148	233.4	120.9	355	4950	137
2011/3/14 2:30	0.43	1070	147	236.2	121.0	359	6000	137
2011/3/14 3:00	0.42	1173	148	239.9	121.5	362	6000	137
2011/3/14 3:30	0.41	1275	145	243.7	121.9	365	5000	139
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	5050	139
2011/3/14 4:30	0.43	1014	147	247.8	122.8	370	5050	139
2011/3/14 5:00	0.44	804	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	249.0	123.5	373	5200	138
2011/3/14 6:00	0.42	1282	148	248.4	123.8	379	5250	139
2011/3/14 6:30	0.45	918	148	249.6	123.9	374	5260	139
2011/3/14 7:00	0.44	884	147	249.7	124.2	373	5300	139
2011/3/14 7:30	0.43	1240	147	255.3	124.7	380	5350	138
2011/3/14 8:00	0.43	1248	147	245.8	124.8	370	5400	129
2011/3/14 8:30	0.44	981	147	238.3	124.7	384	5400	126
2011/3/14 9:00	0.42	1208	148	227.5	124.8	351	5400	123
2011/3/14 9:30	0.40	1265	144	216.9	124.5	340	5400	120
2011/3/14 10:00	0.41	1103	146	207.8	124.3	331	5400	118
2011/3/14 10:30	0.40	1204	144	202.8	124.1	328	5400	114
2011/3/14 11:00	0.38	2931	140	188.8	124.0	318	5350	112
2011/3/14 11:30	0.37	4188	141	186.3	123.4	308	5200	112
2011/3/14 12:00	0.31	4020	135	188.0	121.5	308	5200	110
2011/3/14 12:30	0.22	4089	123	188.1	118.6	303	5200	108
2011/3/14 13:00	0.18	4050	113	177.5	116.0	298	5200	108

3号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
常設値	7.07	321(L3)		13.7	57.0	-	50	32
2011/3/14 0:00	0.01	3419	33.9	29	62.8	129	598	46
2011/3/14 0:30	0.01	3414	33.7	29	62.8	130	598	46
2011/3/14 1:00	0.01	3414	33.8	29	62.4	130	598	46
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	597	46
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	598	46
2011/3/14 2:30	0.00	3410	33.1	29	62.3	130	598	46
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	598	46
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	46
2011/3/14 4:00	-0.01	3409	32.9	29	62.1	130	599	46
2011/3/14 4:30	-0.02	3406	32.8	29	62.0	130	599	45
2011/3/14 5:00	-0.02	3407	32.9	29	61.8	130	597	46
2011/3/14 5:30	-0.03	3409	32.7	29	61.8	130	598	45
2011/3/14 6:00	-0.03	3405	32.6	29	61.8	130	597	46
2011/3/14 6:30	-0.03	3408	32.5	29	61.8	130	598	45
2011/3/14 7:00	-0.04	3407	32.4	29	61.8	130	599	45
2011/3/14 7:30	-0.04	3408	32.4	30	61.5	130	599	45
2011/3/14 8:00	-0.04	3408	32.3	30	61.4	130	599	45
2011/3/14 8:30	-0.04	3408	32.2	29	61.4	130	598	45
2011/3/14 9:00	-0.04	3408	32.1	29	61.4	130	597	45
2011/3/14 9:30	-0.05	3410	32.0	30	61.2	130	599	45
2011/3/14 10:00	-0.05	3414	32.0	29	61.3	130	598	45
2011/3/14 10:30	-0.05	3419	31.8	30	61.0	130	598	45
2011/3/14 11:00	-0.05	3418	31.8	30	61.0	131	600	45
2011/3/14 11:30	-0.05	3418	31.8	30	61.1	131	600	45
2011/3/14 12:00	-0.05	3412	31.8	30	61.0	131	600	45
2011/3/14 12:30	-0.05	3414	31.8	30	61.0	131	600	45
2011/3/14 13:00	-0.05	3421	31.7	30	60.7	131	599	45

4号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPa)	S/C水位(mm)	S/C温度(°C)
表報値	7.07	321(L.B)		137	57	-	50	32
2011/3/14 0:00	0.31	3304	136.6	155	109.9	277	5050	126
2011/3/14 0:30	0.31	2884	138.9	158	109.9	280	5150	127
2011/3/14 1:00	0.31	2507	137.2	180	110.3	282	5160	127
2011/3/14 1:30	0.31	2118	137.4	183	110.5	285	5160	128
2011/3/14 2:00	0.32	1695	137.6	185	110.9	287	5150	128
2011/3/14 2:30	0.32	1230	137.7	169	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	292	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3135	138.4	173	112.5	296	5150	130
2011/3/14 4:30	0.33	2793	138.6	177	112.6	299	5150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.8	305	5200	132
2011/3/14 6:00	0.34	1648	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	846	139.7	192	113	315	5250	133
2011/3/14 7:30	0.35	3438	139.8	193	113.2	315	5200	133
2011/3/14 8:00	0.35	3107	140.4	197	113.5	318	5200	133
2011/3/14 8:30	0.35	2734	140.6	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:30	0.35	1949	141.2	207	114.3	329	5250	135
2011/3/14 10:00	0.36	1600	141.3	210	114.7	332	5250	135
2011/3/14 10:30	0.36	1144	141.6	214	115.1	335	5250	136
2011/3/14 11:00	0.37	663	141.9	218	115.6	339	5250	136
2011/3/14 11:30	0.38	3443	142.1	218	118	338	5200	138
2011/3/14 12:00	0.38	3080	142.7	229	116.4	342	5200	138
2011/3/14 12:30	0.38	2731	142.9	228	116.7	345	5200	137
2011/3/14 13:00	0.37	2319	143.1	229	117.3	344	5250	137

1号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/O圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
番報値	7.07	321(L3)		13.7	57	-	83	92
			炉水温度					
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	989	144	232	123.5	376	7363	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7396	126
2011/3/14 1:30	0.40	1011	144	235	124.1	383	7378	126
2011/3/14 2:00	0.89	1940	143	236	124.2	381	7408	126
2011/3/14 2:30	0.40	1650	144	238	124.3	378	7443	126
2011/3/14 3:00	0.39	744	143	236	124.5	375	7481	126
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5890	126
2011/3/14 4:00	0.37	1167	141	237	124.5	355	5867	124
2011/3/14 4:30	0.37	1727	141	233	124.5	352	5875	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5902	121
2011/3/14 5:30	0.37	1258	141	223	124.4	345	5908	120
2011/3/14 6:00	0.35	1896	139	220	124.2	342	5950	119
2011/3/14 6:30	0.36	1324	140	216	124.2	341	5960	117
2011/3/14 7:00	0.36	827	140	218	124.2	340	5992	116
2011/3/14 7:30	0.36	2000	140	216	124.1	338	6018	114
2011/3/14 8:00	0.35	1537	139	213	124.1	336	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6036	111
2011/3/14 9:00	0.35	1861	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1316	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	139	205	123.8	329	6061	108
2011/3/14 10:30	0.34	4205	139	200	123.8	324	5939	101
2011/3/14 11:00	0.22	4284	123	196	123.1	322	5901	99
2011/3/14 11:30	0.18	4588	113	192	119.3	319	5848	95
2011/3/14 12:00	0.11	4578	103	187	115.6	315	5872	94
2011/3/14 12:30	0.11	4588	103	182	112.6	311	5858	91
2011/3/14 13:00	0.10	4587	102	178	110.7	308	5848	89
2011/3/14 13:30	0.10	4588	102	174	108.9	305	5835	87
2011/3/14 14:00	0.09	4587	97	169	107.4	302	5823	85
2011/3/14 14:30	0.05	4587	84	166	106.3	301	5822	83

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
基準値	7.07	321(LS)		13.7	57	-	83	32
2011/3/14 0:00	0.39	1162	149	220.9	119.7	341	4990	135
2011/3/14 0:30	0.40	1255	144	221.5	119.9	342	4990	135
2011/3/14 1:00	0.42	994	146	224.6	120.1	348	4990	136
2011/3/14 1:30	0.41	1217	145	230.8	120.6	351	4990	136
2011/3/14 2:00	0.42	1099	146	233.4	120.8	359	4990	137
2011/3/14 2:30	0.43	1070	147	236.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	148	239.9	121.5	362	5000	137
2011/3/14 3:30	0.41	1275	146	243.7	121.8	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.8	122.8	370	5050	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	249.0	123.5	373	5200	138
2011/3/14 6:00	0.42	1292	146	246.4	123.8	373	5250	139
2011/3/14 6:30	0.45	916	148	249.6	123.9	374	5250	139
2011/3/14 7:00	0.44	964	147	249.7	124.2	373	5300	139
2011/3/14 7:30	0.49	1240	147	265.3	124.7	380	5350	139
2011/3/14 8:00	0.43	1246	147	245.6	124.9	370	5400	139
2011/3/14 8:30	0.44	881	147	239.3	124.7	364	5400	139
2011/3/14 9:00	0.42	1209	146	227.5	124.6	351	5400	139
2011/3/14 9:30	0.40	1288	144	218.9	124.5	340	5400	139
2011/3/14 10:00	0.41	1103	149	207.6	124.3	331	5400	139
2011/3/14 10:30	0.40	1204	144	202.8	124.1	328	5400	139
2011/3/14 11:00	0.36	2931	140	193.6	124.0	318	5350	139
2011/3/14 11:30	0.37	4188	141	186.9	123.4	308	5200	139
2011/3/14 12:00	0.31	4020	135	169.0	121.5	308	5200	139
2011/3/14 12:30	0.22	4089	123	188.1	118.8	303	5200	139
2011/3/14 13:00	0.16	4050	113	177.5	118.0	299	5200	139
2011/3/14 13:30	0.13	4255	107	170.6	112.9	292	5200	139
2011/3/14 14:00	0.12	4329	103	165.6	111.0	288	5200	139
2011/3/14 14:30	0.11	4269	103	161.6	109.1	282	5200	139

4号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L3)		13.7	87	-	50	32
2011/3/14 0:00	0.31	3904	136.6	155	109.9	277	5050	126
2011/3/14 0:30	0.31	2884	136.9	158	109.9	260	5150	127
2011/3/14 1:00	0.31	2507	137.2	160	110.8	282	5150	127
2011/3/14 1:30	0.31	2118	137.4	163	110.5	255	5150	128
2011/3/14 2:00	0.32	1695	137.6	165	110.9	287	5150	128
2011/3/14 2:30	0.32	1256	137.7	169	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	292	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3135	138.4	175	112.6	298	5150	130
2011/3/14 4:30	0.33	2783	138.6	177	112.6	299	5150	131
2011/3/14 5:00	0.33	2411	138.6	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	138.0	182	112.8	305	5200	132
2011/3/14 6:00	0.34	1648	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	648	139.7	192	113	315	5250	133
2011/3/14 7:30	0.36	3438	139.9	193	113.2	315	5200	133
2011/3/14 8:00	0.35	3107	140.4	197	113.6	318	5200	133
2011/3/14 8:30	0.35	2734	140.6	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:30	0.36	1949	141.2	207	114.3	329	5250	135
2011/3/14 10:00	0.36	1600	141.3	210	114.7	332	5250	136
2011/3/14 10:30	0.36	1144	141.6	214	115.1	335	5250	136
2011/3/14 11:00	0.37	883	141.9	218	115.8	338	5200	136
2011/3/14 11:30	0.38	3445	142.1	218	116	338	5200	136
2011/3/14 12:00	0.38	3080	142.7	223	116.4	342	5200	136
2011/3/14 12:30	0.38	2731	142.9	228	116.7	345	5200	137
2011/3/14 13:00	0.37	2318	143.1	223	117.3	344	5250	137
2011/3/14 13:30	0.37	1963	143.0	220	117.8	341	5350	137
2011/3/14 14:00	0.38	1581	143.0	225	118.2	348	5400	137
2011/3/14 14:30	0.37	1088	143.0	221	118.4	343	5450	137

2F

1号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
監視値	7.07	321(LA)		13.7	57	-	89	32
			炉水温度					
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	969	144	232	123.5	376	7383	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7398	126
2011/3/14 1:30	0.40	1011	144	235	124.1	383	7378	128
2011/3/14 2:00	0.39	1940	143	236	124.2	381	7408	126
2011/3/14 2:30	0.40	1650	144	238	124.3	378	7443	128
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	128
2011/3/14 3:30	0.39	1340	143	238	124.6	371	5880	126
2011/3/14 4:00	0.37	1187	141	237	124.6	368	5807	124
2011/3/14 4:30	0.37	1727	141	233	124.9	362	5875	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5802	121
2011/3/14 5:30	0.37	1298	141	223	124.4	349	5808	120
2011/3/14 6:00	0.38	1896	139	220	124.2	342	5950	119
2011/3/14 6:30	0.36	1924	140	218	124.2	341	5980	117
2011/3/14 7:00	0.36	827	140	218	124.2	340	5992	118
2011/3/14 7:30	0.36	2000	140	218	124.1	338	6018	114
2011/3/14 8:00	0.35	1937	139	213	124.1	336	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1881	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1310	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	139	205	123.8	329	6081	108
2011/3/14 10:30	0.34	4208	138	200	123.8	324	5999	101
2011/3/14 11:00	0.22	4284	123	196	123.1	322	5801	99
2011/3/14 11:30	0.16	4588	113	182	119.3	319	5848	99
2011/3/14 12:00	0.11	4578	103	187	115.6	315	5872	84
2011/3/14 12:30	0.11	4588	103	182	112.8	311	5858	81
2011/3/14 13:00	0.10	4587	102	178	110.7	308	5848	89
2011/3/14 13:30	0.10	4588	102	174	108.9	306	5835	87
2011/3/14 14:00	0.09	4587	97	169	107.4	302	5823	85
2011/3/14 14:30	0.09	4587	84	168	106.3	301	5832	83
2011/3/14 15:00	0.05	4587	84	163	105.2	298	5848	81

1 3
2 3

B = 40
14 = 20

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/C压力(kPaabs)	S/C水位(mm)	S/C温度(°C)
起動値	7.07	321(L3)		13.7	57	-	83	32
2011/3/14 0:00	0.38	1152	143	220.8	118.7	341	4950	135
2011/3/14 0:30	0.40	1255	144	221.5	118.9	342	4950	135
2011/3/14 1:00	0.42	964	146	224.6	120.1	346	4950	135
2011/3/14 1:30	0.41	1217	146	230.8	120.6	351	4950	136
2011/3/14 2:00	0.42	1039	148	233.4	120.9	355	4950	137
2011/3/14 2:30	0.43	1070	147	236.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	146	239.9	121.5	362	5000	137
2011/3/14 3:30	0.41	1275	145	243.7	121.8	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.8	122.8	370	5050	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	249.0	123.5	373	5200	138
2011/3/14 6:00	0.42	1292	148	248.4	123.6	373	5250	139
2011/3/14 6:30	0.45	918	148	249.6	123.9	374	5250	139
2011/3/14 7:00	0.44	984	147	249.7	124.2	373	5300	139
2011/3/14 7:30	0.43	1240	147	255.3	124.7	380	5350	138
2011/3/14 8:00	0.43	1246	147	245.8	124.9	370	5400	129
2011/3/14 8:30	0.44	991	147	239.3	124.7	364	5400	128
2011/3/14 9:00	0.42	1209	148	227.5	124.6	351	5400	123
2011/3/14 9:30	0.40	1285	144	216.9	124.5	340	5400	120
2011/3/14 10:00	0.41	1103	145	207.8	124.3	331	5400	118
2011/3/14 10:30	0.40	1204	144	202.8	124.1	328	5400	114
2011/3/14 11:00	0.36	2031	140	193.8	124.0	316	5350	112
2011/3/14 11:30	0.37	4160	141	185.3	123.4	308	5200	112
2011/3/14 12:00	0.31	4020	135	185.0	121.5	305	5200	110
2011/3/14 12:30	0.22	4089	123	186.1	118.6	303	5200	108
2011/3/14 13:00	0.19	4080	113	177.8	116.0	299	5200	106
2011/3/14 13:30	0.13	4255	107	170.6	112.8	292	5200	104
2011/3/14 14:00	0.12	4328	103	165.6	111.0	288	5200	101
2011/3/14 14:30	0.11	4269	103	161.6	109.1	282	5200	99
2011/3/14 15:00	0.09	4209	95	158.8	107.7	277	5200	96

3号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/O温度(°C)
基準値	7.07	321(L3)		13.7	57.0	-	60	32
2011/3/14 0:00	0.01	3419	33.9	29	62.6	129	598	48
2011/3/14 0:30	0.01	3414	33.7	29	62.9	130	599	48
2011/3/14 1:00	0.01	3414	33.6	29	62.4	130	598	49
2011/3/14 1:30	0.00	3419	33.4	29	62.4	130	597	48
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	599	46
2011/3/14 2:30	0.00	3410	33.1	29	62.9	130	598	46
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	598	48
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	48
2011/3/14 4:00	-0.01	3409	32.9	29	62.1	130	599	48
2011/3/14 4:30	-0.02	3408	32.8	29	62.0	130	599	45
2011/3/14 5:00	-0.02	3407	32.9	29	61.9	130	597	46
2011/3/14 5:30	-0.03	3409	32.7	29	61.9	130	598	45
2011/3/14 6:00	-0.03	3405	32.8	29	61.9	130	597	49
2011/3/14 6:30	-0.03	3406	32.6	29	61.8	130	598	45
2011/3/14 7:00	-0.04	3407	32.4	29	61.8	130	599	46
2011/3/14 7:30	-0.04	3406	32.4	30	61.6	130	599	46
2011/3/14 8:00	-0.04	3406	32.3	30	61.4	130	599	46
2011/3/14 8:30	-0.04	3406	32.2	29	61.4	130	598	46
2011/3/14 9:00	-0.04	3406	32.1	29	61.4	130	597	45
2011/3/14 9:30	-0.05	3416	32.0	30	61.2	130	598	45
2011/3/14 10:00	-0.05	3414	32.0	29	61.3	130	599	45
2011/3/14 10:30	-0.05	3413	31.9	30	61.0	130	598	46
2011/3/14 11:00	-0.05	3416	31.9	30	61.0	131	600	46
2011/3/14 11:30	-0.05	3416	31.9	30	61.1	131	600	48
2011/3/14 12:00	-0.05	3412	31.8	30	61.0	131	600	45
2011/3/14 12:30	-0.05	3414	31.8	30	61.0	131	600	45
2011/3/14 13:00	-0.05	3421	31.7	30	60.7	131	600	45
2011/3/14 13:30	-0.05	3419	31.7	30	60.8	131	598	49
2011/3/14 14:00	-0.05	3417	31.7	30	60.8	131	598	45
2011/3/14 14:30	-0.05	3423	31.8	30	60.7	131	598	46
2011/3/14 15:00	-0.06	3423	31.6	30	60.8	131	599	45

4号機

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/G圧力(kPaabs)	S/G水位(mm)	S/G温度(°C)
警報値	7.07	321(L3)		13.7	97		50	92
2011/3/14 0:00	0.31	3304	136.8	165	109.9	277	5050	128
2011/3/14 0:30	0.31	2884	136.9	158	109.8	280	5150	127
2011/3/14 1:00	0.31	2607	137.2	160	110.3	282	5150	127
2011/3/14 1:30	0.31	2118	137.4	163	110.8	285	5150	128
2011/3/14 2:00	0.32	1895	137.8	163	110.9	287	5150	129
2011/3/14 2:30	0.32	1238	137.7	168	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	292	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3155	138.4	175	112.5	296	5150	130
2011/3/14 4:30	0.33	2793	138.8	177	112.8	299	5150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.9	305	5200	132
2011/3/14 6:00	0.34	1648	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	648	139.7	192	113	315	5250	133
2011/3/14 7:30	0.36	3439	139.9	193	113.2	315	5200	133
2011/3/14 8:00	0.35	3107	140.4	197	113.5	319	5200	133
2011/3/14 8:30	0.35	2734	140.6	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:30	0.35	1949	141.2	207	114.3	329	5260	135
2011/3/14 10:00	0.36	1600	141.3	210	114.7	332	5250	135
2011/3/14 10:30	0.36	1144	141.8	214	115.1	335	5250	136
2011/3/14 11:00	0.37	683	141.9	218	115.5	339	5250	136
2011/3/14 11:30	0.38	3443	142.1	218	116	338	5200	136
2011/3/14 12:00	0.38	3080	142.7	223	116.4	342	5200	136
2011/3/14 12:30	0.38	2731	142.9	226	116.7	345	5200	137
2011/3/14 13:00	0.37	2319	143.1	223	117.3	344	5250	137
2011/3/14 13:30	0.37	1969	143.0	220	117.9	341	5350	137
2011/3/14 14:00	0.38	1581	143.0	225	118.2	346	5400	137
2011/3/14 14:30	0.37	1088	143.0	221	118.4	343	5480	137
2011/3/14 15:00	0.37	644	143.0	220	118.7	343	5550	136

2F トラート1.0ラメータ

時間	1号機							
	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L9)		13.7	57	-	83	32
			炉水温度					
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	999	144	232	123.5	378	7363	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7396	126
2011/3/14 1:30	0.40	1011	144	236	124.1	383	7378	126
2011/3/14 2:00	0.39	1840	149	236	124.2	381	7408	126
2011/3/14 2:30	0.40	1680	144	238	124.3	378	7443	126
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	126
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5880	128
2011/3/14 4:00	0.37	1167	141	237	124.5	356	5867	124
2011/3/14 4:30	0.37	1727	141	239	124.5	352	5876	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5902	121
2011/3/14 5:30	0.37	1258	141	229	124.4	346	5898	120
2011/3/14 6:00	0.35	1898	139	220	124.2	342	5950	119
2011/3/14 6:30	0.38	1324	140	218	124.2	341	5960	117
2011/3/14 7:00	0.36	827	140	218	124.2	340	5982	115
2011/3/14 7:30	0.38	2000	140	216	124.1	338	6018	114
2011/3/14 8:00	0.39	1597	139	213	124.1	336	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1861	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1316	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	139	205	123.8	329	6061	108
2011/3/14 10:30	0.34	4205	138	200	123.8	324	5939	101
2011/3/14 11:00	0.22	4294	123	199	123.1	322	5901	99
2011/3/14 11:30	0.16	4588	113	192	119.3	319	5848	85
2011/3/14 12:00	0.11	4578	103	187	115.8	315	5872	94
2011/3/14 12:30	0.11	4566	103	182	112.6	311	5858	81
2011/3/14 13:00	0.10	4587	102	178	110.7	308	5846	80
2011/3/14 13:30	0.10	4588	102	174	108.9	305	5835	87
2011/3/14 14:00	0.09	4587	97	169	107.4	302	5823	85
2011/3/14 14:30	0.05	4587	84	166	106.3	301	5832	88
2011/3/14 15:00	0.05	4567	84	163	105.2	298	5848	81
2011/3/14 15:30	0.08	4588	95	160	104.6	290	5785	80
2011/3/14 16:00	0.05	4688	84	158	103.8	293	5834	78

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/O圧力(kPaabs)	S/O水位(mm)	S/O温度(°C)
警報値	7.07	321(L3)		19.7	57	-	83	32
2011/3/14 0:00	0.39	1152	143	220.9	119.7	341	4950	136
2011/3/14 0:30	0.40	1255	144	221.5	119.9	342	4950	135
2011/3/14 1:00	0.42	964	148	224.8	120.1	346	4950	136
2011/3/14 1:30	0.41	1217	145	230.8	120.9	351	4950	136
2011/3/14 2:00	0.42	1039	148	233.4	120.9	355	4950	137
2011/3/14 2:30	0.43	1070	147	238.2	121.0	359	5000	137
2011/3/14 3:00	0.42	1173	148	239.9	121.5	362	5000	137
2011/3/14 3:30	0.41	1275	145	243.7	121.8	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.8	122.8	370	5050	139
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	139
2011/3/14 5:30	0.43	1141	147	249.0	123.5	373	5200	138
2011/3/14 6:00	0.42	1292	148	248.4	123.9	373	5250	139
2011/3/14 6:30	0.45	918	148	249.6	123.9	374	5250	139
2011/3/14 7:00	0.44	984	147	249.7	124.2	373	5300	139
2011/3/14 7:30	0.48	1240	147	255.3	124.7	380	5350	138
2011/3/14 8:00	0.43	1248	147	245.8	124.9	370	5400	129
2011/3/14 8:30	0.44	991	147	239.3	124.7	364	5400	128
2011/3/14 9:00	0.42	1209	146	227.5	124.8	351	5400	123
2011/3/14 9:30	0.40	1265	144	218.9	124.5	340	5400	120
2011/3/14 10:00	0.41	1103	145	207.8	124.3	331	5400	116
2011/3/14 10:30	0.40	1204	144	202.8	124.1	326	5400	114
2011/3/14 11:00	0.38	2931	140	193.8	124.0	318	5950	112
2011/3/14 11:30	0.37	4168	141	188.3	123.4	308	5200	112
2011/3/14 12:00	0.31	4020	136	185.0	121.5	308	5200	110
2011/3/14 12:30	0.22	4089	123	186.1	118.8	303	5200	108
2011/3/14 13:00	0.18	4050	119	177.5	118.0	299	5200	108
2011/3/14 13:30	0.13	4255	107	170.8	112.8	292	5200	104
2011/3/14 14:00	0.12	4928	103	165.8	111.0	286	5200	101
2011/3/14 14:30	0.11	4289	103	161.6	109.1	282	5200	99
2011/3/14 15:00	0.08	4208	95	158.8	107.7	277	5200	98
2011/3/14 15:30	0.09	4393	97	152.8	106.4	274	5200	93
2011/3/14 16:00	0.08	4371	95	148.4	105.7	269	5200	91

3号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L9)		13.7	57.0	-	50	32
2011/3/14 0:00	0.01	3419	33.9	29	62.6	129	598	46
2011/3/14 0:30	0.01	3414	33.7	29	62.6	130	598	46
2011/3/14 1:00	0.01	3414	33.8	29	62.4	130	598	46
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	597	46
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	598	46
2011/3/14 2:30	0.00	3410	33.1	29	62.3	130	598	46
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	598	46
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	46
2011/3/14 4:00	-0.01	3409	32.8	29	62.1	130	599	46
2011/3/14 4:30	-0.02	3406	32.8	29	62.0	130	599	45
2011/3/14 5:00	-0.02	3407	32.8	29	61.9	130	597	45
2011/3/14 5:30	-0.03	3409	32.7	29	61.9	130	598	46
2011/3/14 6:00	-0.03	3408	32.6	29	61.9	130	597	45
2011/3/14 6:30	-0.03	3408	32.5	28	61.8	130	598	45
2011/3/14 7:00	-0.04	3407	32.4	29	61.6	130	598	45
2011/3/14 7:30	-0.04	3408	32.4	30	61.5	130	599	45
2011/3/14 8:00	-0.04	3408	32.3	30	61.4	130	599	45
2011/3/14 8:30	-0.04	3408	32.2	29	61.4	130	598	45
2011/3/14 9:00	-0.04	3408	32.1	29	61.4	130	597	45
2011/3/14 9:30	-0.05	3410	32.0	30	61.2	130	598	45
2011/3/14 10:00	-0.05	3414	32.0	29	61.3	130	599	45
2011/3/14 10:30	-0.05	3413	31.9	30	61.0	130	598	45
2011/3/14 11:00	-0.05	3418	31.9	30	61.0	131	600	45
2011/3/14 11:30	-0.05	3416	31.8	30	61.1	131	600	49
2011/3/14 12:00	-0.05	3412	31.8	30	61.0	131	600	45
2011/3/14 12:30	-0.05	3414	31.9	30	61.0	131	600	45
2011/3/14 13:00	-0.05	3421	31.7	30	60.7	131	599	45
2011/3/14 13:30	-0.05	3419	31.7	30	60.8	131	598	45
2011/3/14 14:00	-0.05	3417	31.7	30	60.8	131	598	45
2011/3/14 14:30	-0.05	3423	31.8	30	60.7	131	598	45
2011/3/14 15:00	-0.05	3423	31.8	30	60.6	131	599	45
2011/3/14 15:30	-0.05	3427	31.9	30	60.7	131	600	45
2011/3/14 16:00	-0.05	3427	31.8	30	60.5	131	599	45

4号機

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
基準値	7.07	321(L3)		13.7	97	-	50	32
2011/3/14 0:00	0.31	3304	136.8	155	109.9	277	5050	128
2011/3/14 0:30	0.31	2884	136.8	168	109.9	280	5150	127
2011/3/14 1:00	0.31	2507	137.2	160	110.3	282	5150	127
2011/3/14 1:30	0.31	2118	137.4	183	110.5	285	5150	128
2011/3/14 2:00	0.32	1695	137.6	185	110.9	287	5150	128
2011/3/14 2:30	0.32	1296	137.7	188	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	282	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3198	138.4	175	112.5	296	5160	130
2011/3/14 4:30	0.33	2790	138.6	177	112.8	299	5150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.8	305	5200	132
2011/3/14 6:00	0.34	1648	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	646	139.7	192	113	315	5250	133
2011/3/14 7:30	0.36	3436	139.9	193	113.2	316	5200	133
2011/3/14 8:00	0.35	3107	140.4	197	113.6	319	5200	133
2011/3/14 8:30	0.35	2734	140.6	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:30	0.35	1949	141.2	207	114.3	329	5250	135
2011/3/14 10:00	0.36	1600	141.3	210	114.7	332	5250	136
2011/3/14 10:30	0.36	1144	141.6	214	115.1	335	5250	136
2011/3/14 11:00	0.37	883	141.9	218	115.6	339	5250	136
2011/3/14 11:30	0.38	3443	142.1	218	116	338	5200	136
2011/3/14 12:00	0.38	3080	142.7	223	116.4	342	5200	136
2011/3/14 12:30	0.38	2731	142.9	228	116.7	345	5200	137
2011/3/14 13:00	0.37	2919	143.1	223	117.3	344	5250	137
2011/3/14 13:30	0.37	1983	143.0	220	117.8	341	5350	137
2011/3/14 14:00	0.38	1591	143.0	225	118.2	348	5400	137
2011/3/14 14:30	0.37	1088	143.0	221	118.4	343	5450	137
2011/3/14 15:00	0.37	644	143.0	220	118.7	343	5550	138
2011/3/14 15:30	0.39	3374	142.9	218	118.7	341	6600	138
2011/3/14 16:00	0.38	2992	143.1	215	118.9	339	6550	138

2F

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
警報値	7.07	321(L3)		13.7	97	-	83	32
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	989	144	232	123.5	378	7363	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7398	126
2011/3/14 1:30	0.40	1011	144	235	124.1	369	7378	126
2011/3/14 2:00	0.39	1940	143	236	124.2	381	7408	126
2011/3/14 2:30	0.40	1850	144	238	124.3	376	7443	126
2011/3/14 3:00	0.39	744	143	238	124.5	376	7481	126
2011/3/14 3:30	0.39	1340	143	239	124.8	371	5990	126
2011/3/14 4:00	0.37	1167	141	237	124.5	366	5987	124
2011/3/14 4:30	0.37	1727	141	233	124.5	362	5975	122
2011/3/14 5:00	0.37	1100	141	227	124.3	349	5902	121
2011/3/14 5:30	0.37	1258	141	223	124.4	345	5908	120
2011/3/14 6:00	0.35	1898	139	220	124.2	342	5850	119
2011/3/14 6:30	0.36	1324	140	218	124.2	341	5860	117
2011/3/14 7:00	0.36	627	140	218	124.2	340	5892	118
2011/3/14 7:30	0.36	2000	140	218	124.1	338	6018	114
2011/3/14 8:00	0.35	1537	139	213	124.1	336	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1861	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1216	139	208	124.0	332	6059	109
2011/3/14 10:00	0.35	2088	139	205	123.8	329	6061	108
2011/3/14 10:30	0.34	4205	138	200	123.8	324	5938	101
2011/3/14 11:00	0.22	4294	123	198	123.1	322	5901	99
2011/3/14 11:30	0.16	4588	113	192	119.3	319	5848	96
2011/3/14 12:00	0.11	4578	109	187	116.6	315	5872	94
2011/3/14 12:30	0.11	4588	103	182	112.6	311	5858	91
2011/3/14 13:00	0.10	4587	102	178	110.7	308	5846	89
2011/3/14 13:30	0.10	4588	102	174	108.9	306	5835	87
2011/3/14 14:00	0.09	4587	97	169	107.4	302	5823	85
2011/3/14 14:30	0.05	4587	84	166	106.3	301	5832	83
2011/3/14 15:00	0.05	4587	84	163	106.2	298	5848	81
2011/3/14 15:30	0.08	4588	95	160	104.9	290	5785	80
2011/3/14 16:00	0.05	4588	84	158	103.6	293	5834	79
2011/3/14 16:30	0.04	4589	76	154	102.3	287	5829	76
2011/3/14 17:00	0.04	4589	76	153	101.8	285	5830	74
2011/3/14 17:30	0.04	4587	76	153	101.3	284	5832	72
2011/3/14 18:00	0.04	4589	76	150	100.8	282	5837	71
2011/3/14 18:30	0.04	4589	76					

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/C压力(kPaabs)	S/C水位(mm)	S/O温度(°C)
管線他	7.07	924(L3)	143	19.7	97	-	83	32
2011/3/14 0:00	0.39	1152	143	220.9	119.7	341	4950	139
2011/3/14 0:30	0.40	1255	144	221.5	119.9	342	4950	135
2011/3/14 1:00	0.42	994	148	224.6	120.1	346	4950	135
2011/3/14 1:30	0.41	1217	145	230.8	120.6	351	4950	137
2011/3/14 2:00	0.42	1039	148	233.4	120.9	355	4950	137
2011/3/14 2:30	0.43	1070	147	236.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	146	239.9	121.5	362	5000	138
2011/3/14 3:30	0.41	1275	145	243.7	121.9	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.6	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.6	122.8	370	5050	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	248.0	123.5	373	6200	138
2011/3/14 6:00	0.42	1292	148	248.4	123.6	373	6250	139
2011/3/14 6:30	0.45	916	148	249.5	123.9	374	8250	139
2011/3/14 7:00	0.44	984	147	249.7	124.2	373	8300	139
2011/3/14 7:30	0.43	1240	147	255.3	124.7	380	9950	138
2011/3/14 8:00	0.43	1246	147	245.9	124.9	370	5400	129
2011/3/14 8:30	0.44	991	147	239.9	124.7	364	6400	126
2011/3/14 9:00	0.42	1209	148	227.5	124.8	351	5400	123
2011/3/14 9:30	0.40	1285	144	218.9	124.5	340	5400	120
2011/3/14 10:00	0.41	1103	145	207.8	124.3	331	6400	118
2011/3/14 10:30	0.40	1204	144	202.8	124.1	326	5400	114
2011/3/14 11:00	0.38	2931	140	193.8	124.0	318	5350	112
2011/3/14 11:30	0.37	4168	141	166.3	123.4	306	6200	112
2011/3/14 12:00	0.31	4020	136	185.0	121.5	308	5200	110
2011/3/14 12:30	0.22	4089	123	188.1	118.8	303	5200	108
2011/3/14 13:00	0.19	4050	113	177.5	118.0	298	5200	108
2011/3/14 13:30	0.13	4255	107	170.6	112.8	282	5200	104
2011/3/14 14:00	0.12	4329	103	165.6	111.0	286	5200	101
2011/3/14 14:30	0.11	4269	103	161.8	109.1	282	5200	99
2011/3/14 15:00	0.08	4208	95	156.6	107.7	277	5200	98
2011/3/14 15:30	0.09	4393	97	152.8	108.4	273	5200	93
2011/3/14 16:00	0.09	4371	95	148.4	105.7	269	5200	91
2011/3/14 16:30	0.04	4169	78	141.6	103.9	261	5200	86
2011/3/14 17:00	0.04	4099	76	138.4	103.2	256	5200	84
2011/3/14 17:30	0.05	4259	84	135.9	102.6	255	5200	82
2011/3/14 18:00	0.05	4334	88	133.4	102.2	253	5200	80

9号罐								
時間	炉压(Mpa)	炉水位(mm)	炉水温度(°C)	D/W压力(kPa)	D/W温度(°C)	S/O压力(kPaabs)	S/O水位(mm)	S/O温度(°C)
集報値	7.07	321(L3)		13.7	57.0	-	50	32
2011/3/14 0:00	0.01	3418	33.9	29	62.8	128	598	48
2011/3/14 0:30	0.01	3414	33.7	29	62.8	130	598	48
2011/3/14 1:00	0.01	3414	33.8	29	62.4	130	598	48
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	597	48
2011/3/14 2:00	0.00	3408	33.3	29	62.4	130	598	46
2011/3/14 2:30	0.00	3410	33.1	29	62.3	130	598	48
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	599	48
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	48
2011/3/14 4:00	-0.01	3409	32.9	29	62.1	130	599	48
2011/3/14 4:30	-0.02	3408	32.8	29	62.0	130	599	45
2011/3/14 5:00	-0.02	3407	32.8	29	61.9	130	597	45
2011/3/14 5:30	-0.03	3409	32.7	29	61.9	130	598	45
2011/3/14 6:00	-0.03	3405	32.6	29	61.9	130	597	45
2011/3/14 6:30	-0.03	3406	32.5	29	61.8	130	598	45
2011/3/14 7:00	-0.04	3407	32.4	29	61.8	130	599	49
2011/3/14 7:30	-0.04	3408	32.4	30	61.5	130	598	49
2011/3/14 8:00	-0.04	3408	32.3	30	61.4	130	598	45
2011/3/14 8:30	-0.04	3409	32.2	29	61.4	130	597	45
2011/3/14 9:00	-0.04	3408	32.1	29	61.4	130	598	45
2011/3/14 9:30	-0.05	3418	32.0	30	61.2	130	598	45
2011/3/14 10:00	-0.05	3414	32.0	29	61.3	130	598	45
2011/3/14 10:30	-0.05	3413	31.9	30	61.0	130	598	45
2011/3/14 11:00	-0.05	3418	31.9	30	61.0	131	600	45
2011/3/14 11:30	-0.05	3418	31.8	30	61.1	131	600	45
2011/3/14 12:00	-0.05	3412	31.8	30	61.0	131	600	45
2011/3/14 12:30	-0.05	3414	31.8	30	61.0	131	600	46
2011/3/14 13:00	-0.05	3421	31.7	30	60.7	131	599	45
2011/3/14 13:30	-0.05	3418	31.7	30	60.8	131	598	45
2011/3/14 14:00	-0.05	3417	31.7	30	60.8	131	598	45
2011/3/14 14:30	-0.05	3423	31.6	30	60.7	131	598	45
2011/3/14 15:00	-0.05	3423	31.6	30	60.8	131	600	49
2011/3/14 15:30	-0.05	3427	31.6	30	60.7	131	600	49
2011/3/14 16:00	-0.05	3427	31.6	30	60.5	131	599	45
2011/3/14 16:30	-0.05	3428	31.4	31	60.8	131	598	45
2011/3/14 17:00	-0.05	3429	31.4	30	60.4	131	600	45
2011/3/14 17:30	-0.05	3430	31.3	31	60.4	132	597	46
2011/3/14 18:00	-0.05	3445	31.3	31	60.3	132	598	45
2011/3/14 18:30	-0.05	3440	31.2	31	60.3	132	598	45

4号機

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
	7.07	321(L9)		13.7	57	-	50	32
警報値								
2011/3/14 0:00	0.31	3304	138.8	155	109.9	277	5050	128
2011/3/14 0:30	0.31	2984	136.9	158	109.9	280	5150	127
2011/3/14 1:00	0.31	2807	137.2	180	110.3	282	5150	127
2011/3/14 1:30	0.31	2118	137.4	163	110.8	285	5160	128
2011/3/14 2:00	0.32	1895	137.8	165	110.9	287	5150	128
2011/3/14 2:30	0.32	1288	137.7	168	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.8	292	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3135	138.4	176	112.5	298	5150	130
2011/3/14 4:30	0.33	2793	138.8	177	112.8	299	5150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.8	305	5200	132
2011/3/14 6:00	0.34	1646	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	646	139.7	192	113	316	5250	133
2011/3/14 7:30	0.35	3498	139.9	193	113.2	315	5200	133
2011/3/14 8:00	0.35	3107	140.4	197	113.5	319	5200	133
2011/3/14 8:30	0.35	2734	140.8	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	134
2011/3/14 9:30	0.36	1949	141.2	207	114.3	328	5250	135
2011/3/14 10:00	0.36	1800	141.3	210	114.7	332	5250	135
2011/3/14 10:30	0.36	1144	141.8	214	115.1	335	5250	136
2011/3/14 11:00	0.37	583	141.9	218	115.6	339	5250	136
2011/3/14 11:30	0.36	3443	142.1	216	116	339	5200	136
2011/3/14 12:00	0.38	3080	142.7	223	116.4	342	5200	136
2011/3/14 12:30	0.38	2731	142.9	226	116.7	345	5200	137
2011/3/14 13:00	0.37	2316	143.1	223	117.3	344	5250	137
2011/3/14 13:30	0.37	1863	143.0	220	117.8	341	5350	137
2011/3/14 14:00	0.38	1561	143.0	225	118.2	348	5400	137
2011/3/14 14:30	0.37	1088	143.0	221	118.4	343	5450	137
2011/3/14 15:00	0.37	644	143.0	220	118.7	343	5550	138
2011/3/14 15:30	0.38	3374	142.8	218	119.7	341	5600	138
2011/3/14 16:00	0.38	2992	143.1	215	118.9	339	5550	136
2011/3/14 16:30	0.37	2547	142.9	211	119	338	5800	134
2011/3/14 17:00	0.36	2135	142.6	203	119	328	5800	133
2011/3/14 17:30	0.36	1785	142.3	203	119	328	5800	132
2011/3/14 18:00	0.36	1462	142.0	201	119	328	5800	131
2011/3/14 18:30	0.35	900	141.8	199	119	324	5800	130

1号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/O圧力(kPaabs)	S/O水位(mm)	S/O温度(°C)
警報値	7.07	321(L3)		13.7	57	-	63	32
2011/3/13 8:00	0.29	1628	137	184	115.3	288	6190	128
2011/3/13 8:30	0.3	1628	134	189	116.8	294	6130	126
2011/3/13 9:00	0.31	1180	135	174	116.1	289	6145	127
2011/3/13 9:30	0.32	810	136	178	116.5	301	6116	123.3
2011/3/13 10:00	0.31	1321	135	179	116.9	304	6122	124.3
2011/3/13 10:30	0.32	1373	136	184	117.3	308	6155	126
2011/3/13 11:00	0.32	1016	136	184	117.4	300	6305	128.8
2011/3/13 11:30	0.31	1910	135	185	117.8	302	6371	130
2011/3/13 12:00	0.32	1204	138	174	118.3	302	6478	129
2011/3/13 12:30	0.31	909	136	189	119.8	299	6872	129
2011/3/13 13:00	0.31	1127	135	181	120.5	295	6880	129
2011/3/13 13:30	0.31	1392	133	188	120.6	294	7083	128
2011/3/13 14:00	0.31	1075	136	184	120.3	300	7088	128
2011/3/13 14:30	0.32	1238	136	187	119.5	304	7088	128
2011/3/13 15:00	0.32	907	136	188	119.9	308	7089	128
2011/3/13 15:30	0.32	885	138	173	118.7	312	7108	128
2011/3/13 16:00	0.33	1130	137	177	118.8	318	7122	116
2011/3/13 16:30	0.32	1375	136	180	118.8	319	7141	119
2011/3/13 17:00	0.34	981	138	185	119	325	7145	115
2011/3/13 17:30	0.59	1260	139	188	119.3	327	7167	116
2011/3/13 18:00	0.34	1250	138	191	119.5	333	7168	117
2011/3/13 18:30	0.38	880	138	195	119.9	337	7168	120
2011/3/13 19:00	0.35	1017	140	198	120.1	342	7173	120
2011/3/13 19:30	0.35	1236	139	200	120.4	344	7184	121
2011/3/13 20:00	0.37	940	141	204	120.8	350	7180	122
2011/3/13 20:30	0.37	985	141	208	121.0	354	7178	122
2011/3/13 21:00	0.38	1238	142	208	121.4	367	7184	122
2011/3/13 21:30	0.38	1250	142	211	121.8	361	7190	122
2011/3/13 22:00	0.38	1150	142	220	121.4	365	7248	126
2011/3/13 22:30	0.38	2018	143	222	121.9	368	7241	126
2011/3/13 23:00	0.38	1847	143	222	122.5	372	7235	126
2011/3/13 23:30	0.40	2000	144	230	122.2	376	7299	124
2011/3/14 0:00	0.40	1722	144	232	123.4	377	7331	126
2011/3/14 0:30	0.40	969	144	232	123.5	378	7369	126
2011/3/14 1:00	0.40	2001	144	233	123.7	375	7388	128
2011/3/14 1:30	0.40	1011	144	235	124.1	383	7378	126
2011/3/14 2:00	0.39	1940	143	238	124.2	381	7408	126
2011/3/14 2:30	0.40	1850	144	238	124.3	378	7443	126
2011/3/14 3:00	0.39	744	143	238	124.5	378	7481	126
2011/3/14 3:30	0.39	1340	143	238	124.5	371	5880	126
2011/3/14 4:00	0.37	1167	141	237	124.5	358	5867	124
2011/3/14 4:30	0.37	1727	141	233	124.5	362	5875	122
2011/3/14 5:00	0.37	1100	141	227	124.3	348	5902	121
2011/3/14 5:30	0.37	1258	141	223	124.4	345	5908	120
2011/3/14 6:00	0.38	1888	139	220	124.2	342	5950	119
2011/3/14 6:30	0.38	1324	140	218	124.2	341	5980	117
2011/3/14 7:00	0.38	827	140	219	124.2	340	5992	115
2011/3/14 7:30	0.38	2000	140	218	124.1	338	6018	114
2011/3/14 8:00	0.35	1637	139	213	124.1	338	6030	114
2011/3/14 8:30	0.35	774	139	211	124.1	335	6039	111
2011/3/14 9:00	0.35	1881	139	210	124.0	333	6050	110
2011/3/14 9:30	0.35	1316	139	208	124.0	332	6058	109
2011/3/14 10:00	0.35	2088	138	205	123.8	329	6081	108
2011/3/14 10:30	0.34	4208	138	200	123.8	324	5938	101
2011/3/14 11:00	0.22	4294	123	195	123.1	322	5901	98
2011/3/14 11:30	0.18	4588	113	192	119.3	319	5848	95
2011/3/14 12:00	0.11	4578	103	187	115.8	315	5872	94
2011/3/14 12:30	0.11	4588	103	182	112.8	311	5858	91
2011/3/14 13:00	0.10	4587	102	178	110.7	308	5846	89
2011/3/14 13:30	0.10	4588	102	174	108.9	305	5835	87
2011/3/14 14:00	0.09	4587	97	169	107.4	302	5823	85
2011/3/14 14:30	0.05	4587	84	168	108.3	301	5832	83
2011/3/14 15:00	0.05	4587	84	163	105.2	298	5848	81
2011/3/14 15:30	0.08	4588	95	160	104.5	293	5795	80
2011/3/14 16:00	0.05	4588	84	158	103.6	289	5834	78
2011/3/14 17:00	0.04	4589	78	154	102.3	287	5829	78
2011/3/14 17:30	0.04	4587	78	153	101.8	285	5830	74
2011/3/14 18:00	0.04	4889	78	153	101.3	284	5832	72
2011/3/14 18:30	0.04	4589	78	180	100.8	282	5837	71
2011/3/14 19:00	0.04	4522	78	148	100.3	281	5844	73
2011/3/14 19:30	0.04	4589	78	148	99.5	278	5828	71
2011/3/14 20:00	0.05	4589	84	144	99.1	277	5820	71
2011/3/14 20:30	0.08	4589	88	142	98.5	275	5822	71
2011/3/14 21:00	0.05	4588	84	141	97.8	274	5825	72
2011/3/14 21:30	0.05	4578	84	139	97.1	272	5829	73
2011/3/14 22:00	0.05	4510	84	138	96.8	271	5831	72
2011/3/14 22:30	0.05	4391	84	137	96.1	269	5832	72
2011/3/14 23:00	0.08	4589	95	135	95.8	267	5777	70

時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
観測値	7.07	321(L3)		13.7	57		83	32
2011/3/13 8:00	0.33	1085	137	185.8	110.8	289	3100	132
2011/3/13 8:30	0.31	1284	159	183.7	111	287	3150	132
2011/3/13 9:00	0.31	1225	135	184.9	113.6	280	3200	132
2011/3/13 9:30	0.33	1073	137	180.9	111.8	285	3300	132
2011/3/13 10:00	0.32	1312	138	179.9	112	288	3400	131
2011/3/13 10:30	0.32	1054	138	181.8	112.2	289	3480	131
2011/3/13 11:00	0.33	1103	137	182.8	112.8	290	3500	131
2011/3/13 11:30	0.33	1308	187	189.6	113.3	297	3500	132
2011/3/13 12:00	0.34	1059	138	185.6	113.5	294	3800	132
2011/3/13 12:30	0.35	1084	139	181.2	113.4	290	3700	132
2011/3/13 13:00	0.38	1378	137	185.6	113.9	295	3750	132
2011/3/13 13:30	0.37	918	141	183.1	113.3	284	3800	132
2011/3/13 14:00	0.36	1182	140	180.9	113.8	283	3900	132
2011/3/13 14:30	0.34	1485	138	185.9	114.1	297	4000	132
2011/3/13 15:00	0.37	1190	141	180.8	113.8	283	4000	132
2011/3/13 15:30	0.37	1290	141	182.8	114.3	295	4050	132
2011/3/13 16:00	0.37	1079	141	185.3	114.2	299	4150	132
2011/3/13 16:30	0.39	1067	143	182.8	114.5	297	4200	132
2011/3/13 17:00	0.39	1183	143	180.8	115.2	305	4250	132
2011/3/13 17:30	0.38	1228	142	184.3	115.7	308	4300	133
2011/3/13 18:00	0.37	1258	141	199	118.2	314	4300	133
2011/3/13 18:30	0.37	1258	141	204	118.4	318	4300	134
2011/3/13 19:00	0.39	1130	143	208.0	117.0	324	4300	135
2011/3/13 19:30	0.40	1077	144	212.1	117.3	327	4300	135
2011/3/13 20:00	0.41	1022	145	211.8	117.9	328	4350	135
2011/3/13 20:30	0.40	1226	144	212.4	117.9	328	4400	135
2011/3/13 21:00	0.40	1132	144	214.9	118.2	332	4800	135
2011/3/13 21:30	0.41	1020	145	210.6	118.3	328	4850	138
2011/3/13 22:00	0.40	1170	144	210.8	118.8	328	4850	138
2011/3/13 22:30	0.40	1024	144	214.3	119.7	333	4700	135
2011/3/13 23:00	0.41	1023	145	208.9	118.9	330	4900	135
2011/3/13 23:30	0.40	1273	144	210.6	119.3	331	4800	135
2011/3/14 0:00	0.39	1132	143	220.8	118.7	341	4950	135
2011/3/14 0:30	0.40	1256	144	221.5	119.9	342	4950	135
2011/3/14 1:00	0.42	984	148	224.8	120.1	348	4950	135
2011/3/14 1:30	0.41	1217	145	230.6	120.6	351	4950	138
2011/3/14 2:00	0.42	1039	148	233.4	120.8	355	4950	137
2011/3/14 2:30	0.43	1070	147	238.2	121.0	358	5000	137
2011/3/14 3:00	0.42	1173	148	238.9	121.5	362	5000	137
2011/3/14 3:30	0.41	1276	145	243.7	121.8	365	5000	138
2011/3/14 4:00	0.43	1103	147	247.8	122.8	369	5050	138
2011/3/14 4:30	0.43	1014	147	247.8	122.8	370	5050	138
2011/3/14 5:00	0.44	904	147	248.1	122.9	372	5100	138
2011/3/14 5:30	0.43	1141	147	249.0	123.5	373	5200	138
2011/3/14 6:00	0.42	1292	148	248.4	123.3	373	5250	139
2011/3/14 6:30	0.44	918	148	249.8	123.8	374	5250	139
2011/3/14 7:00	0.44	984	147	249.7	124.2	379	5300	139
2011/3/14 7:30	0.43	1240	147	253.3	124.7	380	5350	138
2011/3/14 8:00	0.43	1248	147	245.8	124.9	370	5400	129
2011/3/14 8:30	0.44	991	147	238.3	124.7	384	5400	128
2011/3/14 9:00	0.42	1208	148	227.8	124.8	351	5400	123
2011/3/14 9:30	0.40	1286	144	218.9	124.5	340	5400	120
2011/3/14 10:00	0.41	1103	148	207.8	124.3	391	5400	118
2011/3/14 10:30	0.40	1204	144	202.8	124.1	328	5400	114
2011/3/14 11:00	0.38	2931	140	183.3	124.0	318	5850	112
2011/3/14 11:30	0.37	4188	141	188.3	123.4	308	6200	112
2011/3/14 12:00	0.31	4020	135	185.0	121.5	308	6200	110
2011/3/14 12:30	0.22	4089	123	188.1	118.8	303	5200	108
2011/3/14 13:00	0.16	4050	113	177.5	118.0	288	5200	108
2011/3/14 13:30	0.19	4255	107	170.8	112.8	282	5200	104
2011/3/14 14:00	0.12	4323	103	165.8	111.0	288	6200	101
2011/3/14 14:30	0.11	4289	103	161.8	109.1	282	6200	99
2011/3/14 15:00	0.08	4208	95	158.8	107.7	277	6200	98
2011/3/14 15:30	0.09	4383	97	162.8	108.4	273	6200	93
2011/3/14 16:00	0.08	4371	95	148.4	103.7	288	6200	91
2011/3/14 17:00	0.04	4186	78	141.8	103.9	281	6200	88
2011/3/14 17:30	0.04	4095	78	138.4	103.2	288	6200	84
2011/3/14 18:00	0.05	4288	84	135.8	102.8	255	6200	82
2011/3/14 18:30	0.06	4334	86	133.4	102.2	293	6200	80
2011/3/14 19:00	0.05	4218	84	130.8	101.5	250	6200	78
2011/3/14 19:30	0.08	4137	84	128.8	100.9	247	6200	76
2011/3/14 20:00	0.05	4140	84	125.8	100.5	245	6200	75
2011/3/14 20:30	0.05	4140	84	122.1	98.8	242	6200	73
2011/3/14 21:00	0.05	4143	84	120.8	98.3	240	6150	72
2011/3/14 21:30	0.05	4148	84	118.1	98.9	237	6150	70
2011/3/14 22:00	0.05	4148	84	118.8	98.8	235	6150	69
2011/3/14 22:30	0.05	4148	84	113.1	98.2	233	6150	67
2011/3/14 23:00	0.05	4148	84	112.5	97.9	231	6150	66

時間 兼報値	3号機							
	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/G圧力(kPaabs)	S/G水位(mm)	S/G温度(°C)
	7.07	321(L3)		13.7	57.0		50	92
2011/3/13 8:00	-0.01	1531	48.2	29	65.5	128	608	64
2011/3/13 8:30	-0.01	1531	44.5	26	65.4	127	602	32
2011/3/13 9:00	0.00	1531	71.4	29	65.2	120	610	49
2011/3/13 9:30	0.08	1531	86.8	28	65.5	120	634	46
2011/3/13 10:00	0.10	1531	90.0	28	65.7	126	652	44
2011/3/13 10:30	0.10	1532	92.0	28	66.3	128	660	43
2011/3/13 11:00	0.00	1531	95.0	29	66.8	128	593	31
2011/3/13 11:30	-0.03	4182	85.4	28	66.0	120	594	82
2011/3/13 12:00	-0.03	3849	86.7	28	65.2	126	601	51
2011/3/13 12:30	-0.03	3864	89.2	27	65.0	127	598	49
2011/3/13 13:00	-0.02	3958	65.2	29	64.7	128	600	47
2011/3/13 13:30	0.02	3918	76.1	27	64.7	129	598	47
2011/3/13 14:00	0.04	3731	82.3	29	64.8	129	600	47
2011/3/13 14:30	0.04	3541	55.4	29	65.0	129	599	47
2011/3/13 15:00	0.04	3587	49.8	29	64.6	129	599	47
2011/3/13 15:30	0.04	3549	45.9	29	64.8	129	598	47
2011/3/13 16:00	0.04	3627	43.3	29	64.4	129	608	48
2011/3/13 16:30	0.04	3504	41.4	28	64.3	129	598	46
2011/3/13 17:00	0.04	3497	40.5	28	64.1	129	600	46
2011/3/13 17:30	0.04	3490	40.0	29	64.0	129	599	45
2011/3/13 18:00	0.03	3479	39.1	28	63.9	129	598	48
2011/3/13 18:30	0.03	3489	38.2	29	63.8	129	598	48
2011/3/13 19:00	0.03	3484	38.1	29	63.8	129	599	46
2011/3/13 19:30	0.03	3458	37.8	28	63.5	129	600	46
2011/3/13 20:00	0.03	3457	35.4	29	63.4	129	598	46
2011/3/13 20:30	0.03	3461	36.6	29	63.3	129	599	46
2011/3/13 21:00	0.03	3454	37.3	28	63.2	129	598	49
2011/3/13 21:30	0.03	3442	36.2	29	63.3	129	598	49
2011/3/13 22:00	0.02	3493	35.4	29	63.2	129	599	46
2011/3/13 22:30	0.02	3428	34.9	29	62.8	130	598	46
2011/3/13 23:00	0.02	3423	34.5	29	63.0	130	600	46
2011/3/13 23:30	0.02	3410	34.2	29	62.8	129	599	46
2011/3/14 0:00	0.01	3419	33.9	29	62.6	129	598	48
2011/3/14 0:30	0.01	3414	33.7	29	62.5	130	608	48
2011/3/14 1:00	0.01	3414	33.6	29	62.4	130	598	46
2011/3/14 1:30	0.00	3413	33.4	29	62.4	130	597	46
2011/3/14 2:00	0.00	3409	33.3	29	62.4	130	598	48
2011/3/14 2:30	0.00	3410	33.1	28	62.3	130	596	46
2011/3/14 3:00	-0.01	3410	33.1	29	62.3	130	598	48
2011/3/14 3:30	-0.01	3410	33.0	29	62.1	130	599	46
2011/3/14 4:00	-0.01	3409	32.9	28	62.1	130	599	46
2011/3/14 4:30	-0.02	3408	32.8	29	62.0	130	599	45
2011/3/14 5:00	-0.02	3407	32.8	29	61.9	130	597	45
2011/3/14 5:30	-0.03	3409	32.7	29	61.9	130	598	45
2011/3/14 6:00	-0.03	3405	32.6	29	61.9	130	597	45
2011/3/14 6:30	-0.03	3406	32.5	29	61.9	130	598	45
2011/3/14 7:00	-0.04	3407	32.4	29	61.8	130	598	45
2011/3/14 7:30	-0.04	3408	32.4	30	61.9	130	599	45
2011/3/14 8:00	-0.04	3408	32.3	30	61.4	130	599	45
2011/3/14 8:30	-0.04	3408	32.2	29	61.4	130	598	45
2011/3/14 9:00	-0.04	3408	32.1	29	61.4	130	597	45
2011/3/14 9:30	-0.05	3418	32.0	30	61.2	130	598	45
2011/3/14 10:00	-0.05	3414	32.0	29	61.3	130	599	45
2011/3/14 10:30	-0.05	3413	31.9	30	61.0	130	598	45
2011/3/14 11:00	-0.05	3416	31.9	30	61.0	131	600	45
2011/3/14 11:30	-0.05	3416	31.8	30	61.1	131	600	45
2011/3/14 12:00	-0.05	3412	31.8	30	61.0	131	600	45
2011/3/14 12:30	-0.05	3414	31.8	30	61.0	131	599	45
2011/3/14 13:00	-0.05	3421	31.7	30	60.7	131	599	45
2011/3/14 13:30	-0.05	3419	31.7	30	60.8	131	598	45
2011/3/14 14:00	-0.05	3417	31.7	30	60.8	131	598	45
2011/3/14 14:30	-0.05	3423	31.6	30	60.7	131	598	45
2011/3/14 15:00	-0.06	3423	31.8	30	60.6	131	600	45
2011/3/14 15:30	-0.05	3427	31.8	30	60.7	131	600	45
2011/3/14 16:00	-0.05	3427	31.5	30	60.5	131	599	45
2011/3/14 16:30	-0.06	3426	31.4	31	60.6	131	599	45
2011/3/14 17:00	-0.06	3428	31.4	30	60.4	131	600	45
2011/3/14 17:30	-0.06	3430	31.3	31	60.4	131	597	45
2011/3/14 18:00	-0.06	3445	31.3	31	60.3	132	598	45
2011/3/14 18:30	-0.06	3440	31.2	31	60.3	132	598	45
2011/3/14 19:00	-0.06	3431	31.2	31	60.2	132	598	45
2011/3/14 19:30	-0.06	3439	31.1	31	60.3	132	598	45
2011/3/14 20:00	-0.06	3433	31.1	31	60.2	132	598	45
2011/3/14 20:30	-0.06	3431	31.1	31	60.2	132	598	45
2011/3/14 21:00	-0.06	3450	31.0	31	60.1	132	596	45
2011/3/14 21:30	-0.06	3442	30.9	31	60.1	132	599	45
2011/3/14 22:00	-0.06	3435	30.9	31	60.1	132	600	45
2011/3/14 22:30	-0.06	3434	30.8	31	60.1	132	598	45
2011/3/14 23:00	-0.06	3442	30.6	31	59.9	132	599	45

4号機								
時間	炉圧(Mpa)	炉水位(mm)	炉水温度(°C)	D/W圧力(kPa)	D/W温度(°C)	S/C圧力(kPaabs)	S/C水位(mm)	S/C温度(°C)
監視値	7.07	321(L3)		13.7	57	-	50	32
2011/3/13 8:00	0.24	1497	130.7	102	90	216	4400	113
2011/3/13 8:30	0.24	1498	130.6	103	81.6	217	4450	113
2011/3/13 9:00	0.24	1114	130.9	104	88.3	218	4550	114
2011/3/13 9:30	0.25	1497	130.5	104	100.1	219	4600	114
2011/3/13 10:00	0.25	1497	131.2	105	100.5	221	4600	114
2011/3/13 10:30	0.24	1498	131.1	105	100.6	222	4650	114
2011/3/13 11:00	0.24	1497	131.0	108	101.3	224	4700	114
2011/3/13 11:30	0.24	1383	131.0	107	101.6	225	4800	114
2011/3/13 12:00	0.25	1093	131.0	113	102	231	4850	115
2011/3/13 12:30	0.25	568	131.3	118	102.4	238	4850	115
2011/3/13 13:00	0.26	3312	131.8	119	102.9	237	4800	118
2011/3/13 13:30	0.26	2824	132.8	120	103.1	238	4800	118
2011/3/13 14:00	0.26	2411	132.6	122	103.5	240	4850	117
2011/3/13 14:30	0.26	1964	132.5	123	103.8	242	4850	117
2011/3/13 15:00	0.26	1519	132.5	125	104.1	244	4900	118
2011/3/13 15:30	0.26	882	132.5	126	104.3	248	4950	119
2011/3/13 16:00	0.26	488	132.6	128	104.7	249	5000	119
2011/3/13 16:30	0.26	3329	133.2	129	104.9	249	4900	120
2011/3/13 17:00	0.26	3003	133.9	130	105.2	249	4900	120
2011/3/13 17:30	0.29	2594	134.4	132	105.7	251	4950	120
2011/3/13 18:00	0.29	2182	134.8	131	106.4	253	4950	121
2011/3/13 18:30	0.29	1759	135.0	135	106.8	255	5000	121
2011/3/13 19:00	0.28	1179	135.0	137	107.2	259	5050	122
2011/3/13 19:30	0.27	681	134.8	139	107.6	260	5050	122
2011/3/13 20:00	0.3	3391	134.2	140	108	260	5000	123
2011/3/13 20:30	0.3	3050	134.9	142	107.9	262	5000	123
2011/3/13 21:00	0.3	2702	135.4	143	108.5	264	5050	124
2011/3/13 21:30	0.3	2319	135.7	145	108.8	268	5050	124
2011/3/13 22:00	0.3	1899	135.9	147	109	268	5150	125
2011/3/13 22:30	0.3	1448	136.1	149	109.1	270	5150	125
2011/3/13 23:00	0.3	1000	136.3	151	109.3	272	5150	125
2011/3/13 23:30	0.31	512	136.5	154	109.6	276	5200	126
2011/3/14 0:00	0.31	3304	136.6	155	109.9	277	5050	126
2011/3/14 0:30	0.31	2884	136.9	158	109.9	280	5150	127
2011/3/14 1:00	0.31	2507	137.2	160	110.3	282	5150	127
2011/3/14 1:30	0.31	2118	137.4	163	110.5	285	5150	128
2011/3/14 2:00	0.32	1695	137.6	165	110.9	287	5150	128
2011/3/14 2:30	0.32	1238	137.7	165	111.4	290	5200	129
2011/3/14 3:00	0.32	784	137.9	170	111.6	292	5200	129
2011/3/14 3:30	0.33	320	138.1	173	112.2	295	5200	130
2011/3/14 4:00	0.33	3135	138.4	175	112.3	296	5150	130
2011/3/14 4:30	0.33	2789	138.6	177	112.6	299	5150	131
2011/3/14 5:00	0.33	2411	138.8	180	112.8	302	5150	131
2011/3/14 5:30	0.33	2012	139.0	182	112.8	305	5200	132
2011/3/14 6:00	0.34	1648	139.2	185	112.9	308	5200	132
2011/3/14 6:30	0.34	1202	139.4	188	113	311	5250	132
2011/3/14 7:00	0.34	846	139.7	192	113	315	5250	133
2011/3/14 7:30	0.36	3438	139.9	193	113.2	315	5200	133
2011/3/14 8:00	0.35	3107	140.4	197	113.9	319	5200	133
2011/3/14 8:30	0.35	2734	140.8	200	113.7	322	5200	134
2011/3/14 9:00	0.35	2359	140.9	203	113.9	325	5200	135
2011/3/14 9:30	0.35	1949	141.2	207	114.3	329	5280	135
2011/3/14 10:00	0.36	1600	141.3	210	114.7	332	5250	135
2011/3/14 10:30	0.36	1144	141.6	214	115.1	336	5250	136
2011/3/14 11:00	0.37	683	141.9	218	115.6	339	5250	136
2011/3/14 11:30	0.38	3443	142.1	218	116	339	5200	136
2011/3/14 12:00	0.38	3080	142.7	223	116.4	342	5200	136
2011/3/14 12:30	0.38	2731	142.9	226	116.7	345	5200	137
2011/3/14 13:00	0.37	2319	143.1	223	117.3	344	5250	137
2011/3/14 13:30	0.37	1983	143.0	220	117.6	341	5350	137
2011/3/14 14:00	0.38	1681	143.0	225	118.2	349	5400	137
2011/3/14 14:30	0.37	1088	143.0	221	118.4	343	5450	137
2011/3/14 15:00	0.37	844	143.0	220	118.7	343	5550	138
2011/3/14 15:30	0.38	3374	142.9	218	118.7	341	5900	138
2011/3/14 16:00	0.38	2992	143.1	215	118.9	339	5550	138
2011/3/14 16:30	0.37	2547	142.6	211	119	335	5800	134
2011/3/14 17:00	0.38	2135	142.6	203	119	328	5900	133
2011/3/14 17:30	0.38	1785	142.3	203	119	328	5900	132
2011/3/14 18:00	0.38	1362	142.0	201	119	326	5900	131
2011/3/14 18:30	0.35	900	141.8	199	119	324	5900	130
2011/3/14 19:00	0.35	478	141.6	195	118.9	321	5550	121
2011/3/14 19:30	0.37	3419	141.4	196	118.8	320	5450	120
2011/3/14 20:00	0.36	3064	141.4	196	118.8	320	5450	119
2011/3/14 20:30	0.36	2711	141.2	188	118.6	312	5459	117
2011/3/14 21:00	0.34	2340	140.8	186	118.6	309	5450	116
2011/3/14 21:30	0.34	1948	140.7	182	118.5	308	5450	114
2011/3/14 22:00	0.33	3768	139.4	177	118.2	301	5360	113
2011/3/14 22:30	0.28	3797	138.3	178	117.8	300	5350	113
2011/3/14 23:00	0.18	3864	123.9	174	115.7	297	5350	113

6°C高圧等24点
平均値に設定
(床裏水15分除
外調整のため)