

1号機

| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 発報値             | 7.07    | 321(L3) |          | 13.7       | 87        | -             | B9        | 32        |
|                 |         |         | 炉水温度     |            |           |               |           |           |
| 2011/3/14 22:00 | 0.05    | 4610    | 84       | 136        | 96.8      | 271           | 5831      | 72        |
| 2011/3/14 22:30 | 0.05    | 4391    | 84       | 137        | 96.1      | 269           | 5832      | 72        |
| 2011/3/14 23:00 | 0.08    | 4589    | 85       | 136        | 96.6      | 267           | 5777      | 70        |
| 2011/3/14 23:30 | 0.07    | 4598    | 90       | 133        | 98.2      | 268           | 5790      | 69        |
| 2011/3/15 0:00  | 0.07    | 4599    | 90       | 132        | 94.8      | 264           | 5798      | 69        |
| 2011/3/15 0:30  | 0.07    | 4609    | 90       | 130        | 94.1      | 269           | 5797      | 67        |
| 2011/3/15 1:00  | 0.07    | 4589    | 90       | 128        | 93.8      | 261           | 5801      | 66        |
| 2011/3/15 1:30  | 0.07    | 4589    | 90       | 127        | 93.2      | 260           | 5804      | 66        |
| 2011/3/15 2:00  | 0.07    | 4589    | 90       | 126        | 92.9      | 259           | 5809      | 66        |
| 2011/3/15 2:30  | 0.08    | 4519    | 86       | 125        | 92.3      | 258           | 5811      | 66        |
| 2011/3/15 3:00  | 0.08    | 4463    | 86       | 124        | 92.1      | 257           | 5812      | 66        |
| 2011/3/15 3:30  | 0.08    | 4392    | 86       | 122        | 91.5      | 256           | 5814      | 66        |
| 2011/3/15 4:00  | 0.08    | 4419    | 86       | 121        | 91.1      | 254           | 5812      | 62        |
| 2011/3/15 4:30  | 0.08    | 4404    | 88       | 120        | 90.8      | 253           | 5810      | 61        |
| 2011/3/15 5:00  | 0.08    | 4387    | 86       | 119        | 90.2      | 252           | 5814      | 60        |
| 2011/3/15 5:30  | 0.09    | 4588    | 87       | 117        | 89.9      | 250           | 5769      | 60        |

2F2 2号機

| 時間<br>監視値       | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | 2号機        |           | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 |         |         |          | D/W圧力(kPa) | D/W温度(°C) |               |           |           |
|                 | 7.07    | 321(L3) |          | 13.7       | 57        |               | 89        | 32        |
|                 |         |         | 84       |            |           |               |           |           |
| 2011/3/14 22:00 | 0.05    | 4148    | 84       | 116.6      | 98.6      | 235           | 5150      | 69        |
| 2011/3/14 22:30 | 0.05    | 4149    | 84       | 119.1      | 99.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.05    | 4149    | 84       | 112.6      | 97.9      | 231           | 5150      | 68        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 97.4      | 229           | 5150      | 65        |
| 2011/3/15 0:00  | 0.05    | 4151    | 84       | 108.1      | 97.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 108.9      | 96.6      | 223           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.3      | 96.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 95.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4154    | 84       | 101.5      | 95.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 99.9       | 95.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 98.4       | 94.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4157    | 84       | 97.1       | 94.4      | 216           | 5100      | 56        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 95.6       | 93.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 94.6       | 93.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4180    | 84       | 93.1       | 93.1      | 212           | 5100      | 53        |
| 2011/3/15 6:30  | 0.08    | 4180    | 86       | 91.8       | 92.7      | 211           | 5100      | 52        |

3号機

| 時刻<br>発報區       | 炉压(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W压力(kPa) | D/W温度(°C) | S/C压力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 7.07    | 321(L3) |          | 13.7       | 57.0      | -             | 60        | 32        |
| 2011/3/14 22:00 | -0.06   | 3435    | 30.9     | 31         | 60.1      | 132           | 600       | 45        |
| 2011/3/14 22:30 | -0.08   | 3434    | 30.8     | 31         | 60.1      | 132           | 598       | 46        |
| 2011/3/14 23:00 | -0.08   | 3442    | 30.8     | 31         | 59.9      | 132           | 599       | 46        |
| 2011/3/14 23:30 | -0.08   | 3437    | 30.7     | 31         | 59.8      | 132           | 598       | 45        |
| 2011/3/15 0:00  | -0.06   | 3434    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:30  | -0.06   | 3469    | 30.6     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:00  | -0.06   | 3449    | 30.5     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:30  | -0.08   | 3442    | 30.5     | 32         | 59.7      | 132           | 598       | 46        |
| 2011/3/15 2:00  | -0.08   | 3430    | 30.4     | 32         | 59.7      | 132           | 598       | 46        |
| 2011/3/15 2:30  | -0.08   | 3444    | 30.4     | 31         | 59.7      | 133           | 599       | 46        |
| 2011/3/15 3:00  | -0.08   | 3437    | 30.3     | 32         | 59.7      | 133           | 599       | 46        |
| 2011/3/15 3:30  | -0.03   | 3000    | 30.3     | 31         | 59.5      | 132           | 598       | 45        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.5      | 132           | 599       | 45        |
| 2011/3/15 4:30  | 0.04    | 3392    | 30.1     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 5:00  | 0.04    | 3391    | 30.1     | 31         | 59.4      | 132           | 598       | 44        |
| 2011/3/15 5:30  | 0.03    | 3378    | 30.0     | 31         | 59.4      | 132           | 599       | 44        |



| 1号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
| 警報區             | 7.07    | 521(L3) |          | 13.7       | 67        | -             | 63        | 62        |
|                 |         |         | 炉水温度     |            |           |               |           |           |
| 2011/3/14 22:00 | 0.05    | 4510    | 84       | 138        | 86.8      | 271           | 5831      | 72        |
| 2011/3/14 22:30 | 0.05    | 4391    | 84       | 137        | 86.1      | 269           | 5832      | 72        |
| 2011/3/14 23:00 | 0.08    | 4589    | 95       | 135        | 95.0      | 267           | 5777      | 70        |
| 2011/3/14 23:30 | 0.07    | 4588    | 90       | 133        | 95.2      | 265           | 5780      | 69        |
| 2011/3/15 0:00  | 0.07    | 4589    | 90       | 132        | 94.8      | 264           | 5786      | 69        |
| 2011/3/15 0:30  | 0.07    | 4589    | 90       | 130        | 94.1      | 263           | 5797      | 67        |
| 2011/3/15 1:00  | 0.07    | 4589    | 90       | 128        | 93.9      | 261           | 5801      | 66        |
| 2011/3/15 1:30  | 0.07    | 4589    | 90       | 127        | 93.2      | 260           | 5804      | 66        |
| 2011/3/15 2:00  | 0.07    | 4589    | 90       | 126        | 92.9      | 259           | 5809      | 65        |
| 2011/3/15 2:30  | 0.06    | 4519    | 88       | 125        | 92.3      | 258           | 5811      | 66        |
| 2011/3/15 3:00  | 0.06    | 4483    | 88       | 124        | 92.1      | 257           | 5812      | 66        |
| 2011/3/15 3:30  | 0.06    | 4392    | 88       | 122        | 91.5      | 255           | 5814      | 65        |
| 2011/3/15 4:00  | 0.06    | 4410    | 88       | 121        | 91.1      | 254           | 5812      | 62        |
| 2011/3/15 4:30  | 0.06    | 4404    | 88       | 120        | 90.8      | 253           | 5810      | 61        |
| 2011/3/15 5:00  | 0.06    | 4357    | 88       | 119        | 90.2      | 252           | 5814      | 60        |
| 2011/3/15 5:30  | 0.09    | 4586    | 97       | 117        | 89.9      | 250           | 5769      | 60        |
| 2011/3/15 6:00  | 0.06    | 4488    | 88       | 118        | 89.7      | 250           | 5807      | 58        |

2F2

2号機

| 時間<br>警報値       | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 89        | 32        |
| 2011/3/14 22:00 | 0.05    | 4146    | 84       | 116.6      | 98.6      | 235           | 5150      | 69        |
| 2011/3/14 22:30 | 0.05    | 4148    | 84       | 113.1      | 98.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.05    | 4148    | 84       | 112.5      | 97.9      | 231           | 5150      | 68        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 97.4      | 229           | 5150      | 68        |
| 2011/3/15 0:00  | 0.05    | 4151    | 84       | 108.1      | 97.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 108.8      | 98.6      | 225           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.3      | 98.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 95.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4154    | 84       | 101.5      | 95.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 99.9       | 95.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 98.4       | 94.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4157    | 84       | 97.1       | 94.4      | 218           | 5100      | 56        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 95.9       | 93.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 94.6       | 93.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4160    | 84       | 93.1       | 93.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30  | 0.05    | 4160    | 86       | 91.9       | 92.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00  | 0.05    | 4163    | 86       | 92.2       | 92.6      | 210           | 5100      | 51        |

| 時間<br>登録順       | 3号機     |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
|                 | 7.07    | 321(L3) |          | 13.7       | 57.0      | -             | 50        | 32        |
| 2011/3/14 22:00 | -0.06   | 3435    | 30.6     | 31         | 59.1      | 132           | 599       | 45        |
| 2011/3/14 22:30 | -0.06   | 3434    | 30.6     | 31         | 59.1      | 132           | 599       | 45        |
| 2011/3/14 23:00 | -0.06   | 3442    | 30.8     | 31         | 59.9      | 132           | 599       | 45        |
| 2011/3/14 23:30 | -0.06   | 3437    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:00  | -0.06   | 3434    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:30  | -0.06   | 3488    | 30.6     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:00  | -0.06   | 3448    | 30.5     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:30  | -0.06   | 3442    | 30.5     | 32         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 2:00  | -0.06   | 3430    | 30.4     | 32         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 2:30  | -0.06   | 3444    | 30.4     | 31         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:00  | -0.06   | 3437    | 30.3     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:30  | -0.03   | 3009    | 30.3     | 31         | 59.5      | 132           | 599       | 45        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.5      | 132           | 599       | 45        |
| 2011/3/15 4:30  | 0.04    | 3382    | 30.1     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 5:00  | 0.04    | 3381    | 30.1     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 5:30  | 0.03    | 3378    | 30.0     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 6:00  | 0.04    | 3376    | 29.9     | 31         | 59.2      | 132           | 599       | 44        |

| 4号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
| 監視値             | 7.07    | 321(L3) |          | 13.7       | 87        |               | 50        | 82        |
| 2011/3/14 22:00 | 0.39    | 3788    | 138.4    | 177        | 118.2     | 301           | 6350      | 113       |
| 2011/3/14 22:30 | 0.28    | 3797    | 138.3    | 178        | 117.8     | 300           | 6350      | 119       |
| 2011/3/14 23:00 | 0.18    | 3864    | 123.9    | 174        | 115.7     | 297           | 6350      | 113       |
| 2011/3/14 23:30 | 0.18    | 4232    | 114.6    | 172        | 113.4     | 284           | 6350      | 110       |
| 2011/3/15 0:00  | 0.18    | 4589    | 108.6    | 168        | 111.2     | 291           | 6300      | 112       |
| 2011/3/15 0:30  | 0.18    | 4589    | 104.7    | 166        | 109.0     | 288           | 6200      | 110       |
| 2011/3/15 1:00  | 0.15    | 4589    | 99.3     | 163        | 105.9     | 285           | 6250      | 112       |
| 2011/3/15 1:30  | 0.14    | 4589    | 97.2     | 160        | 104.1     | 282           | 6250      | 111       |
| 2011/3/15 2:00  | 0.13    | 4589    | 96.0     | 157        | 102.5     | 279           | 6250      | 110       |
| 2011/3/15 2:30  | 0.12    | 4588    | 95.4     | 154        | 101.8     | 278           | 6250      | 108       |
| 2011/3/15 3:00  | 0.1     | 4588    | 96.0     | 152        | 101.4     | 273           | 6200      | 107       |
| 2011/3/15 3:30  | 0.09    | 4588    | 94.8     | 149        | 100.8     | 270           | 6250      | 108       |
| 2011/3/15 4:00  | 0.07    | 4588    | 94.8     | 148        | 100.2     | 268           | 6250      | 104       |
| 2011/3/15 4:30  | 0.09    | 4588    | 94.8     | 144        | 99.6      | 266           | 6200      | 103       |
| 2011/3/15 5:00  | 0.08    | 4588    | 94.3     | 142        | 98.8      | 263           | 6250      | 102       |
| 2011/3/15 5:30  | 0.08    | 4588    | 83.8     | 140        | 98.6      | 261           | 6200      | 101       |
| 2011/3/15 6:00  | 0.09    | 4588    | 83.2     | 137        | 97.8      | 259           | 6200      | 100       |



| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | 1号機        |           | S/G圧力(kPa) | S/G水位(mm) |    | S/G温度(°C) |    |
|-----------------|---------|---------|----------|------------|-----------|------------|-----------|----|-----------|----|
|                 |         |         |          | D/W圧力(kPa) | D/W温度(°C) |            | 83        | 32 | 83        | 32 |
| 警報値             | 7.07    | 321(L3) |          | 13.7       | 57        |            |           |    |           |    |
|                 |         |         | 原水温度     |            |           |            |           |    |           |    |
| 2011/3/14 22:00 | 0.05    | 4510    | 84       | 138        | 96.8      | 271        | 5831      | 72 |           |    |
| 2011/3/14 22:30 | 0.05    | 4381    | 84       | 137        | 96.1      | 269        | 5832      | 72 |           |    |
| 2011/3/14 23:00 | 0.06    | 4588    | 95       | 135        | 95.6      | 267        | 5777      | 70 |           |    |
| 2011/3/14 23:30 | 0.07    | 4589    | 90       | 133        | 95.2      | 265        | 5790      | 69 |           |    |
| 2011/3/15 0:00  | 0.07    | 4589    | 90       | 132        | 94.8      | 264        | 5796      | 69 |           |    |
| 2011/3/15 0:30  | 0.07    | 4589    | 90       | 130        | 94.1      | 263        | 5797      | 67 |           |    |
| 2011/3/15 1:00  | 0.07    | 4589    | 90       | 128        | 93.8      | 281        | 5801      | 68 |           |    |
| 2011/3/15 1:30  | 0.07    | 4589    | 90       | 127        | 93.2      | 260        | 5804      | 66 |           |    |
| 2011/3/15 2:00  | 0.07    | 4589    | 90       | 126        | 92.9      | 259        | 5809      | 68 |           |    |
| 2011/3/15 2:30  | 0.08    | 4619    | 86       | 125        | 92.3      | 258        | 5811      | 66 |           |    |
| 2011/3/15 3:00  | 0.08    | 4463    | 86       | 124        | 92.1      | 257        | 5812      | 66 |           |    |
| 2011/3/15 3:30  | 0.08    | 4392    | 86       | 122        | 91.5      | 255        | 5814      | 65 |           |    |
| 2011/3/15 4:00  | 0.08    | 4418    | 86       | 121        | 91.1      | 254        | 5812      | 62 |           |    |
| 2011/3/15 4:30  | 0.08    | 4404    | 86       | 120        | 90.8      | 253        | 5810      | 61 |           |    |
| 2011/3/15 5:00  | 0.08    | 4357    | 86       | 119        | 90.2      | 252        | 5814      | 60 |           |    |
| 2011/3/15 5:30  | 0.09    | 4586    | 97       | 117        | 89.9      | 250        | 5789      | 60 |           |    |
| 2011/3/15 6:00  | 0.08    | 4468    | 86       | 118        | 89.7      | 250        | 5807      | 58 |           |    |
| 2011/3/15 6:30  | 0.08    | 4437    | 86       | 117        | 89.7      | 249        | 5803      | 57 |           |    |
| 2011/3/15 7:00  | 0.08    | 4465    | 86       | 116        | 88.8      | 248        | 5803      | 57 |           |    |
| 2011/3/15 7:30  | 0.08    | 4431    | 86       | 115        | 88.5      | 247        | 5804      | 56 |           |    |
| 2011/3/15 8:00  | 0.06    | 4402    | 86       | 114        | 88.2      | 246        | 5805      | 56 |           |    |

2F2 2号機

| 時間              | 炉压(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W压力(kPa) | D/W温度(°C) | S/G压力(kPaabs) | S/C水位(mm) | S/G温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 基準値             | 7.07    | 321(L3) |          | 13.7       | 57        |               | 83        | 32        |
| 2011/3/14 22:00 | 0.05    | 4146    | 84       | 118.6      | 98.6      | 235           | 5150      | 69        |
| 2011/3/14 22:30 | 0.05    | 4148    | 84       | 113.1      | 98.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.05    | 4148    | 84       | 112.6      | 97.9      | 231           | 5150      | 66        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 97.4      | 229           | 5150      | 65        |
| 2011/3/15 0:00  | 0.05    | 4151    | 84       | 108.1      | 97.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 106.9      | 96.6      | 225           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.3      | 96.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 95.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4164    | 84       | 101.5      | 95.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 99.9       | 95.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 99.4       | 94.7      | 216           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4157    | 84       | 97.1       | 94.4      | 216           | 5100      | 56        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 95.6       | 93.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 94.6       | 93.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4160    | 84       | 93.1       | 93.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30  | 0.06    | 4160    | 86       | 91.8       | 92.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00  | 0.06    | 4163    | 86       | 92.2       | 92.5      | 210           | 5100      | 51        |
| 2011/3/15 6:30  | 0.06    | 4163    | 86       | 90.6       | 92.0      | 209           | 5100      | 51        |
| 2011/3/15 7:00  | 0.06    | 4163    | 86       | 90.3       | 91.9      | 208           | 5100      | 50        |
| 2011/3/15 7:30  | 0.06    | 4165    | 86       | 89.1       | 91.7      | 207           | 5100      | 49        |
| 2011/3/15 8:00  | 0.06    | 4165    | 86       | 81.3       | 91.3      | 206           | 5100      | 48        |

| 3号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
| 警報値             | 7.07    | 321(L3) |          | 13.7       | 57.0      |               | 50        | 32        |
| 2011/3/14 22:00 | -0.06   | 3435    | 30.9     | 31         | 60.1      | 132           | 600       | 45        |
| 2011/3/14 22:30 | -0.08   | 3434    | 30.8     | 31         | 60.1      | 132           | 598       | 45        |
| 2011/3/14 23:00 | -0.08   | 3442    | 30.8     | 31         | 60.9      | 132           | 599       | 45        |
| 2011/3/14 23:30 | -0.06   | 3437    | 30.7     | 31         | 59.8      | 132           | 598       | 45        |
| 2011/3/15 0:00  | -0.06   | 3434    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:30  | -0.06   | 3460    | 30.6     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:00  | -0.06   | 3448    | 30.5     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:30  | -0.06   | 3442    | 30.5     | 32         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 2:00  | -0.06   | 3430    | 30.4     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 2:30  | -0.06   | 3444    | 30.4     | 31         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:00  | -0.06   | 3437    | 30.3     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:30  | -0.03   | 3000    | 30.3     | 31         | 59.5      | 132           | 599       | 45        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 4:30  | 0.04    | 3382    | 30.1     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 5:00  | 0.04    | 3381    | 30.1     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 5:30  | 0.03    | 3378    | 30.0     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 6:00  | 0.04    | 3378    | 29.9     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 6:30  | 0.04    | 3375    | 29.8     | 31         | 59.3      | 132           | 598       | 44        |
| 2011/3/15 7:00  | 0.04    | 3375    | 29.8     | 31         | 59.1      | 132           | 598       | 44        |
| 2011/3/15 7:30  | 0.03    | 3372    | 29.7     | 31         | 59.1      | 132           | 598       | 44        |
| 2011/3/15 8:00  | 0.04    | 3372    | 28.6     | 31         | 59.1      | 132           | 598       | 44        |

| 4号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
| 警報値             | 7.07    | 321(L3) |          | 13.7       | 57        |               | 50        | 32        |
| 2011/3/14 22:00 | 0.33    | 3766    | 139.4    | 172        | 116.2     | 301           | 5350      | 113       |
| 2011/3/14 22:30 | 0.29    | 3797    | 136.3    | 176        | 117.6     | 300           | 5350      | 113       |
| 2011/3/14 23:00 | 0.18    | 3864    | 123.9    | 174        | 116.7     | 297           | 5350      | 113       |
| 2011/3/14 23:30 | 0.16    | 4232    | 114.6    | 172        | 113.4     | 294           | 5350      | 113       |
| 2011/3/15 0:00  | 0.18    | 4589    | 108.6    | 169        | 111.2     | 291           | 5300      | 112       |
| 2011/3/15 0:30  | 0.18    | 4589    | 104.7    | 166        | 108.9     | 298           | 5200      | 110       |
| 2011/3/15 1:00  | 0.15    | 4589    | 99.3     | 163        | 105.9     | 285           | 5250      | 112       |
| 2011/3/15 1:30  | 0.14    | 4589    | 97.2     | 160        | 104.1     | 282           | 5250      | 111       |
| 2011/3/15 2:00  | 0.13    | 4589    | 96.0     | 157        | 102.5     | 279           | 5250      | 110       |
| 2011/3/15 2:30  | 0.12    | 4589    | 95.4     | 154        | 101.6     | 276           | 5250      | 108       |
| 2011/3/15 3:00  | 0.1     | 4589    | 95.0     | 152        | 101.4     | 273           | 5200      | 107       |
| 2011/3/15 3:30  | 0.09    | 4589    | 94.8     | 149        | 100.9     | 270           | 5250      | 106       |
| 2011/3/15 4:00  | 0.07    | 4589    | 94.8     | 146        | 100.2     | 268           | 5250      | 104       |
| 2011/3/15 4:30  | 0.09    | 4589    | 94.6     | 144        | 99.6      | 265           | 5200      | 103       |
| 2011/3/15 5:00  | 0.08    | 4589    | 94.3     | 142        | 99.0      | 263           | 5250      | 102       |
| 2011/3/15 5:30  | 0.08    | 4589    | 93.8     | 140        | 98.6      | 261           | 5200      | 101       |
| 2011/3/15 6:00  | 0.09    | 4589    | 93.2     | 137        | 97.9      | 259           | 5200      | 100       |
| 2011/3/15 6:30  | 0.09    | 4589    | 91.3     | 134        | 97.3      | 255           | 5200      | 100       |
| 2011/3/15 7:00  | 0.1     | 4589    | 90.3     | 133        | 97        | 254           | 5200      | 99        |
| 2011/3/15 7:30  | 0.09    | 4589    | 89.4     | 131        | 96.6      | 252           | 5200      | 98        |
| 2011/3/15 8:00  | 0.09    | 4589    | 88.6     | 130        | 96.4      | 250           | 5200      | 97        |

2F

| 1号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 除開<br>監視値       | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|                 | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 82        | 32        |
|                 |         |         | 炉水温度     |            |           |               |           |           |
| 2011/3/14 22:00 | 0.05    | 4510    | 84       | 138        | 86.8      | 271           | 5881      | 72        |
| 2011/3/14 22:30 | 0.05    | 4391    | 84       | 137        | 88.1      | 269           | 5832      | 72        |
| 2011/3/14 23:00 | 0.08    | 4589    | 85       | 135        | 85.8      | 267           | 5777      | 70        |
| 2011/3/14 23:30 | 0.07    | 4588    | 90       | 133        | 85.2      | 265           | 5780      | 69        |
| 2011/3/15 0:00  | 0.07    | 4588    | 90       | 132        | 84.8      | 264           | 5786      | 69        |
| 2011/3/15 0:30  | 0.07    | 4589    | 90       | 130        | 84.1      | 263           | 5797      | 67        |
| 2011/3/15 1:00  | 0.07    | 4589    | 90       | 128        | 83.8      | 261           | 5801      | 68        |
| 2011/3/15 1:30  | 0.07    | 4589    | 90       | 127        | 83.2      | 260           | 5804      | 68        |
| 2011/3/15 2:00  | 0.07    | 4589    | 90       | 126        | 82.9      | 259           | 5809      | 68        |
| 2011/3/15 2:30  | 0.06    | 4510    | 86       | 125        | 82.9      | 259           | 5811      | 68        |
| 2011/3/15 3:00  | 0.08    | 4463    | 86       | 124        | 82.1      | 257           | 5812      | 66        |
| 2011/3/15 3:30  | 0.08    | 4392    | 86       | 122        | 81.5      | 255           | 5814      | 65        |
| 2011/3/15 4:00  | 0.08    | 4418    | 86       | 121        | 81.1      | 254           | 5812      | 62        |
| 2011/3/15 4:30  | 0.08    | 4404    | 86       | 120        | 80.8      | 253           | 5810      | 61        |
| 2011/3/15 5:00  | 0.08    | 4357    | 86       | 119        | 80.2      | 252           | 5814      | 60        |
| 2011/3/15 5:30  | 0.09    | 4588    | 87       | 117        | 80.8      | 250           | 5788      | 60        |
| 2011/3/15 6:00  | 0.08    | 4488    | 86       | 116        | 80.7      | 250           | 5807      | 58        |
| 2011/3/15 6:30  | 0.08    | 4437    | 86       | 117        | 80.7      | 249           | 5803      | 58        |
| 2011/3/15 7:00  | 0.08    | 4485    | 86       | 118        | 80.8      | 248           | 5803      | 57        |
| 2011/3/15 7:30  | 0.05    | 4431    | 86       | 115        | 80.5      | 247           | 5804      | 56        |
| 2011/3/15 8:00  | 0.08    | 4402    | 86       | 114        | 80.2      | 248           | 5805      | 58        |
| 2011/3/15 8:30  | 0.08    | 4388    | 86       | 113        | 87.8      | 248           | 5808      | 55        |

2F2

2号機

| 時間<br>登録値       | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | O/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 83        | 32        |
| 2011/3/14 22:00 | 0.05    | 4146    | 84       | 116.8      | 88.6      | 235           | 5150      | 69        |
| 2011/3/14 22:30 | 0.05    | 4148    | 84       | 119.1      | 88.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.05    | 4148    | 84       | 112.5      | 87.9      | 231           | 5150      | 66        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 87.4      | 228           | 5150      | 65        |
| 2011/3/15 0:00  | 0.05    | 4151    | 84       | 109.1      | 87.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 108.9      | 86.8      | 225           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.3      | 86.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 85.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4154    | 84       | 101.8      | 85.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 98.9       | 85.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 98.4       | 84.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4167    | 84       | 97.1       | 84.4      | 216           | 5100      | 56        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 95.6       | 83.8      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 94.6       | 83.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4160    | 84       | 93.1       | 83.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30  | 0.05    | 4160    | 86       | 91.8       | 82.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00  | 0.05    | 4163    | 86       | 82.2       | 82.5      | 210           | 5100      | 51        |
| 2011/3/15 6:30  | 0.05    | 4163    | 86       | 80.6       | 82.0      | 209           | 5100      | 51        |
| 2011/3/15 7:00  | 0.05    | 4163    | 86       | 80.3       | 81.8      | 208           | 5100      | 50        |
| 2011/3/15 7:30  | 0.05    | 4165    | 86       | 80.1       | 81.7      | 207           | 5100      | 49        |
| 2011/3/15 8:00  | 0.05    | 4165    | 86       | 81.3       | 81.3      | 206           | 5100      | 48        |
| 2011/3/15 8:30  | 0.05    | 4165    | 86       | 87.5       | 81.0      | 205           | 5100      | 48        |

| 3号機             |         |         |          |            |           |                             |           |           |
|-----------------|---------|---------|----------|------------|-----------|-----------------------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPa <sub>seba</sub> ) | S/O水位(mm) | S/O温度(°C) |
| 等級値             | 7.07    | 321(L3) |          | 13.7       | 57.0      | -                           | 60        | 32        |
| 2011/3/14 22:00 | -0.09   | 3435    | 30.8     | 31         | 59.1      | 132                         | 600       | 45        |
| 2011/3/14 22:30 | -0.08   | 3434    | 30.8     | 31         | 59.1      | 132                         | 600       | 45        |
| 2011/3/14 23:00 | -0.08   | 3442    | 30.8     | 31         | 59.9      | 132                         | 600       | 45        |
| 2011/3/14 23:30 | -0.06   | 3437    | 30.7     | 31         | 59.9      | 132                         | 600       | 45        |
| 2011/3/15 0:00  | -0.06   | 3424    | 30.7     | 31         | 59.9      | 132                         | 600       | 45        |
| 2011/3/15 0:30  | -0.06   | 3408    | 30.6     | 31         | 59.7      | 132                         | 600       | 45        |
| 2011/3/15 1:00  | -0.06   | 3448    | 30.5     | 31         | 59.7      | 132                         | 600       | 45        |
| 2011/3/15 1:30  | -0.06   | 3442    | 30.6     | 32         | 59.7      | 132                         | 600       | 45        |
| 2011/3/15 2:00  | -0.09   | 3430    | 30.4     | 32         | 59.7      | 132                         | 600       | 45        |
| 2011/3/15 2:30  | -0.08   | 3444    | 30.4     | 31         | 59.7      | 132                         | 600       | 45        |
| 2011/3/15 3:00  | -0.08   | 3437    | 30.3     | 32         | 59.7      | 132                         | 600       | 45        |
| 2011/3/15 3:30  | -0.03   | 3000    | 30.3     | 31         | 59.5      | 132                         | 600       | 45        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.6      | 132                         | 600       | 45        |
| 2011/3/15 4:30  | 0.04    | 3382    | 30.1     | 31         | 59.5      | 132                         | 600       | 44        |
| 2011/3/15 5:00  | 0.04    | 3381    | 30.1     | 31         | 59.4      | 132                         | 600       | 44        |
| 2011/3/15 5:30  | 0.03    | 3378    | 30.0     | 31         | 59.4      | 132                         | 600       | 44        |
| 2011/3/15 6:00  | 0.04    | 3378    | 29.9     | 31         | 59.2      | 132                         | 600       | 44        |
| 2011/3/15 6:30  | 0.04    | 3375    | 29.8     | 31         | 59.3      | 132                         | 600       | 44        |
| 2011/3/15 7:00  | 0.04    | 3375    | 29.8     | 31         | 59.1      | 132                         | 600       | 44        |
| 2011/3/15 7:30  | 0.03    | 3372    | 29.7     | 31         | 59.1      | 132                         | 600       | 44        |
| 2011/3/15 8:00  | 0.04    | 3372    | 29.6     | 31         | 59.1      | 132                         | 600       | 44        |
| 2011/3/15 8:30  | 0.04    | 3372    | 29.6     | 31         | 59.2      | 132                         | 600       | 44        |

4号機

| 時間<br>時刻(時)     | 炉圧(MPa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 7.07    | 321(L3) |          | 13.7       | 67        | -             | 50        | 32        |
| 2011/3/14 22:00 | 0.89    | 3786    | 139.4    | 177        | 118.2     | 301           | 5350      | 113       |
| 2011/3/14 22:30 | 0.29    | 3787    | 138.3    | 178        | 117.8     | 300           | 5350      | 113       |
| 2011/3/14 23:00 | 0.18    | 3884    | 129.9    | 174        | 115.7     | 297           | 5350      | 113       |
| 2011/3/14 23:30 | 0.16    | 4232    | 114.6    | 172        | 113.4     | 294           | 5350      | 113       |
| 2011/3/15 0:00  | 0.18    | 4588    | 108.8    | 168        | 111.2     | 291           | 5300      | 112       |
| 2011/3/15 0:30  | 0.18    | 4589    | 104.7    | 166        | 109.9     | 288           | 5200      | 110       |
| 2011/3/15 1:00  | 0.15    | 4588    | 88.3     | 163        | 105.9     | 285           | 5250      | 112       |
| 2011/3/15 1:30  | 0.14    | 4589    | 87.2     | 160        | 104.1     | 282           | 5250      | 111       |
| 2011/3/15 2:00  | 0.13    | 4589    | 86.0     | 157        | 102.5     | 279           | 5250      | 110       |
| 2011/3/15 2:30  | 0.12    | 4589    | 85.4     | 154        | 101.8     | 278           | 5250      | 109       |
| 2011/3/15 3:00  | 0.1     | 4589    | 85.0     | 152        | 101.4     | 273           | 5200      | 107       |
| 2011/3/15 3:30  | 0.08    | 4589    | 84.8     | 149        | 100.8     | 270           | 5250      | 108       |
| 2011/3/15 4:00  | 0.07    | 4589    | 84.8     | 148        | 100.2     | 268           | 5250      | 104       |
| 2011/3/15 4:30  | 0.09    | 4589    | 84.8     | 144        | 89.8      | 265           | 6200      | 103       |
| 2011/3/15 5:00  | 0.08    | 4589    | 84.3     | 142        | 88.9      | 263           | 5250      | 102       |
| 2011/3/15 5:30  | 0.08    | 4589    | 83.8     | 140        | 88.8      | 261           | 5200      | 101       |
| 2011/3/15 6:00  | 0.09    | 4589    | 83.2     | 137        | 97.9      | 258           | 5200      | 100       |
| 2011/3/15 6:30  | 0.09    | 4589    | 81.3     | 134        | 97.3      | 255           | 5200      | 100       |
| 2011/3/15 7:00  | 0.1     | 4589    | 80.3     | 133        | 97        | 254           | 5200      | 99        |
| 2011/3/15 7:30  | 0.08    | 4589    | 69.4     | 131        | 98.8      | 252           | 5200      | 98        |
| 2011/3/15 8:00  | 0.08    | 4589    | 68.6     | 130        | 98.4      | 250           | 5200      | 97        |
| 2011/3/15 8:30  | 0.11    | 4688    | 68.2     | 128        | 98.3      | 249           | 5200      | 97        |



2F

| 1号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
| 警報値             | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 89        | 32        |
|                 |         |         | 炉水温度     |            |           |               |           |           |
| 2011/3/14 22:00 | 0.05    | 4510    | 84       | 138        | 86.8      | 271           | 5831      | 72        |
| 2011/3/14 22:30 | 0.05    | 4391    | 84       | 137        | 86.1      | 269           | 5832      | 72        |
| 2011/3/14 23:00 | 0.08    | 4569    | 85       | 135        | 85.6      | 267           | 5777      | 70        |
| 2011/3/14 23:30 | 0.07    | 4588    | 90       | 133        | 85.2      | 265           | 5760      | 68        |
| 2011/3/15 0:00  | 0.07    | 4589    | 90       | 132        | 84.8      | 264           | 5786      | 69        |
| 2011/3/15 0:30  | 0.07    | 4589    | 90       | 130        | 84.1      | 263           | 5797      | 67        |
| 2011/3/15 1:00  | 0.07    | 4589    | 90       | 128        | 83.8      | 261           | 5801      | 66        |
| 2011/3/15 1:30  | 0.07    | 4589    | 90       | 127        | 83.2      | 260           | 5804      | 66        |
| 2011/3/15 2:00  | 0.07    | 4589    | 90       | 126        | 82.9      | 259           | 5809      | 65        |
| 2011/3/15 2:30  | 0.08    | 4519    | 86       | 125        | 82.3      | 258           | 5811      | 68        |
| 2011/3/15 3:00  | 0.06    | 4463    | 86       | 124        | 82.1      | 287           | 5812      | 68        |
| 2011/3/15 3:30  | 0.06    | 4392    | 86       | 122        | 81.5      | 255           | 5814      | 65        |
| 2011/3/15 4:00  | 0.06    | 4418    | 86       | 121        | 81.1      | 254           | 5812      | 62        |
| 2011/3/15 4:30  | 0.06    | 4404    | 88       | 120        | 80.8      | 253           | 5810      | 61        |
| 2011/3/15 5:00  | 0.08    | 4357    | 88       | 119        | 80.2      | 252           | 5814      | 60        |
| 2011/3/15 5:30  | 0.09    | 4588    | 97       | 117        | 89.9      | 250           | 5769      | 60        |
| 2011/3/15 6:00  | 0.08    | 4488    | 86       | 118        | 89.7      | 250           | 5807      | 58        |
| 2011/3/15 6:30  | 0.08    | 4437    | 86       | 117        | 89.7      | 249           | 5803      | 58        |
| 2011/3/15 7:00  | 0.08    | 4465    | 86       | 116        | 88.8      | 248           | 5803      | 57        |
| 2011/3/15 7:30  | 0.08    | 4491    | 88       | 115        | 88.5      | 247           | 5804      | 58        |
| 2011/3/15 8:00  | 0.06    | 4402    | 86       | 114        | 88.2      | 246           | 5805      | 56        |
| 2011/3/15 8:30  | 0.06    | 4388    | 86       | 113        | 87.8      | 245           | 5808      | 58        |
| 2011/3/15 9:00  | 0.06    | 4336    | 86       | 113        | 87.8      | 244           | 5808      | 55        |
| 2011/3/15 9:30  | 0.08    | 4302    | 88       | 112        | 87.1      | 244           | 5809      | 54        |

2F2

2号機

| 時間              | 炉圧(Mpa) | 炉水位(mh) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 発報値             | 7.07    | 921(L3) |          | 18.7       | 87        | -             | 83        | 32        |
| 2011/3/14 22:00 | 0.05    | 4146    | 84       | 116.6      | 88.6      | 235           | 5150      | 69        |
| 2011/3/14 22:30 | 0.05    | 4149    | 84       | 113.1      | 88.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.05    | 4148    | 84       | 112.5      | 87.9      | 231           | 5150      | 66        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 87.4      | 229           | 5150      | 65        |
| 2011/3/15 0:00  | 0.05    | 4181    | 84       | 108.1      | 87.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 108.9      | 86.6      | 225           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.3      | 86.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 85.8      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4154    | 84       | 101.6      | 85.4      | 221           | 5150      | 58        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 99.9       | 85.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 88.4       | 84.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4157    | 84       | 87.1       | 84.4      | 216           | 5100      | 56        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 86.6       | 83.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 84.6       | 83.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4160    | 84       | 83.1       | 83.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30  | 0.08    | 4160    | 86       | 81.8       | 82.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00  | 0.08    | 4163    | 86       | 82.2       | 82.6      | 210           | 5100      | 51        |
| 2011/3/15 6:30  | 0.08    | 4163    | 86       | 80.6       | 82.0      | 209           | 5100      | 51        |
| 2011/3/15 7:00  | 0.08    | 4163    | 86       | 80.3       | 81.9      | 208           | 5100      | 49        |
| 2011/3/15 7:30  | 0.08    | 4165    | 86       | 80.1       | 81.7      | 207           | 5100      | 48        |
| 2011/3/15 8:00  | 0.08    | 4165    | 86       | 81.3       | 81.3      | 206           | 5100      | 48        |
| 2011/3/15 8:30  | 0.08    | 4165    | 86       | 87.5       | 81.0      | 205           | 5100      | 48        |
| 2011/3/15 9:00  | 0.08    | 4169    | 86       | 86.6       | 80.7      | 204           | 5100      | 47        |
| 2011/3/15 9:30  | 0.08    | 4165    | 86       | 85.0       | 80.2      | 203           | 5100      | 47        |

| 3号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/O水位(mm) | S/C温度(°C) |
| 種類値             | 7.07    | 321(L3) |          | 13.7       | 57.0      |               | 60        | 32        |
| 2011/3/14 22:00 | -0.06   | 3435    | 30.8     | 31         | 60.1      | 132           | 600       | 46        |
| 2011/3/14 22:30 | -0.06   | 3434    | 30.8     | 31         | 60.1      | 132           | 599       | 46        |
| 2011/3/14 23:00 | -0.06   | 3442    | 30.8     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/14 23:30 | -0.06   | 3437    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:00  | -0.06   | 3434    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:30  | -0.06   | 3466    | 30.6     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:00  | -0.06   | 3448    | 30.5     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:30  | -0.06   | 3442    | 30.5     | 32         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 2:00  | -0.06   | 3430    | 30.4     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 2:30  | -0.06   | 3444    | 30.4     | 31         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:00  | -0.06   | 3437    | 30.3     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:30  | -0.06   | 3000    | 30.3     | 31         | 59.5      | 132           | 599       | 46        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 4:30  | 0.04    | 3382    | 30.1     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 5:00  | 0.04    | 3391    | 30.1     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 5:30  | 0.03    | 3376    | 30.0     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 6:00  | 0.04    | 3376    | 29.8     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 6:30  | 0.04    | 3375    | 29.8     | 31         | 59.3      | 132           | 599       | 44        |
| 2011/3/15 7:00  | 0.04    | 3375    | 29.8     | 31         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 7:30  | 0.03    | 3372    | 29.7     | 31         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 8:00  | 0.04    | 3372    | 29.6     | 31         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 8:30  | 0.04    | 3372    | 29.6     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 9:00  | 0.04    | 3371    | 29.6     | 32         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 9:30  | 0.04    | 3371    | 29.5     | 32         | 59.1      | 132           | 599       | 44        |

| 4号機             |         |         |          |     |               |     |           |     |
|-----------------|---------|---------|----------|-----|---------------|-----|-----------|-----|
| 時間<br>警報値       | 炉圧(MPa) | 炉水位(mm) | 炉水温度(°C) |     | S/C圧力(kPaaba) |     | S/C水位(mm) |     |
|                 |         |         | D/W      | D/W | 57            | 50  | 32        |     |
|                 | 7.07    | 321(L3) |          | 137 |               |     |           |     |
|                 |         |         |          |     |               |     |           |     |
| 2011/3/14 22:00 | 0.33    | 3766    | 139.4    | 177 | 116.2         | 301 | 5350      | 113 |
| 2011/3/14 22:30 | 0.29    | 3797    | 136.3    | 176 | 117.8         | 300 | 5350      | 113 |
| 2011/3/14 23:00 | 0.18    | 3864    | 123.9    | 174 | 115.7         | 287 | 5350      | 118 |
| 2011/3/14 23:30 | 0.16    | 4232    | 114.6    | 172 | 113.4         | 294 | 5350      | 113 |
| 2011/3/15 0:00  | 0.18    | 4589    | 108.6    | 168 | 111.2         | 291 | 5300      | 112 |
| 2011/3/15 0:30  | 0.18    | 4589    | 104.7    | 166 | 109.9         | 288 | 5200      | 110 |
| 2011/3/15 1:00  | 0.15    | 4589    | 99.3     | 163 | 105.9         | 285 | 5250      | 112 |
| 2011/3/15 1:30  | 0.14    | 4589    | 97.2     | 160 | 104.1         | 282 | 5250      | 111 |
| 2011/3/15 2:00  | 0.13    | 4589    | 96.0     | 157 | 102.5         | 279 | 5260      | 110 |
| 2011/3/15 2:30  | 0.12    | 4589    | 95.4     | 154 | 101.8         | 278 | 5260      | 109 |
| 2011/3/15 3:00  | 0.1     | 4589    | 95.0     | 152 | 101.4         | 273 | 5200      | 107 |
| 2011/3/15 3:30  | 0.09    | 4589    | 94.8     | 149 | 100.8         | 270 | 5250      | 108 |
| 2011/3/15 4:00  | 0.07    | 4589    | 94.8     | 146 | 100.2         | 268 | 5250      | 104 |
| 2011/3/15 4:30  | 0.09    | 4589    | 94.8     | 144 | 99.6          | 265 | 5200      | 103 |
| 2011/3/15 5:00  | 0.08    | 4589    | 94.3     | 142 | 98.8          | 263 | 5250      | 102 |
| 2011/3/15 5:30  | 0.09    | 4589    | 93.8     | 140 | 98.6          | 261 | 5200      | 101 |
| 2011/3/15 6:00  | 0.09    | 4589    | 93.2     | 137 | 97.9          | 258 | 5200      | 100 |
| 2011/3/15 6:30  | 0.09    | 4589    | 91.3     | 134 | 97.3          | 255 | 5200      | 100 |
| 2011/3/15 7:00  | 0.1     | 4589    | 90.3     | 133 | 97            | 254 | 5200      | 99  |
| 2011/3/15 7:30  | 0.09    | 4589    | 89.4     | 131 | 96.8          | 252 | 5200      | 99  |
| 2011/3/15 8:00  | 0.08    | 4588    | 88.6     | 130 | 96.4          | 250 | 5200      | 97  |
| 2011/3/15 8:30  | 0.11    | 4589    | 88.2     | 128 | 96.3          | 249 | 5200      | 97  |
| 2011/3/15 9:00  | 0.1     | 4599    | 87.2     | 127 | 96            | 247 | 5150      | 98  |
| 2011/3/15 9:30  | 0.1     | 4589    | 86.8     | 126 | 95.7          | 245 | 5200      | 98  |

+4.196

57A

| 時間              | 号機      |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
| 監視値             | 7.07    | 321(L3) |          | 13.7       | 67        |               | 33        | 32        |
|                 |         |         | 炉水温度     |            |           |               |           |           |
| 2011/3/14 22:00 | 0.05    | 4510    | 64       | 138        | 96.8      | 271           | 5831      | 72        |
| 2011/3/14 22:30 | 0.05    | 4391    | 64       | 137        | 96.1      | 269           | 5832      | 72        |
| 2011/3/14 23:00 | 0.06    | 4589    | 65       | 135        | 95.6      | 267           | 5777      | 70        |
| 2011/3/14 23:30 | 0.07    | 4588    | 60       | 133        | 95.2      | 265           | 5790      | 69        |
| 2011/3/15 0:00  | 0.07    | 4569    | 60       | 132        | 94.8      | 264           | 5796      | 68        |
| 2011/3/15 0:30  | 0.07    | 4569    | 60       | 130        | 94.1      | 263           | 5797      | 67        |
| 2011/3/15 1:00  | 0.07    | 4569    | 60       | 128        | 93.6      | 261           | 5801      | 66        |
| 2011/3/15 1:30  | 0.07    | 4589    | 60       | 127        | 93.2      | 260           | 5804      | 66        |
| 2011/3/15 2:00  | 0.07    | 4589    | 60       | 126        | 92.9      | 259           | 5809      | 65        |
| 2011/3/15 2:30  | 0.06    | 4519    | 66       | 125        | 92.3      | 258           | 5811      | 66        |
| 2011/3/15 3:00  | 0.06    | 4463    | 66       | 124        | 92.1      | 257           | 5812      | 66        |
| 2011/3/15 3:30  | 0.06    | 4392    | 66       | 122        | 91.5      | 255           | 5814      | 65        |
| 2011/3/15 4:00  | 0.06    | 4416    | 66       | 121        | 91.1      | 254           | 5812      | 62        |
| 2011/3/15 4:30  | 0.06    | 4404    | 66       | 120        | 90.8      | 253           | 5810      | 61        |
| 2011/3/15 5:00  | 0.06    | 4357    | 66       | 119        | 90.2      | 252           | 5814      | 60        |
| 2011/3/15 5:30  | 0.06    | 4586    | 67       | 117        | 89.9      | 250           | 5789      | 60        |
| 2011/3/15 6:00  | 0.06    | 4489    | 66       | 119        | 89.7      | 250           | 5807      | 58        |
| 2011/3/15 6:30  | 0.06    | 4437    | 66       | 117        | 89.7      | 249           | 5809      | 58        |
| 2011/3/15 7:00  | 0.06    | 4485    | 66       | 116        | 89.8      | 248           | 5803      | 57        |
| 2011/3/15 7:30  | 0.06    | 4431    | 66       | 115        | 89.5      | 247           | 5804      | 56        |
| 2011/3/15 8:00  | 0.06    | 4402    | 66       | 114        | 89.2      | 246           | 5805      | 56        |
| 2011/3/15 8:30  | 0.06    | 4366    | 66       | 113        | 87.8      | 245           | 5806      | 55        |
| 2011/3/15 9:00  | 0.06    | 4336    | 66       | 113        | 87.6      | 244           | 5808      | 55        |
| 2011/3/15 9:30  | 0.06    | 4302    | 66       | 112        | 87.1      | 244           | 5809      | 54        |
| 2011/3/15 10:00 | 0.06    | 4025    | 67       | 111        | 86.9      | 242           | 5821      | 54        |

2F2 2号機

| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 発動値             | 7.07    | 321(L3) |          | 13.7       | 57        |               | B3        | B2        |
| 2011/3/14 22:00 | 0.05    | 4146    | 84       | 116.6      | 98.6      | 235           | 5150      | 68        |
| 2011/3/14 22:30 | 0.05    | 4146    | 84       | 113.1      | 98.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.05    | 4148    | 84       | 112.5      | 97.8      | 231           | 5150      | 66        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 97.4      | 228           | 5150      | 65        |
| 2011/3/15 0:00  | 0.05    | 4151    | 84       | 108.7      | 97.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 108.9      | 96.8      | 226           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.9      | 96.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 95.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4154    | 84       | 101.5      | 95.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 99.8       | 95.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 98.4       | 94.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4157    | 84       | 97.1       | 94.4      | 216           | 5100      | 56        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 95.8       | 93.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 94.6       | 93.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4160    | 84       | 93.1       | 93.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30  | 0.05    | 4160    | 86       | 91.8       | 92.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00  | 0.06    | 4163    | 86       | 92.2       | 92.5      | 210           | 5100      | 51        |
| 2011/3/15 6:30  | 0.06    | 4163    | 88       | 90.8       | 92.0      | 208           | 5100      | 51        |
| 2011/3/15 7:00  | 0.06    | 4163    | 88       | 90.3       | 91.9      | 208           | 5100      | 50        |
| 2011/3/15 7:30  | 0.06    | 4165    | 86       | 89.1       | 91.7      | 207           | 5100      | 49        |
| 2011/3/15 8:00  | 0.06    | 4165    | 86       | 91.3       | 91.3      | 208           | 5100      | 48        |
| 2011/3/15 8:30  | 0.06    | 4165    | 88       | 87.5       | 91.0      | 205           | 5100      | 48        |
| 2011/3/15 9:00  | 0.06    | 4163    | 88       | 86.8       | 90.7      | 204           | 5100      | 47        |
| 2011/3/15 9:30  | 0.06    | 4165    | 88       | 85.6       | 90.2      | 203           | 5100      | 47        |
| 2011/3/15 10:00 | 0.06    | 4165    | 88       | 84.7       | 90.0      | 202           | 5050      | 46        |

| 3号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
| 登録値             | 7.07    | 321(L3) |          | 19.7       | 57.0      | -             | 50        | 32        |
| 2011/3/14 22:00 | -0.08   | 3435    | 30.9     | 31         | 60.1      | 132           | 599       | 45        |
| 2011/3/14 22:30 | -0.08   | 3434    | 30.6     | 31         | 60.1      | 132           | 599       | 45        |
| 2011/3/14 23:00 | -0.08   | 3442    | 30.8     | 31         | 59.9      | 132           | 599       | 45        |
| 2011/3/14 23:30 | -0.08   | 3437    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:00  | -0.08   | 3434    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:30  | -0.08   | 3468    | 30.6     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:00  | -0.08   | 3449    | 30.5     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:30  | -0.08   | 3442    | 30.5     | 32         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 2:00  | -0.08   | 3430    | 30.4     | 32         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 2:30  | -0.08   | 3444    | 30.4     | 31         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:00  | -0.08   | 3437    | 30.3     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:30  | -0.03   | 3000    | 30.3     | 31         | 59.5      | 132           | 599       | 45        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 4:30  | 0.04    | 3382    | 30.1     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 5:00  | 0.04    | 3381    | 30.1     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 5:30  | 0.03    | 3378    | 29.9     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 6:00  | 0.04    | 3378    | 29.9     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 6:30  | 0.04    | 3375    | 29.8     | 31         | 59.3      | 132           | 599       | 44        |
| 2011/3/15 7:00  | 0.04    | 3375    | 29.8     | 31         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 7:30  | 0.03    | 3372    | 29.7     | 31         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 8:00  | 0.04    | 3372    | 29.6     | 31         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 8:30  | 0.04    | 3372    | 29.6     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 9:00  | 0.04    | 3371    | 29.6     | 32         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 9:30  | 0.04    | 3371    | 29.5     | 32         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 10:00 | 0.04    | 3369    | 29.4     | 31         | 59.0      | 132           | 599       | 44        |

| 4号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/G圧力(kPaabs) | S/G水位(mm) | S/O温度(°C) |
| 参照値             | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 60        | 32        |
| 2011/3/14 22:00 | 0.33    | 3766    | 139.4    | 177        | 119.2     | 301           | 5350      | 113       |
| 2011/3/14 22:30 | 0.28    | 3797    | 136.3    | 176        | 117.8     | 300           | 5350      | 113       |
| 2011/3/14 23:00 | 0.18    | 3864    | 123.9    | 174        | 115.7     | 297           | 5350      | 113       |
| 2011/3/14 23:30 | 0.16    | 4232    | 114.6    | 172        | 113.4     | 294           | 5350      | 113       |
| 2011/3/15 0:00  | 0.16    | 4569    | 108.6    | 169        | 111.2     | 291           | 5300      | 112       |
| 2011/3/15 0:30  | 0.18    | 4599    | 104.7    | 166        | 108.9     | 288           | 5200      | 110       |
| 2011/3/15 1:00  | 0.15    | 4599    | 98.3     | 163        | 105.9     | 285           | 5260      | 112       |
| 2011/3/15 1:30  | 0.14    | 4599    | 97.2     | 160        | 104.1     | 282           | 5250      | 111       |
| 2011/3/15 2:00  | 0.13    | 4599    | 96.0     | 157        | 102.5     | 279           | 5260      | 110       |
| 2011/3/15 2:30  | 0.12    | 4599    | 95.4     | 154        | 101.8     | 276           | 5260      | 109       |
| 2011/3/15 3:00  | 0.1     | 4599    | 95.0     | 152        | 101.4     | 273           | 5200      | 107       |
| 2011/3/15 3:30  | 0.09    | 4599    | 94.8     | 149        | 100.8     | 270           | 5250      | 108       |
| 2011/3/15 4:00  | 0.07    | 4599    | 94.8     | 146        | 100.2     | 268           | 5250      | 104       |
| 2011/3/15 4:30  | 0.09    | 4599    | 94.8     | 144        | 99.8      | 265           | 6200      | 103       |
| 2011/3/15 5:00  | 0.08    | 4599    | 94.3     | 142        | 99.9      | 263           | 5250      | 102       |
| 2011/3/15 5:30  | 0.08    | 4599    | 93.8     | 140        | 98.6      | 261           | 6200      | 101       |
| 2011/3/15 6:00  | 0.09    | 4599    | 93.2     | 137        | 97.9      | 258           | 5200      | 100       |
| 2011/3/15 6:30  | 0.09    | 4599    | 91.3     | 134        | 97.3      | 255           | 6200      | 100       |
| 2011/3/15 7:00  | 0.1     | 4599    | 90.3     | 133        | 97        | 254           | 5200      | 99        |
| 2011/3/15 7:30  | 0.09    | 4599    | 89.4     | 131        | 96.8      | 252           | 5200      | 98        |
| 2011/3/15 8:00  | 0.09    | 4599    | 88.6     | 130        | 96.4      | 250           | 6200      | 87        |
| 2011/3/15 8:30  | 0.11    | 4599    | 88.2     | 128        | 96.3      | 249           | 5200      | 97        |
| 2011/3/15 9:00  | 0.1     | 4599    | 87.2     | 127        | 96        | 247           | 6190      | 98        |
| 2011/3/15 9:30  | 0.1     | 4599    | 86.5     | 125        | 95.7      | 245           | 6200      | 95        |
| 2011/3/15 10:00 | 0.1     | 4599    | 85.9     | 123        | 95.5      | 243           | 5200      | 94        |



271

1号機

| 時間<br>警報値       | 炉圧(Mpa)<br>7.07 | 炉水位(mm)<br>321(L3) | 炉水温度(°C)<br>炉水温度 | D/W圧力(kPa)<br>13.7 | D/W温度(°C)<br>57 | S/C圧力(kPaabs) | S/O水位(mm)<br>83 | S/O温度(°C)<br>32 |
|-----------------|-----------------|--------------------|------------------|--------------------|-----------------|---------------|-----------------|-----------------|
| 2011/3/14 22:00 | 0.05            | 4510               | 84               | 138                | 98.8            | 271           | 5831            | 72              |
| 2011/3/14 22:30 | 0.05            | 4391               | 84               | 137                | 98.1            | 269           | 5832            | 72              |
| 2011/3/14 23:00 | 0.08            | 4589               | 95               | 135                | 95.6            | 267           | 5777            | 70              |
| 2011/3/14 23:30 | 0.07            | 4588               | 90               | 133                | 95.2            | 265           | 5790            | 69              |
| 2011/3/15 0:00  | 0.07            | 4589               | 90               | 132                | 94.8            | 264           | 5798            | 69              |
| 2011/3/15 0:30  | 0.07            | 4589               | 90               | 130                | 94.1            | 263           | 5797            | 67              |
| 2011/3/15 1:00  | 0.07            | 4589               | 90               | 128                | 93.8            | 261           | 5801            | 66              |
| 2011/3/15 1:30  | 0.07            | 4589               | 90               | 127                | 93.2            | 260           | 5804            | 66              |
| 2011/3/15 2:00  | 0.07            | 4589               | 90               | 126                | 92.8            | 259           | 5809            | 65              |
| 2011/3/15 2:30  | 0.06            | 4519               | 86               | 125                | 92.3            | 258           | 5811            | 66              |
| 2011/3/15 3:00  | 0.06            | 4483               | 88               | 124                | 92.1            | 257           | 5812            | 68              |
| 2011/3/15 3:30  | 0.06            | 4392               | 86               | 122                | 91.5            | 255           | 5814            | 65              |
| 2011/3/15 4:00  | 0.06            | 4418               | 86               | 121                | 91.1            | 254           | 5812            | 62              |
| 2011/3/15 4:30  | 0.06            | 4404               | 86               | 120                | 90.8            | 253           | 5810            | 61              |
| 2011/3/15 5:00  | 0.06            | 4357               | 86               | 119                | 90.2            | 252           | 5814            | 60              |
| 2011/3/15 5:30  | 0.09            | 4586               | 97               | 117                | 89.9            | 250           | 5769            | 60              |
| 2011/3/15 6:00  | 0.06            | 4488               | 86               | 118                | 89.7            | 250           | 5807            | 58              |
| 2011/3/15 6:30  | 0.06            | 4437               | 86               | 117                | 89.7            | 249           | 5803            | 58              |
| 2011/3/15 7:00  | 0.06            | 4465               | 86               | 116                | 88.8            | 248           | 5803            | 57              |
| 2011/3/15 7:30  | 0.06            | 4431               | 86               | 115                | 88.5            | 247           | 5804            | 56              |
| 2011/3/15 8:00  | 0.06            | 4402               | 86               | 114                | 88.2            | 246           | 5805            | 56              |
| 2011/3/15 8:30  | 0.06            | 4366               | 86               | 113                | 87.8            | 245           | 5806            | 55              |
| 2011/3/15 9:00  | 0.06            | 4336               | 86               | 113                | 87.6            | 244           | 5808            | 55              |
| 2011/3/15 9:30  | 0.08            | 4302               | 86               | 112                | 87.1            | 244           | 5809            | 54              |
| 2011/3/15 10:00 | 0.09            | 4025               | 97               | 111                | 86.9            | 242           | 5821            | 54              |
| 2011/3/15 10:30 | 0.11            | 3866               | 103              | 108                | 86.6            | 241           | 5875            | 54              |
| 2011/3/15 11:00 | 0.14            | 4291               | 110              | 108                | 86.4            | 239           | 5768            | 53              |

3/15 11:00

0.14 4291 110 108 86.4 239 5768 53

本部 [redacted] → [redacted]

11:30

2F2

2号機

| 時間              | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 警報値             | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 83        | 32        |
| 2011/3/14 22:00 | 0.05    | 4146    | 84       | 118.8      | 98.6      | 235           | 5150      | 69        |
| 2011/3/14 22:30 | 0.05    | 4148    | 84       | 113.1      | 98.2      | 233           | 5150      | 67        |
| 2011/3/14 23:00 | 0.06    | 4148    | 84       | 112.5      | 97.9      | 231           | 5150      | 66        |
| 2011/3/14 23:30 | 0.05    | 4151    | 84       | 110.0      | 97.4      | 229           | 5150      | 65        |
| 2011/3/15 0:00  | 0.05    | 4151    | 84       | 108.1      | 97.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30  | 0.05    | 4154    | 84       | 108.9      | 96.8      | 225           | 5150      | 62        |
| 2011/3/15 1:00  | 0.05    | 4154    | 84       | 104.3      | 96.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30  | 0.05    | 4154    | 84       | 103.1      | 95.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00  | 0.05    | 4154    | 84       | 101.5      | 95.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30  | 0.05    | 4154    | 84       | 99.9       | 95.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00  | 0.05    | 4157    | 84       | 98.4       | 94.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30  | 0.05    | 4157    | 84       | 97.1       | 94.4      | 216           | 5100      | 58        |
| 2011/3/15 4:00  | 0.05    | 4157    | 84       | 95.8       | 93.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30  | 0.05    | 4160    | 84       | 94.8       | 93.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00  | 0.05    | 4160    | 84       | 93.1       | 93.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30  | 0.06    | 4160    | 86       | 91.8       | 92.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00  | 0.06    | 4163    | 86       | 92.2       | 92.5      | 210           | 5100      | 51        |
| 2011/3/15 6:30  | 0.06    | 4163    | 86       | 90.6       | 92.0      | 209           | 5100      | 51        |
| 2011/3/15 7:00  | 0.06    | 4163    | 86       | 90.3       | 91.9      | 208           | 5100      | 50        |
| 2011/3/15 7:30  | 0.06    | 4165    | 86       | 89.1       | 91.7      | 207           | 5100      | 49        |
| 2011/3/15 8:00  | 0.06    | 4185    | 86       | 91.3       | 91.3      | 206           | 5100      | 48        |
| 2011/3/15 8:30  | 0.06    | 4165    | 86       | 87.5       | 91.0      | 205           | 5100      | 48        |
| 2011/3/15 9:00  | 0.06    | 4163    | 86       | 86.6       | 90.7      | 204           | 5100      | 47        |
| 2011/3/15 9:30  | 0.06    | 4165    | 86       | 85.6       | 90.2      | 203           | 5100      | 47        |
| 2011/3/15 10:00 | 0.06    | 4165    | 86       | 84.7       | 90.0      | 202           | 5050      | 46        |
| 2011/3/15 10:30 | 0.06    | 4165    | 86       | 83.1       | 89.9      | 202           | 5050      | 45        |
| 2011/3/15 11:00 | 0.06    | 4165    | 86       | 83.4       | 89.7      | 201           | 5050      | 45        |
| 3/15/11:00      | 0.06    | 4165    | 86       | 83.4       | 89.7      | 201           | 5050      | 45        |

| 時間<br>警報値       | 3号機     |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                 | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
|                 | 7.07    | 321(L3) |          | 13.7       | 67.0      | -             | 50        | 32        |
| 2011/3/14 22:00 | -0.06   | 3435    | 30.9     | 31         | 60.1      | 132           | 600       | 45        |
| 2011/3/14 22:30 | -0.06   | 3434    | 30.8     | 31         | 60.1      | 132           | 598       | 45        |
| 2011/3/14 23:00 | -0.06   | 3442    | 30.8     | 31         | 59.9      | 132           | 599       | 45        |
| 2011/3/14 23:30 | -0.06   | 3437    | 30.7     | 31         | 59.8      | 132           | 598       | 45        |
| 2011/3/15 0:00  | -0.06   | 3434    | 30.7     | 31         | 59.8      | 132           | 599       | 45        |
| 2011/3/15 0:30  | -0.06   | 3468    | 30.6     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:00  | -0.06   | 3448    | 30.5     | 31         | 59.7      | 132           | 599       | 45        |
| 2011/3/15 1:30  | -0.06   | 3442    | 30.5     | 32         | 59.7      | 132           | 598       | 45        |
| 2011/3/15 2:00  | -0.06   | 3430    | 30.4     | 32         | 59.7      | 132           | 598       | 45        |
| 2011/3/15 2:30  | -0.06   | 3444    | 30.4     | 31         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:00  | -0.06   | 3437    | 30.3     | 32         | 59.7      | 133           | 599       | 45        |
| 2011/3/15 3:30  | -0.03   | 3000    | 30.3     | 31         | 59.5      | 132           | 595       | 45        |
| 2011/3/15 4:00  | 0.03    | 3375    | 30.3     | 31         | 59.5      | 132           | 599       | 45        |
| 2011/3/15 4:30  | 0.04    | 3382    | 30.1     | 31         | 59.5      | 132           | 599       | 44        |
| 2011/3/15 5:00  | 0.04    | 3381    | 30.1     | 31         | 59.4      | 132           | 598       | 44        |
| 2011/3/15 5:30  | 0.03    | 3378    | 30.0     | 31         | 59.4      | 132           | 599       | 44        |
| 2011/3/15 6:00  | 0.04    | 3378    | 29.9     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 6:30  | 0.04    | 3375    | 29.8     | 31         | 59.3      | 132           | 599       | 44        |
| 2011/3/15 7:00  | 0.04    | 3376    | 29.8     | 31         | 59.1      | 132           | 598       | 44        |
| 2011/3/15 7:30  | 0.03    | 3372    | 29.7     | 31         | 59.1      | 132           | 598       | 44        |
| 2011/3/15 8:00  | 0.04    | 3372    | 29.6     | 31         | 59.1      | 132           | 598       | 44        |
| 2011/3/15 8:30  | 0.04    | 3372    | 29.6     | 31         | 59.2      | 132           | 599       | 44        |
| 2011/3/15 9:00  | 0.04    | 3371    | 29.6     | 32         | 59.1      | 132           | 598       | 44        |
| 2011/3/15 9:30  | 0.04    | 3371    | 29.5     | 32         | 59.1      | 132           | 599       | 44        |
| 2011/3/15 10:00 | 0.04    | 3369    | 29.4     | 31         | 59.0      | 132           | 598       | 44        |
| 2011/3/15 10:30 | 0.04    | 3368    | 29.4     | 32         | 59.0      | 132           | 597       | 44        |
| 2011/3/15 11:00 | 0.04    | 3371    | 29.3     | 32         | 59.0      | 132           | 599       | 44        |

3/15 11:00

0.04 3371 29.3 32 59.0 132 599 44

| 4号機             |         |         |          |            |           |               |           |           |
|-----------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間<br>登報値       | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|                 | 7.07    | 321(L3) |          | 13.7       | 57        | -             | 50        | 32        |
| 2011/3/14 22:00 | 0.33    | 3766    | 139.4    | 177        | 118.2     | 301           | 5350      | 113       |
| 2011/3/14 22:30 | 0.29    | 3797    | 136.3    | 176        | 117.8     | 300           | 5350      | 113       |
| 2011/3/14 23:00 | 0.18    | 3864    | 123.9    | 174        | 115.7     | 297           | 5350      | 113       |
| 2011/3/14 23:30 | 0.16    | 4232    | 114.6    | 172        | 113.4     | 294           | 5350      | 113       |
| 2011/3/15 0:00  | 0.18    | 4589    | 108.6    | 169        | 111.2     | 291           | 5300      | 112       |
| 2011/3/15 0:30  | 0.18    | 4589    | 104.7    | 166        | 108.9     | 288           | 5200      | 110       |
| 2011/3/15 1:00  | 0.15    | 4589    | 99.3     | 163        | 105.9     | 285           | 5250      | 112       |
| 2011/3/15 1:30  | 0.14    | 4589    | 97.2     | 160        | 104.1     | 282           | 5250      | 111       |
| 2011/3/15 2:00  | 0.13    | 4589    | 96.0     | 157        | 102.5     | 279           | 5250      | 110       |
| 2011/3/15 2:30  | 0.12    | 4589    | 95.4     | 154        | 101.8     | 278           | 5250      | 108       |
| 2011/3/15 3:00  | 0.1     | 4589    | 95.0     | 152        | 101.4     | 273           | 5200      | 107       |
| 2011/3/15 3:30  | 0.09    | 4589    | 94.8     | 149        | 100.9     | 270           | 5250      | 106       |
| 2011/3/15 4:00  | 0.07    | 4589    | 94.8     | 146        | 100.2     | 268           | 5250      | 104       |
| 2011/3/15 4:30  | 0.09    | 4589    | 94.8     | 144        | 99.6      | 265           | 5200      | 103       |
| 2011/3/15 5:00  | 0.08    | 4589    | 94.3     | 142        | 98.9      | 263           | 5250      | 102       |
| 2011/3/15 5:30  | 0.09    | 4589    | 93.8     | 140        | 98.8      | 261           | 5200      | 101       |
| 2011/3/15 6:00  | 0.09    | 4589    | 93.2     | 137        | 97.9      | 258           | 5200      | 100       |
| 2011/3/15 6:30  | 0.09    | 4589    | 91.3     | 134        | 97.3      | 255           | 5200      | 100       |
| 2011/3/15 7:00  | 0.1     | 4589    | 90.3     | 133        | 97        | 254           | 5200      | 99        |
| 2011/3/15 7:30  | 0.09    | 4589    | 89.4     | 131        | 96.8      | 252           | 5200      | 98        |
| 2011/3/15 8:00  | 0.09    | 4589    | 88.8     | 130        | 96.4      | 250           | 5200      | 97        |
| 2011/3/15 8:30  | 0.11    | 4589    | 88.2     | 128        | 96.3      | 249           | 5200      | 97        |
| 2011/3/15 9:00  | 0.1     | 4589    | 87.2     | 127        | 96        | 247           | 5150      | 96        |
| 2011/3/15 9:30  | 0.1     | 4589    | 86.5     | 125        | 95.7      | 245           | 5200      | 95        |
| 2011/3/15 10:00 | 0.1     | 4589    | 85.9     | 123        | 95.5      | 243           | 5200      | 94        |
| 2011/3/15 10:30 | 0.1     | 4589    | 85.3     | 121        | 95.2      | 241           | 5200      | 93        |
| 2011/3/15 11:00 | 0.09    | 4589    | 84.6     | 119        | 94.8      | 240           | 5200      | 92        |
| 3/15<br>11:00   | 0.09    | 4589    | 84.6     | 119        | 94.8      | 240           | 5200      | 92        |

2F

| 時間<br>監視値          | 1号機     |         |          |            |           |               |           |           |
|--------------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
|                    | 炉圧(MPa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/C圧力(kPaabs) | S/C水位(mm) | S/C温度(°C) |
|                    | 7.07    | 321(L3) |          | 13.7       | 57        |               | 89        | 32        |
|                    |         |         | 炉水温度     |            |           |               |           |           |
| 2011/3/15 0:00     | 0.07    | 4689    | 90       | 132        | 84.8      | 284           | 5786      | 69        |
| 2011/3/15 0:30     | 0.07    | 4599    | 90       | 130        | 84.1      | 283           | 5797      | 67        |
| 2011/3/15 1:00     | 0.07    | 4989    | 90       | 128        | 83.8      | 281           | 5801      | 66        |
| 2011/3/15 1:30     | 0.07    | 4589    | 90       | 127        | 83.2      | 280           | 5804      | 66        |
| 2011/3/15 2:00     | 0.07    | 4589    | 90       | 126        | 82.8      | 259           | 5808      | 65        |
| 2011/3/15 2:30     | 0.06    | 4819    | 88       | 125        | 82.3      | 298           | 5811      | 66        |
| 2011/3/15 3:00     | 0.06    | 4483    | 86       | 124        | 82.1      | 257           | 5812      | 66        |
| 2011/3/15 3:30     | 0.06    | 4392    | 86       | 122        | 81.5      | 255           | 5814      | 65        |
| 2011/3/15 4:00     | 0.06    | 4418    | 86       | 121        | 81.1      | 254           | 5812      | 62        |
| 2011/3/15 4:30     | 0.08    | 4404    | 88       | 120        | 80.8      | 253           | 5810      | 61        |
| 2011/3/15 5:00     | 0.06    | 4357    | 88       | 119        | 80.2      | 252           | 5814      | 60        |
| 2011/3/15 5:30     | 0.09    | 4586    | 87       | 117        | 80.9      | 250           | 5769      | 60        |
| 2011/3/15 6:00     | 0.08    | 4488    | 86       | 118        | 80.7      | 260           | 5807      | 59        |
| 2011/3/15 6:30     | 0.08    | 4437    | 86       | 117        | 80.7      | 249           | 5809      | 58        |
| 2011/3/15 7:00     | 0.08    | 4465    | 88       | 116        | 80.8      | 248           | 5803      | 57        |
| 2011/3/15 7:30     | 0.08    | 4431    | 86       | 116        | 80.5      | 247           | 5804      | 58        |
| 2011/3/15 8:00     | 0.08    | 4402    | 88       | 114        | 80.2      | 249           | 5805      | 58        |
| 2011/3/15 8:30     | 0.08    | 4386    | 86       | 113        | 80.8      | 245           | 5806      | 55        |
| 2011/3/15 9:00     | 0.08    | 4386    | 86       | 113        | 80.8      | 244           | 5808      | 55        |
| 2011/3/15 9:30     | 0.08    | 4302    | 86       | 112        | 80.1      | 244           | 5809      | 54        |
| 2011/3/15 10:00    | 0.09    | 4025    | 87       | 111        | 80.8      | 242           | 5821      | 54        |
| 2011/3/15 10:30    | 0.11    | 3869    | 103      | 108        | 86.8      | 241           | 5875      | 64        |
| 2011/3/15 11:00    | 0.14    | 4291    | 110      | 108        | 86.4      | 239           | 5768      | 63        |
| 2011/3/15<br>11:30 | 0.21    | 1900    | 122      | 103        | 86.0      | 233           | 5502      | 53        |

2F2

2号機

| 時間                 | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/G圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
|--------------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 整頓値                | 7.07    | 321(L3) |          | 19.7       | 57        |               | 83        | 32        |
| 2011/3/15 0:00     | 0.05    | 4151    | 84       | 103.1      | 97.2      | 227           | 5150      | 64        |
| 2011/3/15 0:30     | 0.05    | 4154    | 84       | 106.9      | 96.8      | 225           | 5150      | 62        |
| 2011/3/15 1:00     | 0.05    | 4154    | 84       | 104.3      | 96.2      | 224           | 5150      | 61        |
| 2011/3/15 1:30     | 0.05    | 4154    | 84       | 103.1      | 95.9      | 222           | 5150      | 60        |
| 2011/3/15 2:00     | 0.05    | 4154    | 84       | 101.5      | 95.4      | 221           | 5150      | 59        |
| 2011/3/15 2:30     | 0.05    | 4154    | 84       | 99.9       | 95.1      | 219           | 5100      | 58        |
| 2011/3/15 3:00     | 0.05    | 4157    | 84       | 98.4       | 94.7      | 218           | 5100      | 57        |
| 2011/3/15 3:30     | 0.05    | 4157    | 84       | 97.1       | 94.4      | 216           | 5100      | 56        |
| 2011/3/15 4:00     | 0.05    | 4157    | 84       | 95.6       | 93.9      | 215           | 5100      | 55        |
| 2011/3/15 4:30     | 0.05    | 4160    | 84       | 94.6       | 93.6      | 214           | 5100      | 54        |
| 2011/3/15 5:00     | 0.05    | 4160    | 84       | 93.1       | 93.1      | 212           | 5100      | 53        |
| 2011/3/15 5:30     | 0.05    | 4160    | 86       | 91.9       | 92.7      | 211           | 5100      | 52        |
| 2011/3/15 6:00     | 0.05    | 4163    | 86       | 92.2       | 92.5      | 210           | 5100      | 51        |
| 2011/3/15 6:30     | 0.05    | 4163    | 86       | 90.6       | 92.0      | 209           | 5100      | 51        |
| 2011/3/15 7:00     | 0.05    | 4163    | 86       | 90.3       | 91.9      | 208           | 5100      | 50        |
| 2011/3/15 7:30     | 0.05    | 4165    | 86       | 89.1       | 91.7      | 207           | 5100      | 49        |
| 2011/3/15 8:00     | 0.05    | 4165    | 86       | 91.3       | 91.3      | 206           | 5100      | 48        |
| 2011/3/15 8:30     | 0.05    | 4165    | 86       | 87.5       | 91.0      | 206           | 5100      | 48        |
| 2011/3/15 9:00     | 0.05    | 4163    | 86       | 86.6       | 90.7      | 204           | 5100      | 47        |
| 2011/3/15 9:30     | 0.05    | 4165    | 86       | 85.6       | 90.2      | 203           | 5100      | 47        |
| 2011/3/15 10:00    | 0.05    | 4165    | 86       | 84.7       | 90.0      | 202           | 5050      | 46        |
| 2011/3/15 10:30    | 0.05    | 4165    | 86       | 83.1       | 89.8      | 202           | 5050      | 45        |
| 2011/3/15 11:00    | 0.05    | 4165    | 86       | 83.4       | 89.7      | 201           | 5050      | 45        |
| 2011/3/15<br>11:30 | 0.06    | 4168    | 86       | 81.8       | 89.7      | 201           | 5050      | 44        |



| 4号機                |         |         |          |            |           |               |           |           |
|--------------------|---------|---------|----------|------------|-----------|---------------|-----------|-----------|
| 時間                 | 炉圧(Mpa) | 炉水位(mm) | 炉水温度(°C) | D/W圧力(kPa) | D/W温度(°C) | S/O圧力(kPaabs) | S/O水位(mm) | S/O温度(°C) |
| 管線値                | 7.07    | 321(L3) |          | 13.7       | 87        | -             | 50        | 32        |
| 2011/3/15 0:00     | 0.19    | 4589    | 108.9    | 188        | 111.2     | 281           | 5200      | 112       |
| 2011/3/15 0:30     | 0.18    | 4588    | 104.7    | 186        | 108.8     | 288           | 5200      | 110       |
| 2011/3/15 1:00     | 0.15    | 4588    | 98.3     | 163        | 105.9     | 293           | 5250      | 112       |
| 2011/3/15 1:30     | 0.14    | 4588    | 97.2     | 160        | 104.1     | 282           | 5250      | 111       |
| 2011/3/15 2:00     | 0.13    | 4588    | 96.0     | 157        | 102.5     | 279           | 5250      | 110       |
| 2011/3/15 2:30     | 0.12    | 4588    | 95.4     | 154        | 101.8     | 276           | 5250      | 108       |
| 2011/3/15 3:00     | 0.1     | 4588    | 95.0     | 152        | 101.4     | 273           | 5200      | 107       |
| 2011/3/15 3:30     | 0.08    | 4588    | 94.8     | 148        | 100.8     | 270           | 5250      | 106       |
| 2011/3/15 4:00     | 0.07    | 4588    | 94.8     | 146        | 100.2     | 268           | 5250      | 104       |
| 2011/3/15 4:30     | 0.09    | 4588    | 94.8     | 144        | 99.8      | 265           | 5200      | 103       |
| 2011/3/15 5:00     | 0.08    | 4588    | 94.3     | 142        | 98.8      | 263           | 5250      | 102       |
| 2011/3/15 5:30     | 0.08    | 4588    | 93.8     | 140        | 98.8      | 261           | 5200      | 101       |
| 2011/3/15 6:00     | 0.08    | 4588    | 93.2     | 137        | 97.8      | 258           | 5200      | 100       |
| 2011/3/15 6:30     | 0.09    | 4588    | 91.3     | 134        | 97.3      | 255           | 5200      | 100       |
| 2011/3/15 7:00     | 0.1     | 4588    | 90.3     | 133        | 97        | 254           | 5200      | 99        |
| 2011/3/15 7:30     | 0.09    | 4588    | 89.4     | 131        | 96.8      | 252           | 5200      | 99        |
| 2011/3/15 8:00     | 0.09    | 4588    | 88.6     | 130        | 96.4      | 250           | 5200      | 87        |
| 2011/3/15 8:30     | 0.11    | 4588    | 88.2     | 128        | 96.3      | 249           | 5200      | 87        |
| 2011/3/15 9:00     | 0.1     | 4588    | 87.2     | 127        | 96        | 247           | 5150      | 86        |
| 2011/3/15 9:30     | 0.1     | 4588    | 86.5     | 125        | 95.7      | 245           | 5200      | 85        |
| 2011/3/15 10:00    | 0.1     | 4588    | 85.9     | 123        | 95.5      | 243           | 5200      | 84        |
| 2011/3/15 10:30    | 0.1     | 4588    | 85.3     | 121        | 95.2      | 241           | 5200      | 83        |
| 2011/3/15 11:00    | 0.09    | 4588    | 84.6     | 119        | 94.8      | 240           | 5200      | 82        |
| 2011/3/15<br>11:30 | 0.1     | 4589    | 84.1     | 117        | 94.6      | 237           | 5200      | 91        |



2F-1号機

| 時間                 | 炉压(Mpa) | 炉水位(mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W压力<br>(kPa) | D/W温度<br>(°C) | S/C压力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|--------------------|---------|---------|---------------------|-------------------|----------------|---------------|-------------------|---------------|---------------|
| 警報値                | 7.07    | 321(L3) |                     |                   | 13.7           | 57            | -                 | 83            | 32            |
| 2011/3/15 0:00     | 0.07    | 4589    |                     | 90                | 132            | 94.8          | 264               | 5796          | 69            |
| 2011/3/15 0:30     | 0.07    | 4589    |                     | 90                | 130            | 94.1          | 263               | 5797          | 67            |
| 2011/3/15 1:00     | 0.07    | 4589    |                     | 90                | 128            | 93.8          | 261               | 5801          | 66            |
| 2011/3/15 1:30     | 0.07    | 4589    |                     | 90                | 127            | 93.2          | 260               | 5804          | 66            |
| 2011/3/15 2:00     | 0.07    | 4589    |                     | 90                | 126            | 92.9          | 259               | 5809          | 65            |
| 2011/3/15 2:30     | 0.06    | 4519    |                     | 86                | 125            | 92.3          | 258               | 5811          | 66            |
| 2011/3/15 3:00     | 0.06    | 4463    |                     | 86                | 124            | 92.1          | 257               | 5812          | 66            |
| 2011/3/15 3:30     | 0.06    | 4392    |                     | 86                | 122            | 91.5          | 255               | 5814          | 65            |
| 2011/3/15 4:00     | 0.06    | 4418    |                     | 86                | 121            | 91.1          | 254               | 5812          | 62            |
| 2011/3/15 4:30     | 0.06    | 4404    |                     | 86                | 120            | 90.8          | 253               | 5810          | 61            |
| 2011/3/15 5:00     | 0.06    | 4357    |                     | 86                | 119            | 90.2          | 252               | 5814          | 60            |
| 2011/3/15 5:30     | 0.09    | 4586    |                     | 97                | 117            | 89.9          | 250               | 5769          | 60            |
| 2011/3/15 6:00     | 0.06    | 4488    |                     | 86                | 118            | 89.7          | 250               | 5807          | 58            |
| 2011/3/15 6:30     | 0.06    | 4437    |                     | 86                | 117            | 89.7          | 249               | 5803          | 58            |
| 2011/3/15 7:00     | 0.06    | 4465    |                     | 86                | 116            | 88.8          | 248               | 5803          | 57            |
| 2011/3/15 7:30     | 0.06    | 4431    |                     | 86                | 115            | 88.5          | 247               | 5804          | 56            |
| 2011/3/15 8:00     | 0.06    | 4402    |                     | 86                | 114            | 88.2          | 246               | 5805          | 56            |
| 2011/3/15 8:30     | 0.06    | 4366    |                     | 86                | 113            | 87.8          | 245               | 5806          | 55            |
| 2011/3/15 9:00     | 0.06    | 4336    |                     | 86                | 113            | 87.6          | 244               | 5808          | 55            |
| 2011/3/15 9:30     | 0.06    | 4302    |                     | 86                | 112            | 87.1          | 244               | 5809          | 54            |
| 2011/3/15 10:00    | 0.09    | 4025    | 75                  | 97                | 111            | 86.9          | 242               | 6821          | 54            |
| 2011/3/15 10:30    | 0.11    | 3866    | 73                  | 103               | 108            | 86.6          | 241               | 5875          | 54            |
| 2011/3/15 11:00    | 0.14    | 4291    | 73                  | 110               | 108            | 86.4          | 239               | 5768          | 53            |
| 2011/3/15 11:30    | 0.21    | 1900    | 72                  | 122               | 103            | 86.0          | 233               | 5502          | 53            |
| 2011/3/15 12:00    | 0.17    | 6500    | 71                  | 116               | 101            | 85.7          | 230               | 5330          | 52            |
| 2011/3/15 12:30    | 0.13    | 6100    | 68                  | 108               | 97             | 85.3          | 227               | 5273          | 52            |
| 2011/3/15<br>13:00 | 0.13    | 5400    | 68                  | 108               | 97             | 85.0          | 226               | 5233          | 51            |

## 2F-2号機

| 時間                 | 炉圧<br>(Mpa) | 炉水位<br>(mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|--------------------|-------------|-------------|---------------------|-------------------|----------------|---------------|-------------------|---------------|---------------|
| 警報値                | 7.07        | 321(L3)     |                     |                   | 13.7           | 57            | -                 | 83            | 32            |
| 2011/3/15 0:00     | 0.05        | 4151        |                     | 84                | 108.1          | 97.2          | 227               | 5150          | 64            |
| 2011/3/15 0:30     | 0.05        | 4154        |                     | 84                | 106.9          | 96.6          | 225               | 5150          | 62            |
| 2011/3/15 1:00     | 0.05        | 4154        |                     | 84                | 104.3          | 96.2          | 224               | 5150          | 61            |
| 2011/3/15 1:30     | 0.05        | 4154        |                     | 84                | 103.1          | 95.9          | 222               | 5150          | 60            |
| 2011/3/15 2:00     | 0.05        | 4154        |                     | 84                | 101.5          | 95.4          | 221               | 5150          | 59            |
| 2011/3/15 2:30     | 0.05        | 4154        |                     | 84                | 99.9           | 95.1          | 219               | 5100          | 58            |
| 2011/3/15 3:00     | 0.05        | 4157        |                     | 84                | 98.4           | 94.7          | 218               | 5100          | 57            |
| 2011/3/15 3:30     | 0.05        | 4157        |                     | 84                | 97.1           | 94.4          | 216               | 5100          | 56            |
| 2011/3/15 4:00     | 0.05        | 4157        |                     | 84                | 95.6           | 93.9          | 215               | 5100          | 55            |
| 2011/3/15 4:30     | 0.05        | 4160        |                     | 84                | 94.6           | 93.6          | 214               | 5100          | 54            |
| 2011/3/15 5:00     | 0.05        | 4160        |                     | 84                | 93.1           | 93.1          | 212               | 5100          | 53            |
| 2011/3/15 5:30     | 0.06        | 4160        |                     | 86                | 91.8           | 92.7          | 211               | 5100          | 52            |
| 2011/3/15 6:00     | 0.06        | 4163        |                     | 86                | 92.2           | 92.5          | 210               | 5100          | 51            |
| 2011/3/15 6:30     | 0.06        | 4163        |                     | 86                | 90.6           | 92.0          | 209               | 5100          | 51            |
| 2011/3/15 7:00     | 0.06        | 4163        |                     | 86                | 90.3           | 91.9          | 208               | 5100          | 50            |
| 2011/3/15 7:30     | 0.06        | 4165        |                     | 86                | 89.1           | 91.7          | 207               | 5100          | 49            |
| 2011/3/15 8:00     | 0.06        | 4165        |                     | 86                | 91.3           | 91.3          | 206               | 5100          | 48            |
| 2011/3/15 8:30     | 0.06        | 4165        |                     | 86                | 87.5           | 91.0          | 205               | 5100          | 48            |
| 2011/3/15 9:00     | 0.06        | 4163        |                     | 86                | 86.6           | 90.7          | 204               | 5100          | 47            |
| 2011/3/15 9:30     | 0.06        | 4165        |                     | 86                | 85.6           | 90.2          | 203               | 5100          | 47            |
| 2011/3/15 10:00    | 0.06        | 4165        | 70                  | 86                | 84.7           | 90.0          | 202               | 5050          | 46            |
| 2011/3/15 10:30    | 0.06        | 4165        | 70                  | 86                | 83.1           | 89.9          | 202               | 5050          | 45            |
| 2011/3/15 11:00    | 0.06        | 4165        | 69                  | 86                | 83.4           | 89.7          | 201               | 5050          | 45            |
| 2011/3/15 11:30    | 0.06        | 4168        | 69                  | 86                | 81.8           | 89.7          | 201               | 5050          | 44            |
| 2011/3/15 12:00    | 0.05        | 4109        | 69                  | 82                | 82.2           | 89.3          | 200               | 5050          | 44            |
| 2011/3/15 12:30    | 0.05        | 4219        | 70                  | 82                | 80.3           | 88.9          | 199               | 5050          | 44            |
| 2011/3/15<br>13:00 | 0.03        | 4224        | 69                  | 69                | 80.0           | 88.6          | 198               | 5050          | 43            |

2F-3号機

| 時間                 | 炉圧<br>(Mpa) | 炉水位<br>(mm) | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|--------------------|-------------|-------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 警報値                | 7.07        | 321(L3)     |                     | 13.7           | 57.0          | -                 | 50            | 32            |
| 2011/3/14 22:00    | -0.06       | 3435        | 30.9                | 31             | 60.1          | 132               | 600           | 45            |
| 2011/3/14 22:30    | -0.06       | 3434        | 30.8                | 31             | 60.1          | 132               | 598           | 45            |
| 2011/3/14 23:00    | -0.06       | 3442        | 30.8                | 31             | 59.9          | 132               | 599           | 45            |
| 2011/3/14 23:30    | -0.06       | 3437        | 30.7                | 31             | 59.8          | 132               | 598           | 45            |
| 2011/3/15 0:00     | -0.06       | 3434        | 30.7                | 31             | 59.8          | 132               | 599           | 45            |
| 2011/3/15 0:30     | -0.06       | 3466        | 30.6                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:00     | -0.06       | 3448        | 30.5                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:30     | -0.06       | 3442        | 30.5                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:00     | -0.06       | 3430        | 30.4                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:30     | -0.06       | 3444        | 30.4                | 31             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:00     | -0.06       | 3437        | 30.3                | 32             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:30     | -0.03       | 3000        | 30.3                | 31             | 59.5          | 132               | 595           | 45            |
| 2011/3/15 4:00     | 0.03        | 3375        | 30.3                | 31             | 59.5          | 132               | 599           | 45            |
| 2011/3/15 4:30     | 0.04        | 3382        | 30.1                | 31             | 59.5          | 132               | 599           | 44            |
| 2011/3/15 5:00     | 0.04        | 3381        | 30.1                | 31             | 59.4          | 132               | 598           | 44            |
| 2011/3/15 5:30     | 0.03        | 3378        | 30.0                | 31             | 59.4          | 132               | 599           | 44            |
| 2011/3/15 6:00     | 0.04        | 3378        | 29.9                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 6:30     | 0.04        | 3375        | 29.8                | 31             | 59.3          | 132               | 599           | 44            |
| 2011/3/15 7:00     | 0.04        | 3375        | 29.8                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 7:30     | 0.03        | 3372        | 29.7                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:00     | 0.04        | 3372        | 29.6                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:30     | 0.04        | 3372        | 29.6                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 9:00     | 0.04        | 3371        | 29.6                | 32             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 9:30     | 0.04        | 3371        | 29.5                | 32             | 59.1          | 132               | 599           | 44            |
| 2011/3/15 10:00    | 0.04        | 3369        | 29.4                | 31             | 59.0          | 132               | 598           | 44            |
| 2011/3/15 10:30    | 0.04        | 3368        | 29.4                | 32             | 59.0          | 132               | 597           | 44            |
| 2011/3/15 11:00    | 0.04        | 3371        | 29.3                | 32             | 59.0          | 132               | 599           | 44            |
| 2011/3/15 11:30    | 0.04        | 3369        | 29.3                | 32             | 58.8          | 132               | 600           | 44            |
| 2011/3/15 12:00    | 0.04        | 3367        | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 12:30    | 0.04        | 3367        | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15<br>13:00 | 0.04        | 3365        | 29.2                | 32             | 58.8          | 133               | 598           | 44            |

2F-4号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C) | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|----------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)  |          | 13.7        | 57         | -              | 50         | 32         |
| 2011/3/14 22:00 | 0.33     | 3766     | 139.4    | 177         | 118.2      | 301            | 5350       | 113        |
| 2011/3/14 22:30 | 0.29     | 3797     | 136.3    | 176         | 117.8      | 300            | 5350       | 113        |
| 2011/3/14 23:00 | 0.18     | 3864     | 123.9    | 174         | 115.7      | 297            | 5350       | 113        |
| 2011/3/14 23:30 | 0.16     | 4232     | 114.6    | 172         | 113.4      | 294            | 5350       | 113        |
| 2011/3/15 0:00  | 0.18     | 4589     | 108.6    | 169         | 111.2      | 291            | 5300       | 112        |
| 2011/3/15 0:30  | 0.18     | 4589     | 104.7    | 166         | 108.9      | 288            | 5200       | 110        |
| 2011/3/15 1:00  | 0.15     | 4589     | 99.3     | 163         | 105.9      | 285            | 5250       | 112        |
| 2011/3/15 1:30  | 0.14     | 4589     | 97.2     | 160         | 104.1      | 282            | 5250       | 111        |
| 2011/3/15 2:00  | 0.13     | 4589     | 96.0     | 157         | 102.5      | 279            | 5250       | 110        |
| 2011/3/15 2:30  | 0.12     | 4589     | 95.4     | 154         | 101.8      | 276            | 5250       | 108        |
| 2011/3/15 3:00  | 0.1      | 4589     | 95.0     | 152         | 101.4      | 273            | 5200       | 107        |
| 2011/3/15 3:30  | 0.09     | 4589     | 94.8     | 149         | 100.9      | 270            | 5250       | 106        |
| 2011/3/15 4:00  | 0.07     | 4589     | 94.8     | 146         | 100.2      | 268            | 5250       | 104        |
| 2011/3/15 4:30  | 0.09     | 4589     | 94.8     | 144         | 99.6       | 265            | 5200       | 103        |
| 2011/3/15 5:00  | 0.08     | 4589     | 94.3     | 142         | 98.9       | 263            | 5250       | 102        |
| 2011/3/15 5:30  | 0.08     | 4589     | 93.8     | 140         | 98.6       | 261            | 5200       | 101        |
| 2011/3/15 6:00  | 0.09     | 4589     | 93.2     | 137         | 97.9       | 258            | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589     | 91.3     | 134         | 97.3       | 255            | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589     | 90.3     | 133         | 97         | 254            | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589     | 89.4     | 131         | 96.8       | 252            | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589     | 88.6     | 130         | 96.4       | 250            | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589     | 88.2     | 128         | 96.3       | 249            | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589     | 87.2     | 127         | 96         | 247            | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589     | 86.5     | 125         | 95.7       | 245            | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589     | 85.9     | 123         | 95.5       | 243            | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589     | 85.3     | 121         | 95.2       | 241            | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589     | 84.6     | 119         | 94.8       | 240            | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589     | 84.1     | 117         | 94.6       | 237            | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589     | 82.6     | 114         | 94         | 234            | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589     | 80.0     | 111         | 93.5       | 231            | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589     | 78.6     | 109         | 93         | 229            | 5150       | 88         |

1/4



2F

2F-7072ト1072ト (13:30)

2F-1号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度 (°C)<br>給水ノズル温度 | 炉水温度 (°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|----------------------|---------------------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)  |                      |                     | 13.7        | 57         | -              | 83         | 32         |
| 2011/3/15 0:00  | 0.07     | 4589     |                      | 90                  | 132         | 94.8       | 264            | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                      | 90                  | 130         | 94.1       | 263            | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                      | 90                  | 128         | 93.8       | 261            | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                      | 90                  | 127         | 93.2       | 260            | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                      | 90                  | 126         | 92.9       | 259            | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                      | 86                  | 125         | 92.3       | 258            | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                      | 86                  | 124         | 92.1       | 257            | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                      | 86                  | 122         | 91.5       | 255            | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                      | 86                  | 121         | 91.1       | 254            | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                      | 86                  | 120         | 90.8       | 253            | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                      | 86                  | 119         | 90.2       | 252            | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                      | 97                  | 117         | 89.9       | 250            | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                      | 86                  | 118         | 89.7       | 250            | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                      | 86                  | 117         | 89.7       | 249            | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                      | 86                  | 116         | 88.8       | 248            | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                      | 86                  | 115         | 88.5       | 247            | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                      | 86                  | 114         | 88.2       | 246            | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                      | 86                  | 113         | 87.8       | 245            | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                      | 86                  | 113         | 87.6       | 244            | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                      | 86                  | 112         | 87.1       | 244            | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                   | 97                  | 111         | 86.9       | 242            | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                   | 103                 | 108         | 86.6       | 241            | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                   | 110                 | 108         | 86.4       | 239            | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                   | 122                 | 103         | 86.0       | 233            | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71                   | 116                 | 101         | 85.7       | 230            | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                   | 108                 | 97          | 85.3       | 227            | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 68                   | 108                 | 97          | 85.0       | 226            | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67                   | 116                 | 94          | 84.5       | 223            | 5069       | 50         |

2/4

2F-2号機

| 時間                 | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|--------------------|----------|----------|---------------------|-------------------|-------------|------------|----------------|------------|------------|
| 警報値                | 7.07     | 321(1.3) |                     |                   | 13.7        | 57         |                | 83         | 32         |
| 2011/3/15 0:00     | 0.05     | 4151     |                     | 84                | 108.1       | 97.2       | 227            | 5150       | 64         |
| 2011/3/15 0:30     | 0.05     | 4154     |                     | 84                | 106.9       | 96.6       | 225            | 5150       | 62         |
| 2011/3/15 1:00     | 0.05     | 4154     |                     | 84                | 104.3       | 96.2       | 224            | 5150       | 61         |
| 2011/3/15 1:30     | 0.05     | 4154     |                     | 84                | 103.1       | 95.9       | 222            | 5150       | 60         |
| 2011/3/15 2:00     | 0.05     | 4154     |                     | 84                | 101.5       | 95.4       | 221            | 5150       | 59         |
| 2011/3/15 2:30     | 0.05     | 4154     |                     | 84                | 99.9        | 95.1       | 219            | 5100       | 58         |
| 2011/3/15 3:00     | 0.05     | 4157     |                     | 84                | 98.4        | 94.7       | 218            | 5100       | 57         |
| 2011/3/15 3:30     | 0.05     | 4157     |                     | 84                | 97.1        | 94.4       | 216            | 5100       | 56         |
| 2011/3/15 4:00     | 0.05     | 4157     |                     | 84                | 95.6        | 93.9       | 215            | 5100       | 55         |
| 2011/3/15 4:30     | 0.05     | 4160     |                     | 84                | 94.6        | 93.6       | 214            | 5100       | 54         |
| 2011/3/15 5:00     | 0.05     | 4160     |                     | 84                | 93.1        | 93.1       | 212            | 5100       | 53         |
| 2011/3/15 5:30     | 0.06     | 4160     |                     | 86                | 91.8        | 92.7       | 211            | 5100       | 52         |
| 2011/3/15 6:00     | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210            | 5100       | 51         |
| 2011/3/15 6:30     | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209            | 5100       | 51         |
| 2011/3/15 7:00     | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208            | 5100       | 50         |
| 2011/3/15 7:30     | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207            | 5100       | 49         |
| 2011/3/15 8:00     | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206            | 5100       | 48         |
| 2011/3/15 8:30     | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205            | 5100       | 48         |
| 2011/3/15 9:00     | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204            | 5100       | 47         |
| 2011/3/15 9:30     | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203            | 5100       | 47         |
| 2011/3/15 10:00    | 0.06     | 4165     | 70                  | 86                | 84.7        | 90.0       | 202            | 5050       | 46         |
| 2011/3/15 10:30    | 0.06     | 4165     | 70                  | 86                | 83.1        | 89.9       | 202            | 5050       | 45         |
| 2011/3/15 11:00    | 0.06     | 4165     | 69                  | 86                | 83.4        | 89.7       | 201            | 5050       | 45         |
| 2011/3/15 11:30    | 0.06     | 4168     | 69                  | 86                | 81.8        | 89.7       | 201            | 5050       | 44         |
| 2011/3/15 12:00    | 0.05     | 4109     | 69                  | 82                | 82.2        | 89.3       | 200            | 5050       | 44         |
| 2011/3/15 12:30    | 0.05     | 4219     | 70                  | 82                | 80.3        | 88.9       | 199            | 5050       | 44         |
| 2011/3/15 13:00    | 0.03     | 4224     | 69                  | 69                | 80.0        | 88.6       | 198            | 5050       | 43         |
| 2011/3/15<br>13:30 | 0.03     | 4227     | 71                  | 69                | 78.8        | 88.3       | 197            | 5050       | 43         |

3/4

2F-3号機

| 時間                 | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|--------------------|----------|----------|---------------------|-------------|------------|----------------|------------|------------|
| 警報値                | 7.07     | 321(L3)  |                     | 13.7        | 57.0       | -              | 50         | 32         |
| 2011/3/14 22:00    | -0.06    | 3435     | 30.9                | 31          | 60.1       | 132            | 600        | 45         |
| 2011/3/14 22:30    | -0.06    | 3434     | 30.8                | 31          | 60.1       | 132            | 598        | 45         |
| 2011/3/14 23:00    | -0.06    | 3442     | 30.8                | 31          | 59.9       | 132            | 599        | 45         |
| 2011/3/14 23:30    | -0.06    | 3437     | 30.7                | 31          | 59.8       | 132            | 598        | 45         |
| 2011/3/15 0:00     | -0.06    | 3434     | 30.7                | 31          | 59.8       | 132            | 599        | 45         |
| 2011/3/15 0:30     | -0.06    | 3466     | 30.6                | 31          | 59.7       | 132            | 599        | 45         |
| 2011/3/15 1:00     | -0.06    | 3448     | 30.5                | 31          | 59.7       | 132            | 599        | 45         |
| 2011/3/15 1:30     | -0.06    | 3442     | 30.5                | 32          | 59.7       | 132            | 598        | 45         |
| 2011/3/15 2:00     | -0.06    | 3430     | 30.4                | 32          | 59.7       | 132            | 598        | 45         |
| 2011/3/15 2:30     | -0.06    | 3444     | 30.4                | 31          | 59.7       | 133            | 599        | 45         |
| 2011/3/15 3:00     | -0.06    | 3437     | 30.3                | 32          | 59.7       | 133            | 599        | 45         |
| 2011/3/15 3:30     | -0.03    | 3000     | 30.3                | 31          | 59.5       | 132            | 595        | 45         |
| 2011/3/15 4:00     | 0.03     | 3375     | 30.3                | 31          | 59.5       | 132            | 599        | 45         |
| 2011/3/15 4:30     | 0.04     | 3382     | 30.1                | 31          | 59.5       | 132            | 599        | 44         |
| 2011/3/15 5:00     | 0.04     | 3381     | 30.1                | 31          | 59.4       | 132            | 598        | 44         |
| 2011/3/15 5:30     | 0.03     | 3378     | 30.0                | 31          | 59.4       | 132            | 599        | 44         |
| 2011/3/15 6:00     | 0.04     | 3378     | 29.9                | 31          | 59.2       | 132            | 599        | 44         |
| 2011/3/15 6:30     | 0.04     | 3375     | 29.8                | 31          | 59.3       | 132            | 599        | 44         |
| 2011/3/15 7:00     | 0.04     | 3375     | 29.8                | 31          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 7:30     | 0.03     | 3372     | 29.7                | 31          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 8:00     | 0.04     | 3372     | 29.6                | 31          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 8:30     | 0.04     | 3372     | 29.6                | 31          | 59.2       | 132            | 599        | 44         |
| 2011/3/15 9:00     | 0.04     | 3371     | 29.6                | 32          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 9:30     | 0.04     | 3371     | 29.5                | 32          | 59.1       | 132            | 599        | 44         |
| 2011/3/15 10:00    | 0.04     | 3369     | 29.4                | 31          | 59.0       | 132            | 598        | 44         |
| 2011/3/15 10:30    | 0.04     | 3368     | 29.4                | 32          | 59.0       | 132            | 597        | 44         |
| 2011/3/15 11:00    | 0.04     | 3371     | 29.3                | 32          | 59.0       | 132            | 599        | 44         |
| 2011/3/15 11:30    | 0.04     | 3369     | 29.3                | 32          | 58.8       | 132            | 600        | 44         |
| 2011/3/15 12:00    | 0.04     | 3367     | 29.2                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15 12:30    | 0.04     | 3367     | 29.2                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15 13:00    | 0.04     | 3365     | 29.2                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15<br>13:30 | 0.04     | 3367     | 29.1                | 32          | 58.7       | 133            | 598        | 44         |

4/4

2F-4号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水/ズル温度 | D/W压力 (kPa) | D/W温度 (°C) | S/C压力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)  |                     | 13.7        | 57         |                | 50         | 32         |
| 2011/3/14 22:00 | 0.33     | 3766     | 139.4               | 177         | 118.2      | 301            | 5350       | 113        |
| 2011/3/14 22:30 | 0.29     | 3797     | 136.3               | 176         | 117.8      | 300            | 5350       | 113        |
| 2011/3/14 23:00 | 0.18     | 3864     | 123.9               | 174         | 115.7      | 297            | 5350       | 113        |
| 2011/3/14 23:30 | 0.16     | 4232     | 114.6               | 172         | 113.4      | 294            | 5350       | 113        |
| 2011/3/15 0:00  | 0.18     | 4589     | 108.6               | 169         | 111.2      | 291            | 5300       | 112        |
| 2011/3/15 0:30  | 0.18     | 4589     | 104.7               | 166         | 108.9      | 288            | 5200       | 110        |
| 2011/3/15 1:00  | 0.15     | 4589     | 99.3                | 163         | 105.9      | 285            | 5250       | 112        |
| 2011/3/15 1:30  | 0.14     | 4589     | 97.2                | 160         | 104.1      | 282            | 5250       | 111        |
| 2011/3/15 2:00  | 0.13     | 4589     | 96.0                | 157         | 102.5      | 279            | 5250       | 110        |
| 2011/3/15 2:30  | 0.12     | 4589     | 95.4                | 154         | 101.8      | 276            | 5250       | 108        |
| 2011/3/15 3:00  | 0.1      | 4589     | 95.0                | 152         | 101.4      | 273            | 5200       | 107        |
| 2011/3/15 3:30  | 0.09     | 4589     | 94.8                | 149         | 100.9      | 270            | 5250       | 106        |
| 2011/3/15 4:00  | 0.07     | 4589     | 94.8                | 146         | 100.2      | 268            | 5250       | 104        |
| 2011/3/15 4:30  | 0.09     | 4589     | 94.8                | 144         | 99.6       | 265            | 5200       | 103        |
| 2011/3/15 5:00  | 0.08     | 4589     | 94.3                | 142         | 98.9       | 263            | 5250       | 102        |
| 2011/3/15 5:30  | 0.08     | 4589     | 93.8                | 140         | 98.6       | 261            | 5200       | 101        |
| 2011/3/15 6:00  | 0.09     | 4589     | 93.2                | 137         | 97.9       | 258            | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589     | 91.3                | 134         | 97.3       | 255            | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589     | 90.3                | 133         | 97         | 254            | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589     | 89.4                | 131         | 96.8       | 252            | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589     | 88.6                | 130         | 96.4       | 250            | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589     | 88.2                | 128         | 96.3       | 249            | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589     | 87.2                | 127         | 96         | 247            | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589     | 86.5                | 125         | 95.7       | 245            | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589     | 85.9                | 123         | 95.5       | 243            | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589     | 85.3                | 121         | 95.2       | 241            | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589     | 84.6                | 119         | 94.8       | 240            | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589     | 84.1                | 117         | 94.6       | 237            | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589     | 82.6                | 114         | 94         | 234            | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589     | 80.0                | 111         | 93.5       | 231            | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589     | 78.6                | 109         | 93         | 229            | 5150       | 88         |
| 2011/3/15 13:30 | 0.1      | 4589     | 77.4                | 107         | 92.5       | 227            | 5150       | 87         |



1/4

2F-703ポート 107A-A (15:00)

2F-1号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度 (°C)<br>給水ノズル温度 | 炉水温度 (°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|----------------------|---------------------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)  |                      |                     | 13.7        | 57         |                | 83         | 32         |
| 2011/3/15 0:00  | 0.07     | 4589     |                      | 90                  | 132         | 94.8       | 264            | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                      | 90                  | 130         | 94.1       | 263            | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                      | 90                  | 128         | 93.8       | 261            | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                      | 90                  | 127         | 93.2       | 260            | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                      | 90                  | 126         | 92.9       | 259            | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                      | 86                  | 125         | 92.3       | 258            | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                      | 86                  | 124         | 92.1       | 257            | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                      | 86                  | 122         | 91.5       | 255            | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                      | 86                  | 121         | 91.1       | 254            | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                      | 86                  | 120         | 90.8       | 253            | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                      | 86                  | 119         | 90.2       | 252            | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                      | 97                  | 117         | 89.9       | 250            | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                      | 86                  | 118         | 89.7       | 250            | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                      | 86                  | 117         | 89.7       | 249            | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                      | 86                  | 116         | 88.8       | 248            | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                      | 86                  | 115         | 88.5       | 247            | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                      | 86                  | 114         | 88.2       | 246            | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                      | 86                  | 113         | 87.8       | 245            | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                      | 86                  | 113         | 87.6       | 244            | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                      | 86                  | 112         | 87.1       | 244            | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     |                      | 97                  | 111         | 86.9       | 242            | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     |                      | 103                 | 108         | 86.6       | 241            | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     |                      | 110                 | 108         | 86.4       | 239            | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     |                      | 122                 | 103         | 86.0       | 233            | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     |                      | 116                 | 101         | 85.7       | 230            | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     |                      | 108                 | 97          | 85.3       | 227            | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     |                      | 108                 | 97          | 85.0       | 226            | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     |                      | 116                 | 94          | 84.5       | 223            | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     |                      | 108                 | 92          | 84.0       | 220            | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     |                      | 110                 | 89          | 83.7       | 218            | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65                   | 108                 | 89          | 83.3       | 215            | 4785       | 48         |

アップセット  
水位計

停止時  
水位計

2/4

2F-2号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) アップセット | 炉水温度(°C) 給水ノズル温度 | 炉水温度(°C) 炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|-----------------|------------------|----------------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)         |                  |                | 13.7        | 57         |                | 83         | 32         |
| 2011/3/15 0:00  | 0.05     | 4151            |                  | 84             | 108.1       | 97.2       | 227            | 5150       | 64         |
| 2011/3/15 0:30  | 0.05     | 4154            |                  | 84             | 106.9       | 96.6       | 225            | 5150       | 62         |
| 2011/3/15 1:00  | 0.05     | 4154            |                  | 84             | 104.3       | 96.2       | 224            | 5150       | 61         |
| 2011/3/15 1:30  | 0.05     | 4154            |                  | 84             | 103.1       | 95.9       | 222            | 5150       | 60         |
| 2011/3/15 2:00  | 0.05     | 4154            |                  | 84             | 101.5       | 95.4       | 221            | 5150       | 59         |
| 2011/3/15 2:30  | 0.05     | 4154            |                  | 84             | 99.9        | 95.1       | 219            | 5100       | 58         |
| 2011/3/15 3:00  | 0.05     | 4157            |                  | 84             | 98.4        | 94.7       | 218            | 5100       | 57         |
| 2011/3/15 3:30  | 0.05     | 4157            |                  | 84             | 97.1        | 94.4       | 216            | 5100       | 56         |
| 2011/3/15 4:00  | 0.05     | 4157            |                  | 84             | 95.6        | 93.9       | 215            | 5100       | 55         |
| 2011/3/15 4:30  | 0.05     | 4160            |                  | 84             | 94.6        | 93.6       | 214            | 5100       | 54         |
| 2011/3/15 5:00  | 0.05     | 4160            |                  | 84             | 93.1        | 93.1       | 212            | 5100       | 53         |
| 2011/3/15 5:30  | 0.06     | 4160            |                  | 86             | 91.8        | 92.7       | 211            | 5100       | 52         |
| 2011/3/15 6:00  | 0.06     | 4163            |                  | 86             | 92.2        | 92.5       | 210            | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163            |                  | 86             | 90.6        | 92.0       | 209            | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163            |                  | 86             | 90.3        | 91.9       | 208            | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165            |                  | 86             | 89.1        | 91.7       | 207            | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165            |                  | 86             | 91.3        | 91.3       | 206            | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165            |                  | 86             | 87.5        | 91.0       | 205            | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163            |                  | 86             | 86.6        | 90.7       | 204            | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165            |                  | 86             | 85.6        | 90.2       | 203            | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165            | 70               | 86             | 84.7        | 90.0       | 202            | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165            | 70               | 86             | 83.1        | 89.9       | 202            | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165            | 69               | 86             | 83.4        | 89.7       | 201            | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168            | 69               | 86             | 81.8        | 89.7       | 201            | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109            | 69               | 82             | 82.2        | 89.3       | 200            | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219            | 70               | 82             | 80.3        | 88.9       | 199            | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224            | 69               | 69             | 80.0        | 88.6       | 198            | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227            | 71               | 69             | 78.8        | 88.3       | 197            | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230            | 67               | 69             | 77.5        | 87.9       | 195            | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233            | 72               | 69             | 75.6        | 87.6       | 194            | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233            | 65               | 69             | 75.6        | 87.2       | 193            | 5050       | 42         |

3/4

2F-3号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm)<br>777セツト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|--------------------|---------------------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)            |                     | 13.7        | 57.0       | -              | 50         | 32         |
| 2011/3/15 0:00  | -0.06    | 3434               | 30.7                | 31          | 59.8       | 132            | 599        | 45         |
| 2011/3/15 0:30  | -0.06    | 3466               | 30.6                | 31          | 59.7       | 132            | 599        | 45         |
| 2011/3/15 1:00  | -0.06    | 3448               | 30.5                | 31          | 59.7       | 132            | 599        | 45         |
| 2011/3/15 1:30  | -0.06    | 3442               | 30.5                | 32          | 59.7       | 132            | 598        | 45         |
| 2011/3/15 2:00  | -0.06    | 3430               | 30.4                | 32          | 59.7       | 132            | 598        | 45         |
| 2011/3/15 2:30  | -0.06    | 3444               | 30.4                | 31          | 59.7       | 133            | 599        | 45         |
| 2011/3/15 3:00  | -0.06    | 3437               | 30.3                | 32          | 59.7       | 133            | 599        | 45         |
| 2011/3/15 3:30  | -0.03    | 3000               | 30.3                | 31          | 59.5       | 132            | 595        | 45         |
| 2011/3/15 4:00  | 0.03     | 3375               | 30.3                | 31          | 59.5       | 132            | 599        | 45         |
| 2011/3/15 4:30  | 0.04     | 3382               | 30.1                | 31          | 59.5       | 132            | 599        | 44         |
| 2011/3/15 5:00  | 0.04     | 3381               | 30.1                | 31          | 59.4       | 132            | 598        | 44         |
| 2011/3/15 5:30  | 0.03     | 3378               | 30.0                | 31          | 59.4       | 132            | 599        | 44         |
| 2011/3/15 6:00  | 0.04     | 3378               | 29.9                | 31          | 59.2       | 132            | 599        | 44         |
| 2011/3/15 6:30  | 0.04     | 3375               | 29.8                | 31          | 59.3       | 132            | 599        | 44         |
| 2011/3/15 7:00  | 0.04     | 3375               | 29.8                | 31          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 7:30  | 0.03     | 3372               | 29.7                | 31          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 8:00  | 0.04     | 3372               | 29.6                | 31          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 8:30  | 0.04     | 3372               | 29.6                | 31          | 59.2       | 132            | 599        | 44         |
| 2011/3/15 9:00  | 0.04     | 3371               | 29.6                | 32          | 59.1       | 132            | 598        | 44         |
| 2011/3/15 9:30  | 0.04     | 3371               | 29.5                | 32          | 59.1       | 132            | 599        | 44         |
| 2011/3/15 10:00 | 0.04     | 3369               | 29.4                | 31          | 59.0       | 132            | 598        | 44         |
| 2011/3/15 10:30 | 0.04     | 3368               | 29.4                | 32          | 59.0       | 132            | 597        | 44         |
| 2011/3/15 11:00 | 0.04     | 3371               | 29.3                | 32          | 59.0       | 132            | 599        | 44         |
| 2011/3/15 11:30 | 0.04     | 3369               | 29.3                | 32          | 58.8       | 132            | 600        | 44         |
| 2011/3/15 12:00 | 0.04     | 3367               | 29.2                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15 12:30 | 0.04     | 3367               | 29.2                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15 13:00 | 0.04     | 3365               | 29.2                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15 13:30 | 0.04     | 3367               | 29.1                | 32          | 58.7       | 133            | 598        | 44         |
| 2011/3/15 14:00 | 0.04     | 3365               | 29.1                | 32          | 58.8       | 133            | 598        | 44         |
| 2011/3/15 14:30 | 0.04     | 3364               | 29.0                | 32          | 58.7       | 133            | 598        | 44         |
| 2011/3/15 15:00 | 0.04     | 3365               | 29.0                | 32          | 58.8       | 133            | 598        | 44         |

4/4

2F-4号機

| 時間              | 炉庄 (Mpa) | 炉水位 (mm) アップセット | 炉水温度(°C) 給水ノズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|-----------------|------------------|-------------|------------|----------------|------------|------------|
| 警報値             | 7.07     | 321(L3)         |                  | 13.7        | 57         | -              | 50         | 32         |
| 2011/3/15 0:00  | 0.18     | 4589            | 108.6            | 169         | 111.2      | 291            | 5300       | 112        |
| 2011/3/15 0:30  | 0.18     | 4589            | 104.7            | 166         | 108.9      | 288            | 5200       | 110        |
| 2011/3/15 1:00  | 0.15     | 4589            | 99.3             | 163         | 105.9      | 285            | 5250       | 112        |
| 2011/3/15 1:30  | 0.14     | 4589            | 97.2             | 160         | 104.1      | 282            | 5250       | 111        |
| 2011/3/15 2:00  | 0.13     | 4589            | 96.0             | 157         | 102.5      | 279            | 5250       | 110        |
| 2011/3/15 2:30  | 0.12     | 4589            | 95.4             | 154         | 101.8      | 276            | 5250       | 108        |
| 2011/3/15 3:00  | 0.1      | 4589            | 95.0             | 152         | 101.4      | 273            | 5200       | 107        |
| 2011/3/15 3:30  | 0.09     | 4589            | 94.8             | 149         | 100.9      | 270            | 5250       | 106        |
| 2011/3/15 4:00  | 0.07     | 4589            | 94.8             | 146         | 100.2      | 268            | 5250       | 104        |
| 2011/3/15 4:30  | 0.09     | 4589            | 94.8             | 144         | 99.6       | 265            | 5200       | 103        |
| 2011/3/15 5:00  | 0.08     | 4589            | 94.3             | 142         | 98.9       | 263            | 5250       | 102        |
| 2011/3/15 5:30  | 0.08     | 4589            | 93.8             | 140         | 98.6       | 261            | 5200       | 101        |
| 2011/3/15 6:00  | 0.09     | 4589            | 93.2             | 137         | 97.9       | 258            | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589            | 91.3             | 134         | 97.3       | 255            | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589            | 90.3             | 133         | 97         | 254            | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589            | 89.4             | 131         | 96.8       | 252            | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589            | 88.6             | 130         | 96.4       | 250            | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589            | 88.2             | 128         | 96.3       | 249            | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589            | 87.2             | 127         | 96         | 247            | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589            | 86.5             | 125         | 95.7       | 245            | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589            | 85.9             | 123         | 95.5       | 243            | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589            | 85.3             | 121         | 95.2       | 241            | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589            | 84.6             | 119         | 94.8       | 240            | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589            | 84.1             | 117         | 94.6       | 237            | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589            | 82.6             | 114         | 94         | 234            | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589            | 80.0             | 111         | 93.5       | 231            | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589            | 78.6             | 109         | 93         | 229            | 5150       | 88         |
| 2011/3/15 13:30 | 0.1      | 4589            | 77.4             | 107         | 92.5       | 227            | 5150       | 87         |
| 2011/3/15 14:00 | 0.1      | 4589            | 76.1             | 104         | 92.2       | 224            | 5150       | 86         |
| 2011/3/15 14:30 | 0.1      | 4589            | 75.1             | 102         | 91.9       | 222            | 5150       | 85         |
| 2011/3/15 15:00 | 0.1      | 4589            | 74.1             | 101         | 91.6       | 220            | 5200       | 84         |

1530

2F-1号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|----------------|------------|------------|
| 2011/3/15 0:00  | 0.07     | 4589     |                     | 90                 | 132         | 94.8       | 264            | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                     | 90                 | 130         | 94.1       | 263            | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                     | 90                 | 128         | 93.8       | 261            | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                     | 90                 | 127         | 93.2       | 260            | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                     | 90                 | 126         | 92.9       | 259            | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                     | 86                 | 125         | 92.3       | 258            | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                     | 86                 | 124         | 92.1       | 257            | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                     | 86                 | 122         | 91.5       | 255            | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                     | 86                 | 121         | 91.1       | 254            | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                     | 86                 | 120         | 90.8       | 253            | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                     | 86                 | 119         | 90.2       | 252            | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                     | 97                 | 117         | 89.9       | 250            | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250            | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249            | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                     | 86                 | 116         | 88.8       | 248            | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247            | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246            | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245            | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244            | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244            | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242            | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241            | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239            | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233            | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71                  | 116                | 101         | 85.7       | 230            | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227            | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 68                  | 108                | 97          | 85.0       | 226            | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67                  | 116                | 94          | 84.5       | 223            | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66                  | 108                | 92          | 84.0       | 220            | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 66                  | 110                | 89          | 83.7       | 218            | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65                  | 108                | 89          | 83.3       | 215            | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 65                  | 108                | 86          | 83.0       | 213            | 4697       | 48         |

アップセット  
水位計

停止時  
水位計

2F-2号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>アップセット | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|-------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | 0.05        | 4151                  |                     | 84                | 108.1          | 97.2          | 227               | 5150          | 64            |
| 2011/3/15 0:30  | 0.05        | 4154                  |                     | 84                | 106.9          | 96.6          | 225               | 5150          | 62            |
| 2011/3/15 1:00  | 0.05        | 4154                  |                     | 84                | 104.3          | 96.2          | 224               | 5150          | 61            |
| 2011/3/15 1:30  | 0.05        | 4154                  |                     | 84                | 103.1          | 95.9          | 222               | 5150          | 60            |
| 2011/3/15 2:00  | 0.05        | 4154                  |                     | 84                | 101.5          | 95.4          | 221               | 5150          | 59            |
| 2011/3/15 2:30  | 0.05        | 4154                  |                     | 84                | 99.9           | 95.1          | 219               | 5100          | 58            |
| 2011/3/15 3:00  | 0.05        | 4157                  |                     | 84                | 98.4           | 94.7          | 218               | 5100          | 57            |
| 2011/3/15 3:30  | 0.05        | 4157                  |                     | 84                | 97.1           | 94.4          | 216               | 5100          | 56            |
| 2011/3/15 4:00  | 0.05        | 4157                  |                     | 84                | 95.6           | 93.9          | 215               | 5100          | 55            |
| 2011/3/15 4:30  | 0.05        | 4160                  |                     | 84                | 94.6           | 93.6          | 214               | 5100          | 54            |
| 2011/3/15 5:00  | 0.05        | 4160                  |                     | 84                | 93.1           | 93.1          | 212               | 5100          | 53            |
| 2011/3/15 5:30  | 0.06        | 4160                  |                     | 86                | 91.8           | 92.7          | 211               | 5100          | 52            |
| 2011/3/15 6:00  | 0.06        | 4163                  |                     | 86                | 92.2           | 92.5          | 210               | 5100          | 51            |
| 2011/3/15 6:30  | 0.06        | 4163                  |                     | 86                | 90.6           | 92.0          | 209               | 5100          | 51            |
| 2011/3/15 7:00  | 0.06        | 4163                  |                     | 86                | 90.3           | 91.9          | 208               | 5100          | 50            |
| 2011/3/15 7:30  | 0.06        | 4165                  |                     | 86                | 89.1           | 91.7          | 207               | 5100          | 49            |
| 2011/3/15 8:00  | 0.06        | 4165                  |                     | 86                | 91.3           | 91.3          | 206               | 5100          | 48            |
| 2011/3/15 8:30  | 0.06        | 4165                  |                     | 86                | 87.5           | 91.0          | 205               | 5100          | 48            |
| 2011/3/15 9:00  | 0.06        | 4163                  |                     | 86                | 86.6           | 90.7          | 204               | 5100          | 47            |
| 2011/3/15 9:30  | 0.06        | 4165                  |                     | 86                | 85.6           | 90.2          | 203               | 5100          | 47            |
| 2011/3/15 10:00 | 0.06        | 4165                  |                     | 86                | 84.7           | 90.0          | 202               | 5050          | 46            |
| 2011/3/15 10:30 | 0.06        | 4165                  | 70                  | 86                | 83.1           | 89.9          | 202               | 5050          | 45            |
| 2011/3/15 11:00 | 0.06        | 4165                  | 70                  | 86                | 83.4           | 89.7          | 201               | 5050          | 45            |
| 2011/3/15 11:30 | 0.06        | 4168                  | 69                  | 86                | 81.8           | 89.7          | 201               | 5050          | 44            |
| 2011/3/15 12:00 | 0.05        | 4109                  | 69                  | 82                | 82.2           | 89.3          | 200               | 5050          | 44            |
| 2011/3/15 12:30 | 0.05        | 4219                  | 70                  | 82                | 80.3           | 88.9          | 199               | 5050          | 44            |
| 2011/3/15 13:00 | 0.03        | 4224                  | 69                  | 69                | 80.0           | 88.6          | 198               | 5050          | 43            |
| 2011/3/15 13:30 | 0.03        | 4227                  | 71                  | 69                | 78.8           | 88.3          | 197               | 5050          | 43            |
| 2011/3/15 14:00 | 0.03        | 4230                  | 67                  | 69                | 77.5           | 87.9          | 195               | 5050          | 42            |
| 2011/3/15 14:30 | 0.03        | 4233                  | 72                  | 69                | 75.6           | 87.6          | 194               | 5050          | 42            |
| 2011/3/15 15:00 | 0.03        | 4233                  | 65                  | 69                | 75.6           | 87.2          | 193               | 5050          | 42            |
| 2011/3/15 15:30 | 0.03        | 3600                  | 73                  | 69                | 74             | 86.9          | 193               | 5000          | 41            |

アップセット  
水位計

停止時  
水位計

2F-3号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>アツセト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|---------------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | -0.06       | 3434                | 30.7                | 31             | 59.8          | 132               | 599           | 45            |
| 2011/3/15 0:30  | -0.06       | 3466                | 30.6                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:00  | -0.06       | 3448                | 30.5                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:30  | -0.06       | 3442                | 30.5                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:00  | -0.06       | 3430                | 30.4                | 32             | 59.7          | 132               | 596           | 45            |
| 2011/3/15 2:30  | -0.06       | 3444                | 30.4                | 31             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:00  | -0.06       | 3437                | 30.3                | 32             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:30  | -0.03       | 3000                | 30.3                | 31             | 59.5          | 132               | 595           | 45            |
| 2011/3/15 4:00  | 0.03        | 3375                | 30.3                | 31             | 59.5          | 132               | 599           | 45            |
| 2011/3/15 4:30  | 0.04        | 3382                | 30.1                | 31             | 59.5          | 132               | 599           | 44            |
| 2011/3/15 5:00  | 0.04        | 3381                | 30.1                | 31             | 59.4          | 132               | 598           | 44            |
| 2011/3/15 5:30  | 0.03        | 3378                | 30.0                | 31             | 59.4          | 132               | 599           | 44            |
| 2011/3/15 6:00  | 0.04        | 3378                | 29.9                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                | 29.8                | 31             | 59.3          | 132               | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                | 29.8                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                | 29.7                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                | 29.6                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                | 29.6                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                | 29.6                | 32             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                | 29.5                | 32             | 59.1          | 132               | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                | 29.4                | 31             | 59.0          | 132               | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                | 29.4                | 32             | 59.0          | 132               | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                | 29.3                | 32             | 59.0          | 132               | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                | 29.3                | 32             | 58.8          | 132               | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                | 29.1                | 32             | 58.7          | 133               | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                | 29.1                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                | 29.0                | 32             | 58.7          | 133               | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                | 29.0                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                | 28.9                | 32             | 58.7          | 133               | 599           | 44            |

## 2F-4号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>アワーセット | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | 0.18        | 4589                  | 108.6               | 169            | 111.2         | 291               | 5300          | 112           |
| 2011/3/15 0:30  | 0.18        | 4589                  | 104.7               | 166            | 108.9         | 288               | 5200          | 110           |
| 2011/3/15 1:00  | 0.15        | 4589                  | 99.3                | 163            | 105.9         | 285               | 5250          | 112           |
| 2011/3/15 1:30  | 0.14        | 4589                  | 97.2                | 160            | 104.1         | 282               | 5250          | 111           |
| 2011/3/15 2:00  | 0.13        | 4589                  | 96.0                | 157            | 102.5         | 279               | 5250          | 110           |
| 2011/3/15 2:30  | 0.12        | 4589                  | 95.4                | 154            | 101.8         | 276               | 5250          | 108           |
| 2011/3/15 3:00  | 0.1         | 4589                  | 95.0                | 152            | 101.4         | 273               | 5200          | 107           |
| 2011/3/15 3:30  | 0.09        | 4589                  | 94.8                | 149            | 100.9         | 270               | 5250          | 106           |
| 2011/3/15 4:00  | 0.07        | 4589                  | 94.8                | 146            | 100.2         | 268               | 5250          | 104           |
| 2011/3/15 4:30  | 0.09        | 4589                  | 94.8                | 144            | 99.6          | 265               | 5200          | 103           |
| 2011/3/15 5:00  | 0.08        | 4589                  | 94.3                | 142            | 98.9          | 263               | 5250          | 102           |
| 2011/3/15 5:30  | 0.08        | 4589                  | 93.8                | 140            | 98.6          | 261               | 5200          | 101           |
| 2011/3/15 6:00  | 0.09        | 4589                  | 93.2                | 137            | 97.9          | 258               | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                  | 91.3                | 134            | 97.3          | 255               | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                  | 90.3                | 133            | 97            | 254               | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                  | 89.4                | 131            | 96.8          | 252               | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                  | 88.6                | 130            | 96.4          | 250               | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                  | 88.2                | 128            | 96.3          | 249               | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                  | 87.2                | 127            | 96            | 247               | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                  | 86.5                | 125            | 95.7          | 245               | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                  | 85.9                | 123            | 95.5          | 243               | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                  | 85.3                | 121            | 95.2          | 241               | 5200          | 93            |
| 2011/3/15 11:00 | 0.09        | 4589                  | 84.6                | 119            | 94.8          | 240               | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                  | 84.1                | 117            | 94.6          | 237               | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                  | 82.6                | 114            | 94            | 234               | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                  | 80.0                | 111            | 93.5          | 231               | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                  | 78.6                | 109            | 93            | 229               | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                  | 77.4                | 107            | 92.5          | 227               | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                  | 76.1                | 104            | 92.2          | 224               | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                  | 75.1                | 102            | 91.9          | 222               | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                  | 74.1                | 101            | 91.6          | 220               | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                  | 73.2                | 99             | 91.4          | 218               | 5150          | 82            |



76=00

2F-1号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|----------------|------------|------------|
| 2011/3/15 0:00  | 0.07     | 4589     |                     | 90                 | 132         | 94.8       | 264            | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                     | 90                 | 130         | 94.1       | 263            | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                     | 90                 | 128         | 93.8       | 261            | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                     | 90                 | 127         | 93.2       | 260            | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                     | 90                 | 126         | 92.9       | 259            | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                     | 86                 | 125         | 92.3       | 258            | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                     | 86                 | 124         | 92.1       | 257            | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                     | 86                 | 122         | 91.5       | 255            | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                     | 86                 | 121         | 91.1       | 254            | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                     | 86                 | 120         | 90.8       | 253            | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                     | 86                 | 119         | 90.2       | 252            | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                     | 97                 | 117         | 89.9       | 250            | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250            | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249            | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                     | 86                 | 116         | 88.8       | 248            | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247            | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246            | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245            | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244            | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244            | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242            | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241            | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239            | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233            | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71                  | 116                | 101         | 85.7       | 230            | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227            | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 68                  | 108                | 97          | 85.0       | 226            | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67                  | 116                | 94          | 84.5       | 223            | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66                  | 108                | 92          | 84.0       | 220            | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 66                  | 110                | 89          | 83.7       | 218            | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65                  | 108                | 89          | 83.3       | 215            | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 65                  | 108                | 86          | 83         | 213            | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 65                  | 76                 | 88          | 83         | 216            | 4962       | 47         |

777セツ  
水位計

停止時  
水位計

777セツ  
水位計

2F-2号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm)<br>アップセット | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|--------------------|---------------------|-------------------|-------------|------------|----------------|------------|------------|
| 2011/3/15 0:00  | 0.05     | 4151               |                     | 84                | 108.1       | 97.2       | 227            | 5150       | 64         |
| 2011/3/15 0:30  | 0.05     | 4154               |                     | 84                | 106.9       | 96.6       | 225            | 5150       | 62         |
| 2011/3/15 1:00  | 0.05     | 4154               |                     | 84                | 104.3       | 96.2       | 224            | 5150       | 61         |
| 2011/3/15 1:30  | 0.05     | 4154               |                     | 84                | 103.1       | 95.9       | 222            | 5150       | 60         |
| 2011/3/15 2:00  | 0.05     | 4154               |                     | 84                | 101.5       | 95.4       | 221            | 5150       | 59         |
| 2011/3/15 2:30  | 0.05     | 4154               |                     | 84                | 99.9        | 95.1       | 219            | 5100       | 58         |
| 2011/3/15 3:00  | 0.05     | 4157               |                     | 84                | 98.4        | 94.7       | 218            | 5100       | 57         |
| 2011/3/15 3:30  | 0.05     | 4157               |                     | 84                | 97.1        | 94.4       | 216            | 5100       | 56         |
| 2011/3/15 4:00  | 0.05     | 4157               |                     | 84                | 95.6        | 93.9       | 215            | 5100       | 55         |
| 2011/3/15 4:30  | 0.05     | 4160               |                     | 84                | 94.6        | 93.6       | 214            | 5100       | 54         |
| 2011/3/15 5:00  | 0.05     | 4160               |                     | 84                | 93.1        | 93.1       | 212            | 5100       | 53         |
| 2011/3/15 5:30  | 0.06     | 4160               |                     | 86                | 91.8        | 92.7       | 211            | 5100       | 52         |
| 2011/3/15 6:00  | 0.06     | 4163               |                     | 86                | 92.2        | 92.5       | 210            | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163               |                     | 86                | 90.6        | 92.0       | 209            | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163               |                     | 86                | 90.3        | 91.9       | 208            | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165               |                     | 86                | 89.1        | 91.7       | 207            | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165               |                     | 86                | 91.3        | 91.3       | 206            | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165               |                     | 86                | 87.5        | 91.0       | 205            | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163               |                     | 86                | 86.6        | 90.7       | 204            | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165               |                     | 86                | 85.6        | 90.2       | 203            | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165               | 70                  | 86                | 84.7        | 90.0       | 202            | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165               | 70                  | 86                | 83.1        | 89.9       | 202            | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165               | 69                  | 86                | 83.4        | 89.7       | 201            | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168               | 69                  | 86                | 81.8        | 89.7       | 201            | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109               | 69                  | 82                | 82.2        | 89.3       | 200            | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219               | 70                  | 82                | 80.3        | 88.9       | 199            | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224               | 69                  | 69                | 80.0        | 88.6       | 198            | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227               | 71                  | 69                | 78.8        | 88.3       | 197            | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230               | 67                  | 69                | 77.5        | 87.9       | 195            | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233               | 72                  | 69                | 75.6        | 87.6       | 194            | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233               | 65                  | 69                | 75.6        | 87.2       | 193            | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600               | 73                  | 69                | 74          | 87         | 193            | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286               | 66                  | 69                | 74          | 87         | 192            | 5000       | 41         |

アップセット  
水位計

停止時  
水位計

アップセット  
水位計

2F-3号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>777セト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|----------------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | -0.06       | 3434                 | 30.7                | 31             | 59.8          | 132               | 599           | 45            |
| 2011/3/15 0:30  | -0.06       | 3466                 | 30.6                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:00  | -0.06       | 3448                 | 30.5                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:30  | -0.06       | 3442                 | 30.5                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:00  | -0.06       | 3430                 | 30.4                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:30  | -0.06       | 3444                 | 30.4                | 31             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:00  | -0.06       | 3437                 | 30.3                | 32             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:30  | -0.03       | 3000                 | 30.3                | 31             | 59.5          | 132               | 595           | 45            |
| 2011/3/15 4:00  | 0.03        | 3375                 | 30.3                | 31             | 59.5          | 132               | 599           | 45            |
| 2011/3/15 4:30  | 0.04        | 3382                 | 30.1                | 31             | 59.5          | 132               | 599           | 44            |
| 2011/3/15 5:00  | 0.04        | 3381                 | 30.1                | 31             | 59.4          | 132               | 598           | 44            |
| 2011/3/15 5:30  | 0.03        | 3378                 | 30.0                | 31             | 59.4          | 132               | 599           | 44            |
| 2011/3/15 6:00  | 0.04        | 3378                 | 29.9                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                 | 29.8                | 31             | 59.3          | 132               | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                 | 29.8                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                 | 29.7                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                 | 29.6                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                 | 29.6                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                 | 29.6                | 32             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                 | 29.5                | 32             | 59.1          | 132               | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                 | 29.4                | 31             | 59.0          | 132               | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                 | 29.4                | 32             | 59.0          | 132               | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                 | 29.3                | 32             | 59.0          | 132               | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                 | 29.3                | 32             | 58.8          | 132               | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                 | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                 | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                 | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                 | 29.1                | 32             | 58.7          | 133               | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                 | 29.1                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                 | 29.0                | 32             | 58.7          | 133               | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                 | 29.0                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                 | 28.9                | 32             | 58.7          | 133               | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                 | 26.9                | 33             | 58.7          | 133               | 597           | 44            |

2F-4号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>アップセット | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | 0.18        | 4589                  | 108.6               | 169            | 111.2         | 291               | 5300          | 112           |
| 2011/3/15 0:30  | 0.18        | 4589                  | 104.7               | 166            | 108.9         | 288               | 5200          | 110           |
| 2011/3/15 1:00  | 0.15        | 4589                  | 99.3                | 163            | 105.9         | 285               | 5250          | 112           |
| 2011/3/15 1:30  | 0.14        | 4589                  | 97.2                | 160            | 104.1         | 282               | 5250          | 111           |
| 2011/3/15 2:00  | 0.13        | 4589                  | 96.0                | 157            | 102.5         | 279               | 5250          | 110           |
| 2011/3/15 2:30  | 0.12        | 4589                  | 95.4                | 154            | 101.8         | 276               | 5250          | 108           |
| 2011/3/15 3:00  | 0.1         | 4589                  | 95.0                | 152            | 101.4         | 273               | 5200          | 107           |
| 2011/3/15 3:30  | 0.09        | 4589                  | 94.8                | 149            | 100.9         | 270               | 5250          | 106           |
| 2011/3/15 4:00  | 0.07        | 4589                  | 94.8                | 146            | 100.2         | 268               | 5250          | 104           |
| 2011/3/15 4:30  | 0.09        | 4589                  | 94.8                | 144            | 99.6          | 265               | 5200          | 103           |
| 2011/3/15 5:00  | 0.08        | 4589                  | 94.3                | 142            | 98.9          | 263               | 5250          | 102           |
| 2011/3/15 5:30  | 0.08        | 4589                  | 93.8                | 140            | 98.6          | 261               | 5200          | 101           |
| 2011/3/15 6:00  | 0.09        | 4589                  | 93.2                | 137            | 97.9          | 258               | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                  | 91.3                | 134            | 97.3          | 255               | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                  | 90.3                | 133            | 97            | 254               | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                  | 89.4                | 131            | 96.8          | 252               | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                  | 88.6                | 130            | 96.4          | 250               | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                  | 88.2                | 128            | 96.3          | 249               | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                  | 87.2                | 127            | 96            | 247               | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                  | 86.5                | 125            | 95.7          | 245               | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                  | 85.9                | 123            | 95.5          | 243               | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                  | 85.3                | 121            | 95.2          | 241               | 5200          | 93            |
| 2011/3/15 11:00 | 0.09        | 4589                  | 84.6                | 119            | 94.8          | 240               | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                  | 84.1                | 117            | 94.6          | 237               | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                  | 82.6                | 114            | 94            | 234               | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                  | 80.0                | 111            | 93.5          | 231               | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                  | 78.6                | 109            | 93            | 229               | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                  | 77.4                | 107            | 92.5          | 227               | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                  | 76.1                | 104            | 92.2          | 224               | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                  | 75.1                | 102            | 91.9          | 222               | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                  | 74.1                | 101            | 91.6          | 220               | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                  | 73.2                | 99             | 91.4          | 218               | 5150          | 82            |
| 2011/3/15 16:00 | 0.09        | 4589                  | 72.4                | 97             | 91.2          | 217               | 5150          | 82            |

2F-1号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|----------------|------------|------------|
| 2011/3/15 0:00  | 0.07     | 4589     |                     | 90                 | 132         | 94.8       | 264            | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                     | 90                 | 130         | 94.1       | 263            | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                     | 90                 | 128         | 93.8       | 261            | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                     | 90                 | 127         | 93.2       | 260            | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                     | 90                 | 126         | 92.9       | 259            | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                     | 86                 | 125         | 92.3       | 258            | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                     | 86                 | 124         | 92.1       | 257            | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                     | 86                 | 122         | 91.5       | 255            | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                     | 86                 | 121         | 91.1       | 254            | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                     | 86                 | 120         | 90.8       | 253            | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                     | 86                 | 119         | 90.2       | 252            | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                     | 97                 | 117         | 89.9       | 250            | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250            | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249            | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                     | 86                 | 116         | 88.8       | 248            | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247            | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246            | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245            | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244            | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244            | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242            | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241            | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239            | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233            | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71                  | 116                | 101         | 85.7       | 230            | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227            | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 68                  | 108                | 97          | 85.0       | 226            | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67                  | 116                | 94          | 84.5       | 223            | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66                  | 108                | 92          | 84.0       | 220            | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 66                  | 110                | 89          | 83.7       | 218            | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65                  | 108                | 89          | 83.3       | 215            | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 65                  | 108                | 86          | 83         | 213            | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 65                  | 76                 | 88          | 83         | 216            | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                | 97                 | 88          | 82.5       | 215            | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                | 117                | 85          | 82         | 212            | 4752       | 48         |

777セト  
水位計

停止時  
水位計

777セト  
水位計

2F-2号機

| 時間              | 炉圧 (Mpa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPaabs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|----------------|------------|------------|
| 2011/3/15 0:00  | 0.05     | 4151     |                     | 84                | 108.1       | 97.2       | 227            | 5150       | 64         |
| 2011/3/15 0:30  | 0.05     | 4154     |                     | 84                | 106.9       | 96.6       | 225            | 5150       | 62         |
| 2011/3/15 1:00  | 0.05     | 4154     |                     | 84                | 104.3       | 96.2       | 224            | 5150       | 61         |
| 2011/3/15 1:30  | 0.05     | 4154     |                     | 84                | 103.1       | 95.9       | 222            | 5150       | 60         |
| 2011/3/15 2:00  | 0.05     | 4154     |                     | 84                | 101.5       | 95.4       | 221            | 5150       | 59         |
| 2011/3/15 2:30  | 0.05     | 4154     |                     | 84                | 99.9        | 95.1       | 219            | 5100       | 58         |
| 2011/3/15 3:00  | 0.05     | 4157     |                     | 84                | 98.4        | 94.7       | 218            | 5100       | 57         |
| 2011/3/15 3:30  | 0.05     | 4157     |                     | 84                | 97.1        | 94.4       | 216            | 5100       | 56         |
| 2011/3/15 4:00  | 0.05     | 4157     |                     | 84                | 95.6        | 93.9       | 215            | 5100       | 55         |
| 2011/3/15 4:30  | 0.05     | 4160     |                     | 84                | 94.6        | 93.6       | 214            | 5100       | 54         |
| 2011/3/15 5:00  | 0.05     | 4160     |                     | 84                | 93.1        | 93.1       | 212            | 5100       | 53         |
| 2011/3/15 5:30  | 0.06     | 4160     |                     | 86                | 91.8        | 92.7       | 211            | 5100       | 52         |
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210            | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209            | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208            | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207            | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206            | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205            | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204            | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203            | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202            | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     |                     | 86                | 83.1        | 89.9       | 202            | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     |                     | 86                | 83.4        | 89.7       | 201            | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     |                     | 86                | 81.8        | 89.7       | 201            | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     |                     | 82                | 82.2        | 89.3       | 200            | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     |                     | 82                | 80.3        | 88.9       | 199            | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     |                     | 69                | 80.0        | 88.6       | 198            | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     |                     | 69                | 78.8        | 88.3       | 197            | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     |                     | 69                | 77.5        | 87.9       | 195            | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     |                     | 69                | 75.6        | 87.6       | 194            | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     |                     | 65                | 75.6        | 87.2       | 193            | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     |                     | 73                | 74          | 87         | 193            | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     |                     | 66                | 74          | 87         | 192            | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     |                     | 74                | 73.4        | 86.3       | 191            | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     | 64.6                | 69                | 72.5        | 86         | 191            | 5000       | 40         |

炉外  
水位計

停止時  
水位計

炉外  
水位計

2F-3号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>アンプ外 | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|---------------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | -0.06       | 3434                | 30.7                | 31             | 59.8          | 132               | 599           | 45            |
| 2011/3/15 0:30  | -0.06       | 3466                | 30.6                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:00  | -0.06       | 3448                | 30.5                | 31             | 59.7          | 132               | 599           | 45            |
| 2011/3/15 1:30  | -0.06       | 3442                | 30.5                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:00  | -0.06       | 3430                | 30.4                | 32             | 59.7          | 132               | 598           | 45            |
| 2011/3/15 2:30  | -0.06       | 3444                | 30.4                | 31             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:00  | -0.06       | 3437                | 30.3                | 32             | 59.7          | 133               | 599           | 45            |
| 2011/3/15 3:30  | -0.03       | 3000                | 30.3                | 31             | 59.5          | 132               | 595           | 45            |
| 2011/3/15 4:00  | 0.03        | 3375                | 30.3                | 31             | 59.5          | 132               | 599           | 45            |
| 2011/3/15 4:30  | 0.04        | 3382                | 30.1                | 31             | 59.5          | 132               | 599           | 44            |
| 2011/3/15 5:00  | 0.04        | 3381                | 30.1                | 31             | 59.4          | 132               | 598           | 44            |
| 2011/3/15 5:30  | 0.03        | 3378                | 30.0                | 31             | 59.4          | 132               | 599           | 44            |
| 2011/3/15 6:00  | 0.04        | 3378                | 29.9                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                | 29.8                | 31             | 59.3          | 132               | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                | 29.8                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                | 29.7                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                | 29.6                | 31             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                | 29.6                | 31             | 59.2          | 132               | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                | 29.6                | 32             | 59.1          | 132               | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                | 29.5                | 32             | 59.1          | 132               | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                | 29.4                | 31             | 59.0          | 132               | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                | 29.4                | 32             | 59.0          | 132               | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                | 29.3                | 32             | 59.0          | 132               | 598           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                | 29.3                | 32             | 58.8          | 132               | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                | 29.2                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                | 29.1                | 32             | 58.7          | 133               | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                | 29.1                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                | 29.0                | 32             | 58.7          | 133               | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                | 29.0                | 32             | 58.8          | 133               | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                | 28.9                | 32             | 58.7          | 133               | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                | 26.9                | 33             | 58.7          | 133               | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                | 26.9                | 33             | 58.5          | 133               | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                | 28.8                | 33             | 58.5          | 133               | 598           | 44            |

2F-4号機

| 時間              | 炉圧<br>(Mpa) | 炉水位<br>(mm)<br>アツクセ | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPaabs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|---------------------|---------------------|----------------|---------------|-------------------|---------------|---------------|
| 2011/3/15 0:00  | 0.18        | 4589                | 108.6               | 169            | 111.2         | 291               | 5300          | 112           |
| 2011/3/15 0:30  | 0.18        | 4589                | 104.7               | 166            | 108.9         | 288               | 5200          | 110           |
| 2011/3/15 1:00  | 0.15        | 4589                | 99.3                | 163            | 105.9         | 285               | 5250          | 112           |
| 2011/3/15 1:30  | 0.14        | 4589                | 97.2                | 160            | 104.1         | 282               | 5250          | 111           |
| 2011/3/15 2:00  | 0.13        | 4589                | 96.0                | 157            | 102.5         | 279               | 5250          | 110           |
| 2011/3/15 2:30  | 0.12        | 4589                | 95.4                | 154            | 101.8         | 276               | 5250          | 108           |
| 2011/3/15 3:00  | 0.1         | 4589                | 95.0                | 152            | 101.4         | 273               | 5200          | 107           |
| 2011/3/15 3:30  | 0.09        | 4589                | 94.8                | 149            | 100.9         | 270               | 5250          | 106           |
| 2011/3/15 4:00  | 0.07        | 4589                | 94.8                | 146            | 100.2         | 268               | 5250          | 104           |
| 2011/3/15 4:30  | 0.09        | 4589                | 94.8                | 144            | 99.6          | 265               | 5200          | 103           |
| 2011/3/15 5:00  | 0.08        | 4589                | 94.3                | 142            | 98.9          | 263               | 5250          | 102           |
| 2011/3/15 5:30  | 0.08        | 4589                | 93.8                | 140            | 98.6          | 261               | 5200          | 101           |
| 2011/3/15 6:00  | 0.09        | 4589                | 93.2                | 137            | 97.9          | 258               | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                | 91.3                | 134            | 97.3          | 255               | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                | 90.3                | 133            | 97            | 254               | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                | 89.4                | 131            | 96.8          | 252               | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                | 88.6                | 130            | 96.4          | 250               | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                | 88.2                | 128            | 96.3          | 249               | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                | 87.2                | 127            | 96            | 247               | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                | 86.5                | 125            | 95.7          | 245               | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                | 85.9                | 123            | 95.5          | 243               | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                | 85.3                | 121            | 95.2          | 241               | 5200          | 93            |
| 2011/3/15 11:00 | 0.09        | 4589                | 84.6                | 119            | 94.8          | 240               | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                | 84.1                | 117            | 94.6          | 237               | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                | 82.6                | 114            | 94            | 234               | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                | 80.0                | 111            | 93.5          | 231               | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                | 78.6                | 109            | 93            | 229               | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                | 77.4                | 107            | 92.5          | 227               | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                | 76.1                | 104            | 92.2          | 224               | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                | 75.1                | 102            | 91.9          | 222               | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                | 74.1                | 101            | 91.6          | 220               | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                | 73.2                | 99             | 91.4          | 218               | 5150          | 82            |
| 2011/3/15 16:00 | 0.09        | 4589                | 72.4                | 97             | 91.2          | 217               | 5150          | 82            |
| 2011/3/15 16:30 | 0.1         | 4589                | 71.7                | 96             | 90.9          | 215               | 5100          | 81            |
| 2011/3/15 17:00 | 0.1         | 4589                | 70.7                | 94             | 90.6          | 213               | 5100          | 79            |



2F 7032K (7X-A) (17:30)

1/4

2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 0:00  | 0.07     | 4589     |                     | 90                 | 132         | 94.8       | 264             | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                     | 90                 | 130         | 94.1       | 263             | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                     | 90                 | 128         | 93.8       | 261             | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                     | 90                 | 127         | 93.2       | 260             | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                     | 90                 | 126         | 92.9       | 259             | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                     | 86                 | 125         | 92.3       | 258             | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                     | 86                 | 124         | 92.1       | 257             | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                     | 86                 | 122         | 91.5       | 255             | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                     | 86                 | 121         | 91.1       | 254             | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                     | 86                 | 120         | 90.8       | 253             | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                     | 86                 | 119         | 90.2       | 252             | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                     | 97                 | 117         | 89.9       | 250             | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                     | 86                 | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.5       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71                  | 116                | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 68                  | 103                | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67                  | 116                | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66                  | 108                | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 66                  | 110                | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65                  | 108                | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 65                  | 108                | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 65                  | 76                 | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                | 97                 | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                | 117                | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 66.7                | 120                | 84          | 81.9       | 210             | 4496       | 48         |

707セト  
水位計

停止時  
水位計

707セト  
水位計

2/4

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 0:00  | 0.05     | 4151     |                     | 84                | 108.1       | 97.2       | 227             | 5150       | 64         |
| 2011/3/15 0:30  | 0.05     | 4154     |                     | 84                | 106.9       | 96.6       | 225             | 5150       | 62         |
| 2011/3/15 1:00  | 0.05     | 4154     |                     | 84                | 104.3       | 96.2       | 224             | 5150       | 61         |
| 2011/3/15 1:30  | 0.05     | 4154     |                     | 84                | 103.1       | 95.9       | 222             | 5150       | 60         |
| 2011/3/15 2:00  | 0.05     | 4154     |                     | 84                | 101.5       | 95.4       | 221             | 5150       | 59         |
| 2011/3/15 2:30  | 0.05     | 4154     |                     | 84                | 99.9        | 95.1       | 219             | 5100       | 58         |
| 2011/3/15 3:00  | 0.05     | 4157     |                     | 84                | 98.4        | 94.7       | 218             | 5100       | 57         |
| 2011/3/15 3:30  | 0.05     | 4157     |                     | 84                | 97.1        | 94.4       | 216             | 5100       | 56         |
| 2011/3/15 4:00  | 0.05     | 4157     |                     | 84                | 95.6        | 93.9       | 215             | 5100       | 55         |
| 2011/3/15 4:30  | 0.05     | 4160     |                     | 84                | 94.6        | 93.6       | 214             | 5100       | 54         |
| 2011/3/15 5:00  | 0.05     | 4160     |                     | 84                | 93.1        | 93.1       | 212             | 5100       | 53         |
| 2011/3/15 5:30  | 0.06     | 4160     |                     | 86                | 91.8        | 92.7       | 211             | 5100       | 52         |
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     |                     | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     |                     | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     |                     | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     |                     | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     |                     | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     |                     | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     |                     | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     |                     | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     |                     | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     |                     | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     |                     | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     |                     | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     |                     | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     |                     | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     |                     | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |

アッパセト  
水位計

停止時  
水位計

アッパセト  
水位計

3/4

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アツアセト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 0:00  | -0.06       | 3434                 | 30.7                | 31             | 59.8          | 132                | 599           | 45            |
| 2011/3/15 0:30  | -0.06       | 3466                 | 30.6                | 31             | 59.7          | 132                | 599           | 45            |
| 2011/3/15 1:00  | -0.06       | 3448                 | 30.5                | 31             | 59.7          | 132                | 599           | 45            |
| 2011/3/15 1:30  | -0.06       | 3442                 | 30.5                | 32             | 59.7          | 132                | 598           | 45            |
| 2011/3/15 2:00  | -0.06       | 3430                 | 30.4                | 32             | 59.7          | 132                | 598           | 45            |
| 2011/3/15 2:30  | -0.06       | 3444                 | 30.4                | 31             | 59.7          | 133                | 599           | 45            |
| 2011/3/15 3:00  | -0.06       | 3437                 | 30.3                | 32             | 59.7          | 133                | 599           | 45            |
| 2011/3/15 3:30  | -0.03       | 3000                 | 30.3                | 31             | 59.5          | 132                | 595           | 45            |
| 2011/3/15 4:00  | 0.03        | 3375                 | 30.3                | 31             | 59.5          | 132                | 599           | 45            |
| 2011/3/15 4:30  | 0.04        | 3382                 | 30.1                | 31             | 59.5          | 132                | 599           | 44            |
| 2011/3/15 5:00  | 0.04        | 3381                 | 30.1                | 31             | 59.4          | 132                | 598           | 44            |
| 2011/3/15 5:30  | 0.03        | 3378                 | 30.0                | 31             | 59.4          | 132                | 599           | 44            |
| 2011/3/15 6:00  | 0.04        | 3378                 | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                 | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                 | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                 | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                 | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                 | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                 | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                 | 29.5                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                 | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                 | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                 | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                 | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                 | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                 | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                 | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                 | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                 | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                 | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                 | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                 | 28.9                | 32             | 58.7          | 133                | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                 | 26.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                 | 26.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                 | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                 | 28.8                | 33             | 58.6          | 133                | 597           | 44            |

4/4

2F-4号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) アップセット | 炉水温度(°C) 給水ノズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|-----------------|------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 0:00  | 0.18     | 4589            | 108.6            | 169         | 111.2      | 291             | 5300       | 112        |
| 2011/3/15 0:30  | 0.18     | 4589            | 104.7            | 166         | 108.9      | 288             | 5200       | 110        |
| 2011/3/15 1:00  | 0.15     | 4589            | 99.3             | 163         | 105.9      | 285             | 5250       | 112        |
| 2011/3/15 1:30  | 0.14     | 4589            | 97.2             | 160         | 104.1      | 282             | 5250       | 111        |
| 2011/3/15 2:00  | 0.13     | 4589            | 96.0             | 157         | 102.5      | 279             | 5250       | 110        |
| 2011/3/15 2:30  | 0.12     | 4589            | 95.4             | 154         | 101.8      | 276             | 5250       | 108        |
| 2011/3/15 3:00  | 0.1      | 4589            | 95.0             | 152         | 101.4      | 273             | 5200       | 107        |
| 2011/3/15 3:30  | 0.09     | 4589            | 94.8             | 149         | 100.9      | 270             | 5250       | 106        |
| 2011/3/15 4:00  | 0.07     | 4589            | 94.8             | 146         | 100.2      | 268             | 5250       | 104        |
| 2011/3/15 4:30  | 0.09     | 4589            | 94.8             | 144         | 99.6       | 265             | 5200       | 103        |
| 2011/3/15 5:00  | 0.08     | 4589            | 94.3             | 142         | 98.9       | 263             | 5250       | 102        |
| 2011/3/15 5:30  | 0.08     | 4589            | 93.8             | 140         | 98.6       | 261             | 5200       | 101        |
| 2011/3/15 6:00  | 0.09     | 4589            | 93.2             | 137         | 97.9       | 258             | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589            | 91.3             | 134         | 97.3       | 255             | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589            | 90.3             | 133         | 97         | 254             | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589            | 89.4             | 131         | 96.8       | 252             | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589            | 88.6             | 130         | 96.4       | 250             | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589            | 88.2             | 128         | 96.3       | 249             | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589            | 87.2             | 127         | 96         | 247             | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589            | 86.5             | 125         | 95.7       | 245             | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589            | 85.9             | 123         | 95.5       | 243             | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589            | 85.3             | 121         | 95.2       | 241             | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589            | 84.6             | 119         | 94.8       | 240             | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589            | 84.1             | 117         | 94.6       | 237             | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589            | 82.6             | 114         | 94         | 234             | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589            | 80.0             | 111         | 93.5       | 231             | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589            | 78.6             | 109         | 93         | 229             | 5150       | 88         |
| 2011/3/15 13:30 | 0.1      | 4589            | 77.4             | 107         | 92.5       | 227             | 5150       | 87         |
| 2011/3/15 14:00 | 0.1      | 4589            | 76.1             | 104         | 92.2       | 224             | 5150       | 86         |
| 2011/3/15 14:30 | 0.1      | 4589            | 75.1             | 102         | 91.9       | 222             | 5150       | 85         |
| 2011/3/15 15:00 | 0.1      | 4589            | 74.1             | 101         | 91.6       | 220             | 5200       | 84         |
| 2011/3/15 15:30 | 0.1      | 4589            | 73.2             | 99          | 91.4       | 218             | 5150       | 82         |
| 2011/3/15 16:00 | 0.09     | 4589            | 72.4             | 97          | 91.2       | 217             | 5150       | 82         |
| 2011/3/15 16:30 | 0.1      | 4589            | 71.7             | 96          | 90.9       | 215             | 5100       | 81         |
| 2011/3/15 17:00 | 0.1      | 4589            | 70.7             | 94          | 90.6       | 213             | 5100       | 79         |
| 2011/3/15 17:30 | 0.1      | 4589            | 70.3             | 93          | 90.4       | 212             | 5050       | 78         |

2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度 (°C)<br>給水ノズル温度 | 炉水温度 (°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|----------------------|---------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 0:00  | 0.07     | 4589     |                      | 90                  | 132         | 94.8       | 264             | 5796       | 69         |
| 2011/3/15 0:30  | 0.07     | 4589     |                      | 90                  | 130         | 94.1       | 263             | 5797       | 67         |
| 2011/3/15 1:00  | 0.07     | 4589     |                      | 90                  | 128         | 93.8       | 261             | 5801       | 66         |
| 2011/3/15 1:30  | 0.07     | 4589     |                      | 90                  | 127         | 93.2       | 260             | 5804       | 66         |
| 2011/3/15 2:00  | 0.07     | 4589     |                      | 90                  | 126         | 92.9       | 259             | 5809       | 65         |
| 2011/3/15 2:30  | 0.06     | 4519     |                      | 86                  | 125         | 92.3       | 258             | 5811       | 66         |
| 2011/3/15 3:00  | 0.06     | 4463     |                      | 86                  | 124         | 92.1       | 257             | 5812       | 66         |
| 2011/3/15 3:30  | 0.06     | 4392     |                      | 86                  | 122         | 91.5       | 255             | 5814       | 65         |
| 2011/3/15 4:00  | 0.06     | 4418     |                      | 86                  | 121         | 91.1       | 254             | 5812       | 62         |
| 2011/3/15 4:30  | 0.06     | 4404     |                      | 86                  | 120         | 90.8       | 253             | 5810       | 61         |
| 2011/3/15 5:00  | 0.06     | 4357     |                      | 86                  | 119         | 90.2       | 252             | 5814       | 60         |
| 2011/3/15 5:30  | 0.09     | 4586     |                      | 97                  | 117         | 89.9       | 250             | 5769       | 60         |
| 2011/3/15 6:00  | 0.06     | 4488     |                      | 86                  | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                      | 86                  | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.08     | 4465     |                      | 86                  | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                      | 86                  | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                      | 86                  | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                      | 86                  | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.08     | 4336     |                      | 86                  | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                      | 86                  | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                   | 97                  | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                   | 103                 | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                   | 110                 | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                   | 122                 | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71                   | 116                 | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                   | 108                 | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 68                   | 108                 | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67                   | 116                 | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66                   | 108                 | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 66                   | 110                 | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65                   | 108                 | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 65                   | 108                 | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 65                   | 76                  | 88          | 83         | 216             | 4982       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                 | 97                  | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                 | 117                 | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 66.7                 | 120                 | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4586     | 64.4                 | 108                 | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     | 62.9                 | 103                 | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     | 62.2                 | 103                 | 80          | 80.8       | 205             | 4300       | 46         |

アップセト  
水位計

停止時  
水位計

777セト  
水位計

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 0:00  | 0.05     | 4151     |                     | 84                | 108.1       | 97.2       | 227             | 5150       | 64         |
| 2011/3/15 0:30  | 0.05     | 4154     |                     | 84                | 106.9       | 96.6       | 225             | 5150       | 62         |
| 2011/3/15 1:00  | 0.05     | 4154     |                     | 84                | 104.3       | 96.2       | 224             | 5150       | 61         |
| 2011/3/15 1:30  | 0.05     | 4154     |                     | 84                | 103.1       | 95.9       | 222             | 5150       | 60         |
| 2011/3/15 2:00  | 0.05     | 4154     |                     | 84                | 101.5       | 95.4       | 221             | 5150       | 59         |
| 2011/3/15 2:30  | 0.05     | 4154     |                     | 84                | 99.9        | 95.1       | 219             | 5100       | 58         |
| 2011/3/15 3:00  | 0.05     | 4157     |                     | 84                | 98.4        | 94.7       | 218             | 5100       | 57         |
| 2011/3/15 3:30  | 0.05     | 4157     |                     | 84                | 97.1        | 94.4       | 216             | 5100       | 56         |
| 2011/3/15 4:00  | 0.05     | 4157     |                     | 84                | 95.6        | 93.9       | 215             | 5100       | 55         |
| 2011/3/15 4:30  | 0.05     | 4160     |                     | 84                | 94.6        | 93.6       | 214             | 5100       | 54         |
| 2011/3/15 5:00  | 0.05     | 4160     |                     | 84                | 93.1        | 93.1       | 212             | 5100       | 53         |
| 2011/3/15 5:30  | 0.06     | 4160     |                     | 86                | 91.8        | 92.7       | 211             | 5100       | 52         |
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 70                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     |                     | 70                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     |                     | 69                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     |                     | 69                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     |                     | 69                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     |                     | 70                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     |                     | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     |                     | 71                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     |                     | 67                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     |                     | 72                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     |                     | 65                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     |                     | 73                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     |                     | 66                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     |                     | 74                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     |                     | 64.6              | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     |                     | 75                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     |                     | 64.9              | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     |                     | 76                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     |                     | 64                | 68.8        | 84.9       | 184             | 4800       | 39         |

アブソリュート  
水位計

停止時  
水位計

アブソリュート  
水位計

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>777セット | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 0:00  | -0.06       | 3434                  | 30.7                | 31             | 59.8          | 132                | 599           | 45            |
| 2011/3/15 0:30  | -0.06       | 3466                  | 30.6                | 31             | 59.7          | 132                | 599           | 45            |
| 2011/3/15 1:00  | -0.06       | 3448                  | 30.5                | 31             | 59.7          | 132                | 599           | 45            |
| 2011/3/15 1:30  | -0.06       | 3442                  | 30.5                | 32             | 59.7          | 132                | 598           | 45            |
| 2011/3/15 2:00  | -0.06       | 3430                  | 30.4                | 32             | 59.7          | 132                | 598           | 45            |
| 2011/3/15 2:30  | -0.06       | 3444                  | 30.4                | 31             | 59.7          | 133                | 599           | 45            |
| 2011/3/15 3:00  | -0.06       | 3437                  | 30.3                | 32             | 59.7          | 133                | 599           | 45            |
| 2011/3/15 3:30  | -0.03       | 3000                  | 30.3                | 31             | 59.5          | 132                | 595           | 45            |
| 2011/3/15 4:00  | 0.03        | 3375                  | 30.3                | 31             | 59.5          | 132                | 599           | 45            |
| 2011/3/15 4:30  | 0.04        | 3382                  | 30.1                | 31             | 59.5          | 132                | 599           | 44            |
| 2011/3/15 5:00  | 0.04        | 3381                  | 30.1                | 31             | 59.4          | 132                | 598           | 44            |
| 2011/3/15 5:30  | 0.03        | 3378                  | 30.0                | 31             | 59.4          | 132                | 599           | 44            |
| 2011/3/15 6:00  | 0.04        | 3378                  | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                  | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                  | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                  | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                  | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                  | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                  | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                  | 29.5                | 32             | 59.1          | 132                | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                  | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                  | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                  | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                  | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                  | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                  | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                  | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                  | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                  | 28.9                | 32             | 58.7          | 133                | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                  | 26.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                  | 26.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                  | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                  | 28.8                | 33             | 58.6          | 133                | 597           | 44            |
| 2011/3/15 18:00 | 0.04        | 3362                  | 28.8                | 33             | 58.4          | 133                | 599           | 44            |
| 2011/3/15 18:30 | 0.04        | 3364                  | 29.1                | 33             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 19:00 | 0.04        | 3362                  | 29.2                | 33             | 58.4          | 134                | 598           | 44            |

2F-4号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アツクセ | 炉水温度(°C)<br>給水/ズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|---------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 0:00  | 0.18        | 4589                | 108.6               | 169            | 111.2         | 291                | 5300          | 112           |
| 2011/3/15 0:30  | 0.18        | 4589                | 104.7               | 166            | 108.9         | 288                | 5200          | 110           |
| 2011/3/15 1:00  | 0.15        | 4589                | 99.3                | 163            | 105.9         | 285                | 5250          | 112           |
| 2011/3/15 1:30  | 0.14        | 4589                | 97.2                | 160            | 104.1         | 282                | 5250          | 111           |
| 2011/3/15 2:00  | 0.13        | 4589                | 96.0                | 157            | 102.5         | 279                | 5250          | 110           |
| 2011/3/15 2:30  | 0.12        | 4589                | 95.4                | 154            | 101.8         | 276                | 5250          | 108           |
| 2011/3/15 3:00  | 0.1         | 4589                | 95.0                | 152            | 101.4         | 273                | 5200          | 107           |
| 2011/3/15 3:30  | 0.09        | 4589                | 94.8                | 149            | 100.9         | 270                | 5250          | 106           |
| 2011/3/15 4:00  | 0.07        | 4589                | 94.8                | 146            | 100.2         | 268                | 5250          | 104           |
| 2011/3/15 4:30  | 0.09        | 4589                | 94.8                | 144            | 99.6          | 265                | 5200          | 103           |
| 2011/3/15 5:00  | 0.08        | 4589                | 94.3                | 142            | 98.9          | 263                | 5250          | 102           |
| 2011/3/15 5:30  | 0.08        | 4589                | 93.8                | 140            | 98.6          | 261                | 5200          | 101           |
| 2011/3/15 6:00  | 0.09        | 4589                | 93.2                | 137            | 97.9          | 258                | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                | 91.3                | 134            | 97.3          | 255                | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                | 90.3                | 133            | 97            | 254                | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                | 89.4                | 131            | 96.8          | 252                | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                | 88.6                | 130            | 96.4          | 250                | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                | 88.2                | 128            | 96.3          | 249                | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                | 87.2                | 127            | 96            | 247                | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                | 86.5                | 125            | 95.7          | 245                | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                | 85.9                | 123            | 95.5          | 243                | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                | 85.3                | 121            | 95.2          | 241                | 5200          | 93            |
| 2011/3/15 11:00 | 0.09        | 4589                | 84.6                | 119            | 94.8          | 240                | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                | 84.1                | 117            | 94.6          | 237                | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                | 82.6                | 114            | 94            | 234                | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                | 80.0                | 111            | 93.5          | 231                | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                | 78.6                | 109            | 93            | 229                | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                | 77.4                | 107            | 92.5          | 227                | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                | 76.1                | 104            | 92.2          | 224                | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                | 75.1                | 102            | 91.9          | 222                | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                | 74.1                | 101            | 91.6          | 220                | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                | 73.2                | 99             | 91.4          | 218                | 5150          | 82            |
| 2011/3/15 16:00 | 0.09        | 4589                | 72.4                | 97             | 91.2          | 217                | 5150          | 82            |
| 2011/3/15 16:30 | 0.1         | 4589                | 71.7                | 96             | 90.9          | 215                | 5100          | 81            |
| 2011/3/15 17:00 | 0.1         | 4589                | 70.7                | 94             | 90.6          | 213                | 5100          | 79            |
| 2011/3/15 17:30 | 0.1         | 4589                | 70.3                | 93             | 90.4          | 212                | 5050          | 78            |
| 2011/3/15 18:00 | 0.1         | 4589                | 69.7                | 92             | 90.1          | 211                | 5150          | 77            |
| 2011/3/15 18:30 | 0.1         | 4589                | 69.0                | 90             | 89.8          | 209                | 5150          | 76            |
| 2011/3/15 19:00 | 0.1         | 4589                | 68.5                | 89             | 89.5          | 208                | 5150          | 75            |



2F 70分特. 07X-A (20:00) 2F-1号機

2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度 (°C)<br>給水ノズル温度 | 炉水温度 (°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|----------------------|---------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4488     |                      | 86                  | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                      | 86                  | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                      | 86                  | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                      | 86                  | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                      | 86                  | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                      | 86                  | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                      | 86                  | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                      | 86                  | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     |                      | 97                  | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     |                      | 103                 | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     |                      | 110                 | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     |                      | 122                 | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 停止時<br>水位計           | 116                 | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     |                      | 108                 | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     |                      | 108                 | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     |                      | 116                 | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     |                      | 108                 | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     |                      | 110                 | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     |                      | 108                 | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     |                      | 108                 | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     |                      | 76                  | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     |                      | 97                  | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     |                      | 117                 | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     |                      | 120                 | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4586     |                      | 108                 | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     |                      | 103                 | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     |                      | 103                 | 80          | 80.8       | 205             | 4300       | 46         |
| 2011/3/15 19:30 | 0.12     | 4586     |                      | 103                 | 78          | 80.5       | 203             | 4212       | 46         |
| 2011/3/15 20:00 | 0.13     | 6600     |                      | 61.3                | 77          | 80.3       | 201             | 4126       | 46         |
| 2011/3/15 20:30 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/15 21:00 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/15 21:30 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/15 22:00 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                      |                     |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                      |                     |             |            |                 |            |            |

70分特  
水位計

停止時  
水位計

70分特  
水位計

停止時  
水位計

2/4

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     | 70                  | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     | 69                  | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     | 69                  | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     | 68.7                | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     | 70                  | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     | 68.9                | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     | 67.7                | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     | 66.5                | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     | 65.6                | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     | 65.4                | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     | 64.9                | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     | 65.6                | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     | 65.1                | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     | 64.6                | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     | 64.5                | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     | 64.9                | 69                | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     | 64.9                | 69                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     | 64                  | 82                | 68.8        | 84.9       | 184             | 4800       | 39         |
| 2011/3/15 19:30 | 0.2      | 7400     | 59.6                |                   | 65.9        | 84.6       | 179             | 4600       | 38         |
| 2011/3/15 20:00 | 0.1      | 7000     | 60.8                |                   | 64.7        | 84.1       | 178             | 4500       | 38         |
| 2011/3/15 20:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 21:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 21:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                   |             |            |                 |            |            |

アッパセト  
水位計

アッパセト  
水位計

停止時  
水位計



9/4

2F-4号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アツクセト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.09        | 4589                 | 93.2                | 137            | 97.9          | 258                | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                 | 91.3                | 134            | 97.3          | 255                | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                 | 90.3                | 133            | 97            | 254                | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                 | 89.4                | 131            | 96.8          | 252                | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                 | 88.6                | 130            | 96.4          | 250                | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                 | 88.2                | 128            | 96.3          | 249                | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                 | 87.2                | 127            | 96            | 247                | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                 | 86.5                | 125            | 95.7          | 245                | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                 | 85.9                | 123            | 95.5          | 243                | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                 | 85.3                | 121            | 95.2          | 241                | 5200          | 93            |
| 2011/3/15 11:00 | 0.09        | 4589                 | 84.6                | 119            | 94.8          | 240                | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                 | 84.1                | 117            | 94.6          | 237                | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                 | 82.6                | 114            | 94            | 234                | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                 | 80.0                | 111            | 93.5          | 231                | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                 | 78.6                | 109            | 93            | 229                | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                 | 77.4                | 107            | 92.5          | 227                | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                 | 76.1                | 104            | 92.2          | 224                | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                 | 75.1                | 102            | 91.9          | 222                | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                 | 74.1                | 101            | 91.6          | 220                | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                 | 73.2                | 99             | 91.4          | 218                | 5150          | 82            |
| 2011/3/15 16:00 | 0.09        | 4589                 | 72.4                | 97             | 91.2          | 217                | 5150          | 82            |
| 2011/3/15 16:30 | 0.1         | 4589                 | 71.7                | 96             | 90.9          | 215                | 5100          | 81            |
| 2011/3/15 17:00 | 0.1         | 4589                 | 70.7                | 94             | 90.6          | 213                | 5100          | 79            |
| 2011/3/15 17:30 | 0.1         | 4589                 | 70.3                | 93             | 90.4          | 212                | 5050          | 78            |
| 2011/3/15 18:00 | 0.1         | 4589                 | 69.7                | 92             | 90.1          | 211                | 5150          | 77            |
| 2011/3/15 18:30 | 0.1         | 4589                 | 69.0                | 90             | 89.8          | 209                | 5150          | 76            |
| 2011/3/15 19:00 | 0.1         | 4589                 | 68.5                | 89             | 89.5          | 208                | 5150          | 75            |
| 2011/3/15 19:30 | 0.1         | 4589                 | 67.8                | 88             | 89.3          | 207                | 5100          | 75            |
| 2011/3/15 20:00 | 0.1         | 4589                 | 67.1                | 87             | 89            | 206                | 5050          | 74            |
| 2011/3/15 20:30 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 21:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 21:30 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 22:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 22:30 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 23:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 23:30 |             |                      |                     |                |               |                    |               |               |

2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/G圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4488     | 86                  | 86                 | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     | 86                  | 86                 | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     | 86                  | 86                 | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     | 86                  | 86                 | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     | 86                  | 86                 | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     | 86                  | 86                 | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     | 86                  | 86                 | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     | 86                  | 86                 | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 97                  | 97                 | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 103                 | 103                | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 110                 | 110                | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 122                 | 122                | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 116                 | 116                | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 108                 | 108                | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 108                 | 108                | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 116                 | 116                | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 108                 | 108                | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 110                 | 110                | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 108                 | 108                | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 108                 | 108                | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 76                  | 76                 | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 97                  | 97                 | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 117                 | 117                | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 120                 | 120                | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4586     | 108                 | 108                | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     | 103                 | 103                | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     | 103                 | 103                | 80          | 80.8       | 205             | 4300       | 46         |
| 2011/3/15 19:30 | 0.12     | 4586     | 61.7                | 61.7               | 78          | 80.5       | 203             | 4212       | 46         |
| 2011/3/15 20:00 | 0.13     | 6600     | 61.3                | 61.3               | 77          | 80.3       | 201             | 4126       | 46         |
| 2011/3/15 20:30 | 0.12     | 7000     | 61                  | 61                 | 74          | 79.9       | 199             | 4013       | 46         |
| 2011/3/15 21:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 21:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 22:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                    |             |            |                 |            |            |

7:07セト  
水位計

停止時  
水位計

7:07セト  
水位計

停止時  
水位計

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     | 70                  | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     | 70                  | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     | 69                  | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     | 68.7                | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     | 70                  | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     | 68.9                | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     | 67.7                | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     | 66.5                | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     | 85.6                | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     | 85.4                | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     | 64.9                | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     | 65.6                | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     | 65.1                | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     | 64.6                | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     | 64.5                | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     | 64.9                | 69                | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     | 64.9                | 69                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     | 64                  | 82                | 68.8        | 84.9       | 184             | 4800       | 39         |
| 2011/3/15 19:30 | 0.2      | 7400     | 59.6                | -                 | 65.9        | 84.6       | 179             | 4600       | 38         |
| 2011/3/15 20:00 | 0.1      | 7000     | 60.8                | -                 | 64.7        | 84.1       | 178             | 4500       | 38         |
| 2011/3/15 20:30 | 0.1      | 7100     | 58.6                | -                 | 61.5        | 83.9       | 174             | 4000       | 38         |
| 2011/3/15 21:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 21:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                   |             |            |                 |            |            |

777セト  
水位計

777セト  
水位計

停止時  
水位計

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>777セツト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.04        | 3378                  | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                  | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                  | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                  | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                  | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                  | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                  | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                  | 29.5                | 32             | 59.1          | 132                | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                  | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                  | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                  | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                  | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                  | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                  | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                  | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                  | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                  | 28.9                | 32             | 58.7          | 133                | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                  | 26.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                  | 26.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                  | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                  | 28.8                | 33             | 58.6          | 133                | 597           | 44            |
| 2011/3/15 18:00 | 0.04        | 3362                  | 28.8                | 33             | 58.4          | 133                | 599           | 44            |
| 2011/3/15 18:30 | 0.04        | 3364                  | 29.1                | 33             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 19:00 | 0.04        | 3362                  | 29.2                | 33             | 58.4          | 134                | 598           | 44            |
| 2011/3/15 19:30 | 0.04        | 3364                  | 29.2                | 33             | 58.4          | 134                | 599           | 44            |
| 2011/3/15 20:00 | 0.04        | 3365                  | 29.2                | 22             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 20:30 | 0.04        | 3364                  | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:00 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 21:30 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 22:00 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 22:30 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 23:00 |             |                       |                     |                |               |                    |               |               |

2F-4号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アッポゼト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.09        | 4589                 | 93.2                | 137            | 97.9          | 258                | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                 | 91.3                | 134            | 97.3          | 255                | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                 | 90.3                | 133            | 97            | 254                | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                 | 89.4                | 131            | 96.8          | 252                | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                 | 88.6                | 130            | 96.4          | 250                | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                 | 88.2                | 128            | 96.3          | 249                | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                 | 87.2                | 127            | 96            | 247                | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                 | 86.5                | 125            | 95.7          | 245                | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                 | 85.9                | 123            | 95.5          | 243                | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                 | 85.3                | 121            | 95.2          | 241                | 5200          | 93            |
| 2011/3/15 11:00 | 0.09        | 4589                 | 84.6                | 119            | 94.8          | 240                | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                 | 84.1                | 117            | 94.6          | 237                | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                 | 82.6                | 114            | 94            | 234                | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                 | 80.0                | 111            | 93.5          | 231                | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                 | 78.6                | 109            | 93            | 229                | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                 | 77.4                | 107            | 92.5          | 227                | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                 | 76.1                | 104            | 92.2          | 224                | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                 | 75.1                | 102            | 91.9          | 222                | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                 | 74.1                | 101            | 91.6          | 220                | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                 | 73.2                | 99             | 91.4          | 218                | 5150          | 82            |
| 2011/3/15 16:00 | 0.09        | 4589                 | 72.4                | 97             | 91.2          | 217                | 5150          | 82            |
| 2011/3/15 16:30 | 0.1         | 4589                 | 71.7                | 96             | 90.9          | 215                | 5100          | 81            |
| 2011/3/15 17:00 | 0.1         | 4589                 | 70.7                | 94             | 90.6          | 213                | 5100          | 79            |
| 2011/3/15 17:30 | 0.1         | 4589                 | 70.3                | 93             | 90.4          | 212                | 5050          | 78            |
| 2011/3/15 18:00 | 0.1         | 4589                 | 69.7                | 92             | 90.1          | 211                | 5150          | 77            |
| 2011/3/15 18:30 | 0.1         | 4589                 | 69.0                | 90             | 89.8          | 209                | 5150          | 76            |
| 2011/3/15 19:00 | 0.1         | 4589                 | 68.5                | 89             | 89.5          | 208                | 5150          | 75            |
| 2011/3/15 19:30 | 0.1         | 4589                 | 67.8                | 88             | 89.3          | 207                | 5100          | 75            |
| 2011/3/15 20:00 | 0.1         | 4589                 | 67.1                | 87             | 89            | 206                | 5050          | 74            |
| 2011/3/15 20:30 | 0.05        | 3896                 | 68.2                | 88             | 88.7          | 208                | 5200          | 73            |
| 2011/3/15 21:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 21:30 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 22:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 22:30 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 23:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 23:30 |             |                      |                     |                |               |                    |               |               |



2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     | 777セト<br>水位計        | 86                 | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71.1                | 116                | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 67.5                | 108                | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67.1                | 116                | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66.4                | 108                | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 65.8                | 110                | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65.4                | 108                | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 64.9                | 108                | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 64.7                | 76                 | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                | 97                 | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                | 117                | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 66.7                | 120                | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4506     | 64.4                | 108                | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     | 62.9                | 103                | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     | 62.2                | 103                | 80          | 80.8       | 205             | 4300       | 46         |
| 2011/3/15 19:30 | 0.12     | 4586     | 61.7                | -                  | 78          | 80.5       | 203             | 4212       | 46         |
| 2011/3/15 20:00 | 0.13     | 6600     | 61.3                | -                  | 77          | 80.3       | 201             | 4126       | 46         |
| 2011/3/15 20:30 | 0.12     | 7000     | 61                  | -                  | 74          | 79.9       | 199             | 4013       | 46         |
| 2011/3/15 21:00 | 0.12     | 6900     | 60.4                | -                  | 73          | 79.7       | 197             | 3944       | 46         |
| 2011/3/15 21:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 22:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                    |             |            |                 |            |            |

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     |                     | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     |                     | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     |                     | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     |                     | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     |                     | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     |                     | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     |                     | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     |                     | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     |                     | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     |                     | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     |                     | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4236     |                     | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     |                     | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     |                     | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     |                     | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     |                     | 69                | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     |                     | 69                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     |                     | 82                | 68.8        | 84.9       | 184             | 4800       | 39         |
| 2011/3/15 19:30 | 0.2      | 7400     |                     | -                 | 65.9        | 84.6       | 179             | 4600       | 38         |
| 2011/3/15 20:00 | 0.1      | 7000     |                     | -                 | 64.7        | 84.1       | 178             | 4500       | 38         |
| 2011/3/15 20:30 | 0.1      | 7100     |                     | -                 | 61.5        | 83.9       | 174             | 4000       | 38         |
| 2011/3/15 21:00 | 0.09     | 7100     | 58.3                | -                 | 60.3        | 83.8       | 172             | 4300       | 37         |
| 2011/3/15 21:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                   |             |            |                 |            |            |

777セト  
水位計

777セト  
水位計

停止時  
水位計

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>777ゼット | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.04        | 3378                  | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                  | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                  | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                  | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                  | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                  | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                  | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                  | 29.5                | 32             | 59.1          | 132                | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                  | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                  | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                  | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                  | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                  | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                  | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                  | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                  | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                  | 28.9                | 32             | 58.7          | 133                | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                  | 28.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                  | 28.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                  | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                  | 28.8                | 33             | 58.6          | 133                | 597           | 44            |
| 2011/3/15 18:00 | 0.04        | 3362                  | 28.8                | 33             | 58.4          | 133                | 599           | 44            |
| 2011/3/15 18:30 | 0.04        | 3364                  | 29.1                | 33             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 19:00 | 0.04        | 3362                  | 29.2                | 33             | 58.4          | 134                | 598           | 44            |
| 2011/3/15 19:30 | 0.04        | 3364                  | 29.2                | 33             | 58.4          | 134                | 599           | 44            |
| 2011/3/15 20:00 | 0.04        | 3365                  | 29.2                | 22             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 20:30 | 0.04        | 3364                  | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:00 | 0.04        | 3365                  | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:30 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 22:00 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 22:30 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 23:00 |             |                       |                     |                |               |                    |               |               |

2F-4号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) アップセット | 炉水温度(°C) 給水/ズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|-----------------|------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.09     | 4589            | 93.2             | 137         | 97.9       | 258             | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589            | 91.3             | 134         | 97.3       | 255             | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589            | 90.3             | 133         | 97         | 254             | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589            | 89.4             | 131         | 96.8       | 252             | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589            | 88.6             | 130         | 96.4       | 250             | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589            | 88.2             | 128         | 96.3       | 249             | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589            | 87.2             | 127         | 96         | 247             | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589            | 86.5             | 125         | 95.7       | 245             | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589            | 85.9             | 123         | 95.5       | 243             | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589            | 85.3             | 121         | 95.2       | 241             | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589            | 84.6             | 119         | 94.8       | 240             | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589            | 84.1             | 117         | 94.6       | 237             | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589            | 82.6             | 114         | 94         | 234             | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589            | 80.0             | 111         | 93.5       | 231             | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589            | 78.6             | 109         | 93         | 229             | 5150       | 88         |
| 2011/3/15 13:30 | 0.1      | 4589            | 77.4             | 107         | 92.5       | 227             | 5150       | 87         |
| 2011/3/15 14:00 | 0.1      | 4589            | 76.1             | 104         | 92.2       | 224             | 5150       | 86         |
| 2011/3/15 14:30 | 0.1      | 4589            | 75.1             | 102         | 91.9       | 222             | 5150       | 85         |
| 2011/3/15 15:00 | 0.1      | 4589            | 74.1             | 101         | 91.6       | 220             | 5200       | 84         |
| 2011/3/15 15:30 | 0.1      | 4589            | 73.2             | 99          | 91.4       | 218             | 5150       | 82         |
| 2011/3/15 16:00 | 0.09     | 4589            | 72.4             | 97          | 91.2       | 217             | 5150       | 82         |
| 2011/3/15 16:30 | 0.1      | 4589            | 71.7             | 96          | 90.9       | 215             | 5100       | 81         |
| 2011/3/15 17:00 | 0.1      | 4589            | 70.7             | 94          | 90.6       | 213             | 5100       | 79         |
| 2011/3/15 17:30 | 0.1      | 4589            | 70.3             | 93          | 90.4       | 212             | 5050       | 78         |
| 2011/3/15 18:00 | 0.1      | 4589            | 69.7             | 92          | 90.1       | 211             | 5150       | 77         |
| 2011/3/15 18:30 | 0.1      | 4589            | 69.0             | 90          | 89.8       | 209             | 5150       | 76         |
| 2011/3/15 19:00 | 0.1      | 4589            | 68.5             | 89          | 89.5       | 208             | 5150       | 75         |
| 2011/3/15 19:30 | 0.1      | 4589            | 67.8             | 88          | 89.3       | 207             | 5100       | 75         |
| 2011/3/15 20:00 | 0.1      | 4589            | 67.1             | 87          | 89         | 206             | 5050       | 74         |
| 2011/3/15 20:30 | 0.05     | 3896            | 68.2             | 88          | 88.7       | 208             | 5200       | 73         |
| 2011/3/15 21:00 | 0.05     | 3951            | 73.3             | 89          | 88.3       | 209             | 5100       | 73         |
| 2011/3/15 21:30 |          |                 |                  |             |            |                 |            |            |
| 2011/3/15 22:00 |          |                 |                  |             |            |                 |            |            |
| 2011/3/15 22:30 |          |                 |                  |             |            |                 |            |            |
| 2011/3/15 23:00 |          |                 |                  |             |            |                 |            |            |
| 2011/3/15 23:30 |          |                 |                  |             |            |                 |            |            |

2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     | 777セト<br>水位計        | 86                 | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71.1                | 116                | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 67.5                | 108                | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67.1                | 116                | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66.4                | 108                | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 65.8                | 110                | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65.4                | 108                | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 64.9                | 108                | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 64.7                | 76                 | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                | 97                 | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                | 117                | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 66.7                | 120                | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4586     | 64.4                | 108                | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     | 62.9                | 103                | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     | 62.2                | 103                | 80          | 80.8       | 205             | 4300       | 46         |
| 2011/3/15 19:30 | 0.12     | 4586     | 61.7                | -                  | 78          | 80.5       | 203             | 4212       | 46         |
| 2011/3/15 20:00 | 0.13     | 6600     | 61.3                | -                  | 77          | 80.3       | 201             | 4126       | 46         |
| 2011/3/15 20:30 | 0.12     | 7000     | 61                  | -                  | 74          | 79.9       | 199             | 4013       | 46         |
| 2011/3/15 21:00 | 0.12     | 6900     | 60.4                | -                  | 73          | 79.7       | 197             | 3944       | 45         |
| 2011/3/15 21:30 | 0.12     | 6900     | 60                  | -                  | 72          | 79.4       | 195             | 3870       | 46         |
| 2011/3/15 22:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                    |             |            |                 |            |            |

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     |                     | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     |                     | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     |                     | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     |                     | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     |                     | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     |                     | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     |                     | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     |                     | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     |                     | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     |                     | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     |                     | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     |                     | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     |                     | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     |                     | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     |                     | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     |                     | 69                | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     |                     | 69                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     |                     | 82                | 68.8        | 84.9       | 184             | 4800       | 39         |
| 2011/3/15 19:30 | 0.2      | 7400     |                     | -                 | 65.9        | 84.6       | 179             | 4600       | 38         |
| 2011/3/15 20:00 | 0.1      | 7000     |                     | -                 | 64.7        | 84.1       | 178             | 4500       | 38         |
| 2011/3/15 20:30 | 0.1      | 7100     |                     | -                 | 61.5        | 83.9       | 174             | 4000       | 38         |
| 2011/3/15 21:00 | 0.09     | 7100     |                     | -                 | 60.3        | 83.8       | 172             | 4300       | 37         |
| 2011/3/15 21:30 | 0.09     | 7100     |                     | 58.3              | 59          | 83.5       | 170             | 4200       | 37         |
| 2011/3/15 22:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 22:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                   |             |            |                 |            |            |

アッセル  
水位計

アッセル  
水位計

停止時  
水位計

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アップセット | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|-----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.04        | 3378                  | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                  | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                  | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                  | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                  | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                  | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                  | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                  | 29.5                | 32             | 59.1          | 132                | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                  | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                  | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                  | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                  | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                  | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                  | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                  | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                  | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                  | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                  | 28.9                | 32             | 58.7          | 133                | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                  | 26.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                  | 26.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                  | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                  | 28.8                | 33             | 58.6          | 133                | 597           | 44            |
| 2011/3/15 18:00 | 0.04        | 3362                  | 28.8                | 33             | 58.4          | 133                | 599           | 44            |
| 2011/3/15 18:30 | 0.04        | 3364                  | 29.1                | 33             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 19:00 | 0.04        | 3362                  | 29.2                | 33             | 58.4          | 134                | 598           | 44            |
| 2011/3/15 19:30 | 0.04        | 3364                  | 29.2                | 33             | 58.4          | 134                | 599           | 44            |
| 2011/3/15 20:00 | 0.04        | 3365                  | 29.2                | 22             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 20:30 | 0.04        | 3364                  | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:00 | 0.04        | 3365                  | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:30 | 0.04        | 3364                  | 29.2                | 33             | 58.3          | 134                | 598           | 44            |
| 2011/3/15 22:00 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 22:30 |             |                       |                     |                |               |                    |               |               |
| 2011/3/15 23:00 |             |                       |                     |                |               |                    |               |               |

2F-4号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アツシヤト | 炉水温度(°C)<br>給水/ズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.09        | 4589                 | 93.2                | 137            | 97.9          | 258                | 5200          | 100           |
| 2011/3/15 6:30  | 0.09        | 4589                 | 91.3                | 134            | 97.3          | 255                | 5200          | 100           |
| 2011/3/15 7:00  | 0.1         | 4589                 | 90.3                | 133            | 97            | 254                | 5200          | 99            |
| 2011/3/15 7:30  | 0.09        | 4589                 | 89.4                | 131            | 96.8          | 252                | 5200          | 98            |
| 2011/3/15 8:00  | 0.09        | 4589                 | 88.6                | 130            | 96.4          | 250                | 5200          | 97            |
| 2011/3/15 8:30  | 0.11        | 4589                 | 88.2                | 128            | 96.3          | 249                | 5200          | 97            |
| 2011/3/15 9:00  | 0.1         | 4589                 | 87.2                | 127            | 96            | 247                | 5150          | 96            |
| 2011/3/15 9:30  | 0.1         | 4589                 | 86.5                | 125            | 95.7          | 245                | 5200          | 95            |
| 2011/3/15 10:00 | 0.1         | 4589                 | 85.9                | 123            | 95.5          | 243                | 5200          | 94            |
| 2011/3/15 10:30 | 0.1         | 4589                 | 85.3                | 121            | 95.2          | 241                | 5200          | 93            |
| 2011/3/15 11:00 | 0.08        | 4589                 | 84.6                | 119            | 94.8          | 240                | 5200          | 92            |
| 2011/3/15 11:30 | 0.1         | 4589                 | 84.1                | 117            | 94.6          | 237                | 5200          | 91            |
| 2011/3/15 12:00 | 0.1         | 4589                 | 82.6                | 114            | 94            | 234                | 5200          | 90            |
| 2011/3/15 12:30 | 0.1         | 4589                 | 80.0                | 111            | 93.5          | 231                | 5150          | 89            |
| 2011/3/15 13:00 | 0.09        | 4589                 | 78.6                | 109            | 93            | 229                | 5150          | 88            |
| 2011/3/15 13:30 | 0.1         | 4589                 | 77.4                | 107            | 92.5          | 227                | 5150          | 87            |
| 2011/3/15 14:00 | 0.1         | 4589                 | 76.1                | 104            | 92.2          | 224                | 5150          | 86            |
| 2011/3/15 14:30 | 0.1         | 4589                 | 75.1                | 102            | 91.9          | 222                | 5150          | 85            |
| 2011/3/15 15:00 | 0.1         | 4589                 | 74.1                | 101            | 91.6          | 220                | 5200          | 84            |
| 2011/3/15 15:30 | 0.1         | 4589                 | 73.2                | 99             | 91.4          | 218                | 5150          | 82            |
| 2011/3/15 16:00 | 0.09        | 4589                 | 72.4                | 97             | 91.2          | 217                | 5150          | 82            |
| 2011/3/15 16:30 | 0.1         | 4589                 | 71.7                | 96             | 90.9          | 215                | 5100          | 81            |
| 2011/3/15 17:00 | 0.1         | 4589                 | 70.7                | 94             | 90.6          | 213                | 5100          | 79            |
| 2011/3/15 17:30 | 0.1         | 4589                 | 70.3                | 93             | 90.4          | 212                | 5050          | 78            |
| 2011/3/15 18:00 | 0.1         | 4589                 | 69.7                | 92             | 90.1          | 211                | 5150          | 77            |
| 2011/3/15 18:30 | 0.1         | 4589                 | 69.0                | 90             | 89.8          | 209                | 5150          | 76            |
| 2011/3/15 19:00 | 0.1         | 4589                 | 68.5                | 89             | 89.5          | 208                | 5150          | 75            |
| 2011/3/15 19:30 | 0.1         | 4589                 | 67.8                | 88             | 89.3          | 207                | 5100          | 75            |
| 2011/3/15 20:00 | 0.1         | 4589                 | 67.1                | 87             | 89            | 206                | 5050          | 74            |
| 2011/3/15 20:30 | 0.05        | 3896                 | 68.2                | 88             | 88.7          | 208                | 5200          | 73            |
| 2011/3/15 21:00 | 0.05        | 3951                 | 73.3                | 89             | 88.3          | 209                | 5100          | 73            |
| 2011/3/15 21:30 | 0.06        | 3200                 | 81.3                | 90             | 88            | 209                | 5150          | 73            |
| 2011/3/15 22:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 22:30 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 23:00 |             |                      |                     |                |               |                    |               |               |
| 2011/3/15 23:30 |             |                      |                     |                |               |                    |               |               |



2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4488     |                     | 86                 | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     |                     | 86                 | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     | 777セト<br>水位計        | 86                 | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71.1                | 116                | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 67.5                | 108                | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67.1                | 116                | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66.4                | 108                | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 65.8                | 110                | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65.4                | 108                | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 64.9                | 108                | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 64.7                | 76                 | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                | 97                 | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                | 117                | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 66.7                | 120                | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4586     | 64.4                | 108                | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     | 62.9                | 103                | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     | 62.2                | 103                | 80          | 80.8       | 205             | 4300       | 46         |
| 2011/3/15 19:30 | 0.12     | 4586     | 61.7                | -                  | 78          | 80.5       | 203             | 4212       | 46         |
| 2011/3/15 20:00 | 0.13     | 6600     | 61.3                | -                  | 77          | 80.3       | 201             | 4126       | 46         |
| 2011/3/15 20:30 | 0.12     | 7000     | 61                  | -                  | 74          | 79.9       | 199             | 4013       | 46         |
| 2011/3/15 21:00 | 0.12     | 6900     | 60.4                | -                  | 73          | 79.7       | 197             | 3944       | 46         |
| 2011/3/15 21:30 | 0.12     | 6900     | 60                  | -                  | 72          | 79.4       | 195             | 3870       | 46         |
| 2011/3/15 22:00 | 0.12     | 6900     | 59.6                | -                  | 70          | 79.1       | 193             | 3773       | 46         |
| 2011/3/15 22:30 | 0.11     | 7200     | 63.7                | -                  | 70          | 78.7       | 191             | 3702       | 43         |
| 2011/3/15 23:00 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                    |             |            |                 |            |            |

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     | 70                  | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     | 69                  | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     | 69                  | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     | 68.7                | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     | 70                  | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     | 68.9                | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     | 67.7                | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     | 66.5                | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     | 65.6                | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     | 65.4                | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     | 64.9                | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     | 65.6                | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     | 65.1                | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     | 64.6                | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     | 64.5                | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     | 64.9                | 69                | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     | 64.9                | 69                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     | 64                  | 82                | 68.8        | 84.9       | 184             | 4800       | 39         |
| 2011/3/15 19:30 | 0.2      | 7400     | 59.6                | -                 | 65.9        | 84.6       | 179             | 4600       | 38         |
| 2011/3/15 20:00 | 0.1      | 7000     | 60.8                | -                 | 64.7        | 84.1       | 178             | 4500       | 38         |
| 2011/3/15 20:30 | 0.1      | 7100     | 58.6                | -                 | 61.5        | 83.9       | 174             | 4000       | 38         |
| 2011/3/15 21:00 | 0.09     | 7100     | 58.3                | -                 | 60.3        | 83.8       | 172             | 4300       | 37         |
| 2011/3/15 21:30 | 0.09     | 7100     | 58.3                | -                 | 59          | 83.5       | 170             | 4200       | 37         |
| 2011/3/15 22:00 | 0.09     | 7100     | 57.3                | -                 | 57.4        | 82.9       | 168             | 4100       | 37         |
| 2011/3/15 22:30 | 0.09     | 7100     | 56.8                | -                 | 57.2        | 82.6       | 165             | 4000       | 37         |
| 2011/3/15 23:00 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/15 23:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                   |             |            |                 |            |            |

777セ外  
水位計

777セ外  
水位計

停止時  
水位計

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アツテト | 炉水温度(°C)<br>給水ノズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|---------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.04        | 3378                | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                | 29.5                | 32             | 59.1          | 132                | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                | 28.9                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                | 26.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                | 26.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                | 28.8                | 33             | 58.6          | 133                | 597           | 44            |
| 2011/3/15 18:00 | 0.04        | 3362                | 28.8                | 33             | 58.4          | 133                | 599           | 44            |
| 2011/3/15 18:30 | 0.04        | 3364                | 29.1                | 33             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 19:00 | 0.04        | 3362                | 29.2                | 33             | 58.4          | 134                | 598           | 44            |
| 2011/3/15 19:30 | 0.04        | 3364                | 29.2                | 33             | 58.4          | 134                | 599           | 44            |
| 2011/3/15 20:00 | 0.04        | 3365                | 29.2                | 22             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 20:30 | 0.04        | 3364                | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:00 | 0.04        | 3365                | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:30 | 0.04        | 3364                | 29.2                | 33             | 58.3          | 134                | 598           | 44            |
| 2011/3/15 22:00 | 0.04        | 3362                | 29.2                | 33             | 58.2          | 133                | 600           | 44            |
| 2011/3/15 22:30 | 0.12        | 3361                | 29.1                | 33             | 58.1          | 134                | 599           | 44            |
| 2011/3/15 23:00 |             |                     |                     |                |               |                    |               |               |

2F-4号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) アツクセツ | 炉水温度(°C) 給水ノズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------------|------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.09     | 4589           | 93.2             | 137         | 97.9       | 258             | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589           | 91.3             | 134         | 97.3       | 255             | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589           | 90.3             | 133         | 97         | 254             | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589           | 89.4             | 131         | 96.8       | 252             | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589           | 88.6             | 130         | 96.4       | 250             | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589           | 88.2             | 128         | 96.3       | 249             | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589           | 87.2             | 127         | 96         | 247             | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589           | 86.5             | 125         | 95.7       | 245             | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589           | 85.9             | 123         | 95.5       | 243             | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589           | 85.3             | 121         | 95.2       | 241             | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589           | 84.6             | 119         | 94.8       | 240             | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589           | 84.1             | 117         | 94.6       | 237             | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589           | 82.6             | 114         | 94         | 234             | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589           | 80.0             | 111         | 93.5       | 231             | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589           | 78.6             | 109         | 93         | 229             | 5150       | 88         |
| 2011/3/15 13:30 | 0.1      | 4589           | 77.4             | 107         | 92.5       | 227             | 5150       | 87         |
| 2011/3/15 14:00 | 0.1      | 4589           | 76.1             | 104         | 92.2       | 224             | 5150       | 86         |
| 2011/3/15 14:30 | 0.1      | 4589           | 75.1             | 102         | 91.9       | 222             | 5150       | 85         |
| 2011/3/15 15:00 | 0.1      | 4589           | 74.1             | 101         | 91.6       | 220             | 5200       | 84         |
| 2011/3/15 15:30 | 0.1      | 4589           | 73.2             | 99          | 91.4       | 218             | 5150       | 82         |
| 2011/3/15 16:00 | 0.09     | 4589           | 72.4             | 97          | 91.2       | 217             | 5150       | 82         |
| 2011/3/15 16:30 | 0.1      | 4589           | 71.7             | 96          | 90.9       | 215             | 5100       | 81         |
| 2011/3/15 17:00 | 0.1      | 4589           | 70.7             | 94          | 90.6       | 213             | 5100       | 79         |
| 2011/3/15 17:30 | 0.1      | 4589           | 70.3             | 93          | 90.4       | 212             | 5050       | 78         |
| 2011/3/15 18:00 | 0.1      | 4589           | 69.7             | 92          | 90.1       | 211             | 5150       | 77         |
| 2011/3/15 18:30 | 0.1      | 4589           | 69.0             | 90          | 89.8       | 209             | 5150       | 76         |
| 2011/3/15 19:00 | 0.1      | 4589           | 68.5             | 89          | 89.5       | 208             | 5150       | 75         |
| 2011/3/15 19:30 | 0.1      | 4589           | 67.8             | 88          | 89.3       | 207             | 5100       | 75         |
| 2011/3/15 20:00 | 0.1      | 4589           | 67.1             | 87          | 89         | 206             | 5050       | 74         |
| 2011/3/15 20:30 | 0.05     | 3896           | 66.2             | 88          | 88.7       | 208             | 5200       | 73         |
| 2011/3/15 21:00 | 0.05     | 3951           | 73.3             | 89          | 88.3       | 209             | 5100       | 73         |
| 2011/3/15 21:30 | 0.06     | 3200           | 81.3             | 90          | 88         | 209             | 5150       | 73         |
| 2011/3/15 22:00 | 0.07     | 4190           | 87.4             | 88          | 87.7       | 205             | 5100       | 73         |
| 2011/3/15 22:30 | 0.12     | 4588           | 87.4             | 86          | 87.4       | 205             | 5100       | 73         |
| 2011/3/15 23:00 |          |                |                  |             |            |                 |            |            |
| 2011/3/15 23:30 |          |                |                  |             |            |                 |            |            |

2F-1号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|--------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4438     |                     | 86                 | 118         | 89.7       | 250             | 5807       | 58         |
| 2011/3/15 6:30  | 0.06     | 4437     | 797セプト<br>水位計       | 86                 | 117         | 89.7       | 249             | 5803       | 58         |
| 2011/3/15 7:00  | 0.06     | 4465     |                     | 86                 | 116         | 88.8       | 248             | 5803       | 57         |
| 2011/3/15 7:30  | 0.06     | 4431     |                     | 86                 | 115         | 88.5       | 247             | 5804       | 56         |
| 2011/3/15 8:00  | 0.06     | 4402     |                     | 86                 | 114         | 88.2       | 246             | 5805       | 56         |
| 2011/3/15 8:30  | 0.06     | 4366     |                     | 86                 | 113         | 87.8       | 245             | 5806       | 55         |
| 2011/3/15 9:00  | 0.06     | 4336     |                     | 86                 | 113         | 87.6       | 244             | 5808       | 55         |
| 2011/3/15 9:30  | 0.06     | 4302     |                     | 86                 | 112         | 87.1       | 244             | 5809       | 54         |
| 2011/3/15 10:00 | 0.09     | 4025     | 75                  | 97                 | 111         | 86.9       | 242             | 6821       | 54         |
| 2011/3/15 10:30 | 0.11     | 3866     | 73                  | 103                | 108         | 86.6       | 241             | 5875       | 54         |
| 2011/3/15 11:00 | 0.14     | 4291     | 73                  | 110                | 108         | 86.4       | 239             | 5768       | 53         |
| 2011/3/15 11:30 | 0.21     | 1900     | 72                  | 122                | 103         | 86.0       | 233             | 5502       | 53         |
| 2011/3/15 12:00 | 0.17     | 6500     | 71.1                | 116                | 101         | 85.7       | 230             | 5330       | 52         |
| 2011/3/15 12:30 | 0.13     | 6100     | 68                  | 108                | 97          | 85.3       | 227             | 5273       | 52         |
| 2011/3/15 13:00 | 0.13     | 5400     | 67.5                | 108                | 97          | 85.0       | 226             | 5233       | 51         |
| 2011/3/15 13:30 | 0.17     | 6300     | 67.1                | 116                | 94          | 84.5       | 223             | 5069       | 50         |
| 2011/3/15 14:00 | 0.13     | 6600     | 66.4                | 108                | 92          | 84.0       | 220             | 4933       | 49         |
| 2011/3/15 14:30 | 0.14     | 6400     | 65.8                | 110                | 89          | 83.7       | 218             | 4871       | 49         |
| 2011/3/15 15:00 | 0.13     | 6300     | 65.4                | 108                | 89          | 83.3       | 215             | 4785       | 48         |
| 2011/3/15 15:30 | 0.13     | 6400     | 64.9                | 108                | 86          | 83         | 213             | 4697       | 48         |
| 2011/3/15 16:00 | 0.04     | 3459     | 64.7                | 76                 | 88          | 83         | 216             | 4962       | 47         |
| 2011/3/15 16:30 | 0.09     | 3750     | 66.1                | 97                 | 88          | 82.5       | 215             | 4977       | 47         |
| 2011/3/15 17:00 | 0.18     | 4588     | 68.3                | 117                | 85          | 82         | 212             | 4752       | 48         |
| 2011/3/15 17:30 | 0.2      | 4587     | 66.7                | 120                | 84          | 81.9       | 210             | 4496       | 48         |
| 2011/3/15 18:00 | 0.13     | 4586     | 64.4                | 108                | 84          | 81.5       | 208             | 4415       | 47         |
| 2011/3/15 18:30 | 0.12     | 4588     | 62.9                | 103                | 81          | 81.2       | 207             | 4376       | 47         |
| 2011/3/15 19:00 | 0.12     | 4587     | 62.2                | 103                | 80          | 80.8       | 205             | 4300       | 46         |
| 2011/3/15 19:30 | 0.12     | 4586     | 61.7                | -                  | 78          | 80.5       | 203             | 4212       | 46         |
| 2011/3/15 20:00 | 0.13     | 6600     | 61.3                | -                  | 77          | 80.3       | 201             | 4126       | 46         |
| 2011/3/15 20:30 | 0.12     | 7000     | 61                  | -                  | 74          | 79.9       | 199             | 4013       | 46         |
| 2011/3/15 21:00 | 0.12     | 6900     | 60.4                | -                  | 73          | 79.7       | 197             | 3944       | 46         |
| 2011/3/15 21:30 | 0.12     | 6900     | 60                  | -                  | 72          | 79.4       | 195             | 3870       | 46         |
| 2011/3/15 22:00 | 0.12     | 6900     | 59.6                | -                  | 70          | 79.1       | 193             | 3773       | 46         |
| 2011/3/15 22:30 | 0.11     | 7200     | 63.7                | -                  | 70          | 78.7       | 191             | 3702       | 43         |
| 2011/3/15 23:00 | 0.13     | 7200     | 59                  | -                  | 69          | 78.5       | 189             | 3617       | 43         |
| 2011/3/15 23:30 |          |          |                     |                    |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                    |             |            |                 |            |            |

停止時  
水位計

797セプト  
水位計

停止時  
水位計

2F-2号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) | 炉水温度(°C)<br>給水ノズル温度 | 炉水温度(°C)<br>炉圧換算値 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|----------|---------------------|-------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.06     | 4163     |                     | 86                | 92.2        | 92.5       | 210             | 5100       | 51         |
| 2011/3/15 6:30  | 0.06     | 4163     |                     | 86                | 90.6        | 92.0       | 209             | 5100       | 51         |
| 2011/3/15 7:00  | 0.06     | 4163     |                     | 86                | 90.3        | 91.9       | 208             | 5100       | 50         |
| 2011/3/15 7:30  | 0.06     | 4165     |                     | 86                | 89.1        | 91.7       | 207             | 5100       | 49         |
| 2011/3/15 8:00  | 0.06     | 4165     |                     | 86                | 91.3        | 91.3       | 206             | 5100       | 48         |
| 2011/3/15 8:30  | 0.06     | 4165     |                     | 86                | 87.5        | 91.0       | 205             | 5100       | 48         |
| 2011/3/15 9:00  | 0.06     | 4163     |                     | 86                | 86.6        | 90.7       | 204             | 5100       | 47         |
| 2011/3/15 9:30  | 0.06     | 4165     |                     | 86                | 85.6        | 90.2       | 203             | 5100       | 47         |
| 2011/3/15 10:00 | 0.06     | 4165     |                     | 86                | 84.7        | 90.0       | 202             | 5050       | 46         |
| 2011/3/15 10:30 | 0.06     | 4165     |                     | 86                | 83.1        | 89.9       | 202             | 5050       | 45         |
| 2011/3/15 11:00 | 0.06     | 4165     |                     | 86                | 83.4        | 89.7       | 201             | 5050       | 45         |
| 2011/3/15 11:30 | 0.06     | 4168     |                     | 86                | 81.8        | 89.7       | 201             | 5050       | 44         |
| 2011/3/15 12:00 | 0.05     | 4109     |                     | 82                | 82.2        | 89.3       | 200             | 5050       | 44         |
| 2011/3/15 12:30 | 0.05     | 4219     |                     | 82                | 80.3        | 88.9       | 199             | 5050       | 44         |
| 2011/3/15 13:00 | 0.03     | 4224     |                     | 69                | 80.0        | 88.6       | 198             | 5050       | 43         |
| 2011/3/15 13:30 | 0.03     | 4227     |                     | 69                | 78.8        | 88.3       | 197             | 5050       | 43         |
| 2011/3/15 14:00 | 0.03     | 4230     |                     | 69                | 77.5        | 87.9       | 195             | 5050       | 42         |
| 2011/3/15 14:30 | 0.03     | 4233     |                     | 69                | 75.6        | 87.6       | 194             | 5050       | 42         |
| 2011/3/15 15:00 | 0.03     | 4233     |                     | 69                | 75.6        | 87.2       | 193             | 5050       | 42         |
| 2011/3/15 15:30 | 0.03     | 3600     |                     | 69                | 74          | 87         | 193             | 5000       | 41         |
| 2011/3/15 16:00 | 0.03     | 4286     |                     | 69                | 74          | 87         | 192             | 5000       | 41         |
| 2011/3/15 16:30 | 0.03     | 4258     |                     | 69                | 73.4        | 86.3       | 191             | 5000       | 41         |
| 2011/3/15 17:00 | 0.03     | 4255     |                     | 69                | 72.5        | 86         | 191             | 5000       | 40         |
| 2011/3/15 17:30 | 0.03     | 4255     |                     | 69                | 72.2        | 85.7       | 190             | 5000       | 40         |
| 2011/3/15 18:00 | 0.03     | 4247     |                     | 69                | 71.6        | 85.1       | 189             | 5000       | 39         |
| 2011/3/15 18:30 | 0.03     | 4247     |                     | 69                | 70.3        | 85.1       | 187             | 4950       | 39         |
| 2011/3/15 19:00 | 0.05     | 4590     |                     | 82                | 68.8        | 84.9       | 184             | 4800       | 39         |
| 2011/3/15 19:30 | 0.2      | 7400     |                     | -                 | 65.9        | 84.6       | 179             | 4600       | 38         |
| 2011/3/15 20:00 | 0.1      | 7000     |                     | -                 | 64.7        | 84.1       | 178             | 4500       | 38         |
| 2011/3/15 20:30 | 0.1      | 7100     |                     | -                 | 61.5        | 83.9       | 174             | 4000       | 38         |
| 2011/3/15 21:00 | 0.09     | 7100     |                     | -                 | 60.3        | 83.8       | 172             | 4300       | 37         |
| 2011/3/15 21:30 | 0.09     | 7100     |                     | -                 | 59          | 83.5       | 170             | 4200       | 37         |
| 2011/3/15 22:00 | 0.09     | 7100     |                     | -                 | 57.4        | 82.9       | 168             | 4100       | 37         |
| 2011/3/15 22:30 | 0.09     | 7100     |                     | -                 | 57.2        | 82.6       | 165             | 4000       | 37         |
| 2011/3/15 23:00 | 0.09     | 7100     |                     | -                 | 55.9        | 82         | 163             | 3900       | 36         |
| 2011/3/15 23:30 |          |          |                     |                   |             |            |                 |            |            |
| 2011/3/16 0:00  |          |          |                     |                   |             |            |                 |            |            |

777セト  
水位計

777セト  
水位計

停止時  
水位計

2F-3号機

| 時間              | 炉圧<br>(MPa) | 炉水位<br>(mm)<br>アツクセト | 炉水温度(°C)<br>給水/ズル温度 | D/W圧力<br>(kPa) | D/W温度<br>(°C) | S/C圧力<br>(kPa abs) | S/C水位<br>(mm) | S/C温度<br>(°C) |
|-----------------|-------------|----------------------|---------------------|----------------|---------------|--------------------|---------------|---------------|
| 2011/3/15 6:00  | 0.04        | 3378                 | 29.9                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 6:30  | 0.04        | 3375                 | 29.8                | 31             | 59.3          | 132                | 599           | 44            |
| 2011/3/15 7:00  | 0.04        | 3375                 | 29.8                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 7:30  | 0.03        | 3372                 | 29.7                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:00  | 0.04        | 3372                 | 29.6                | 31             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 8:30  | 0.04        | 3372                 | 29.6                | 31             | 59.2          | 132                | 599           | 44            |
| 2011/3/15 9:00  | 0.04        | 3371                 | 29.6                | 32             | 59.1          | 132                | 598           | 44            |
| 2011/3/15 9:30  | 0.04        | 3371                 | 29.5                | 32             | 59.1          | 132                | 599           | 44            |
| 2011/3/15 10:00 | 0.04        | 3369                 | 29.4                | 31             | 59.0          | 132                | 598           | 44            |
| 2011/3/15 10:30 | 0.04        | 3368                 | 29.4                | 32             | 59.0          | 132                | 597           | 44            |
| 2011/3/15 11:00 | 0.04        | 3371                 | 29.3                | 32             | 59.0          | 132                | 599           | 44            |
| 2011/3/15 11:30 | 0.04        | 3369                 | 29.3                | 32             | 58.8          | 132                | 600           | 44            |
| 2011/3/15 12:00 | 0.04        | 3367                 | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 12:30 | 0.04        | 3367                 | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:00 | 0.04        | 3365                 | 29.2                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 13:30 | 0.04        | 3367                 | 29.1                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 14:00 | 0.04        | 3365                 | 29.1                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 14:30 | 0.04        | 3364                 | 29.0                | 32             | 58.7          | 133                | 598           | 44            |
| 2011/3/15 15:00 | 0.04        | 3365                 | 29.0                | 32             | 58.8          | 133                | 598           | 44            |
| 2011/3/15 15:30 | 0.04        | 3365                 | 28.9                | 32             | 58.7          | 133                | 599           | 44            |
| 2011/3/15 16:00 | 0.04        | 3365                 | 26.9                | 33             | 58.7          | 133                | 597           | 44            |
| 2011/3/15 16:30 | 0.04        | 3362                 | 26.9                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:00 | 0.04        | 3362                 | 28.8                | 33             | 58.5          | 133                | 598           | 44            |
| 2011/3/15 17:30 | 0.04        | 3364                 | 28.8                | 33             | 58.6          | 133                | 597           | 44            |
| 2011/3/15 18:00 | 0.04        | 3362                 | 28.8                | 33             | 58.4          | 133                | 599           | 44            |
| 2011/3/15 18:30 | 0.04        | 3364                 | 29.1                | 33             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 19:00 | 0.04        | 3362                 | 29.2                | 33             | 58.4          | 134                | 598           | 44            |
| 2011/3/15 19:30 | 0.04        | 3364                 | 29.2                | 33             | 58.4          | 134                | 599           | 44            |
| 2011/3/15 20:00 | 0.04        | 3365                 | 29.2                | 22             | 58.5          | 134                | 599           | 44            |
| 2011/3/15 20:30 | 0.04        | 3364                 | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:00 | 0.04        | 3365                 | 29.2                | 33             | 58.3          | 134                | 599           | 44            |
| 2011/3/15 21:30 | 0.04        | 3364                 | 29.2                | 33             | 58.3          | 134                | 598           | 44            |
| 2011/3/15 22:00 | 0.04        | 3362                 | 29.2                | 33             | 58.2          | 133                | 600           | 44            |
| 2011/3/15 22:30 | 0.12        | 3361                 | 29.1                | 33             | 58.1          | 134                | 599           | 44            |
| 2011/3/15 23:00 | 0.04        | 3362                 | 29.1                | 33             | 58.1          | 131                | 437           | 44            |

2F-4号機

| 時間              | 炉圧 (MPa) | 炉水位 (mm) アップ外 | 炉水温度(°C) 給水ノズル温度 | D/W圧力 (kPa) | D/W温度 (°C) | S/C圧力 (kPa abs) | S/C水位 (mm) | S/C温度 (°C) |
|-----------------|----------|---------------|------------------|-------------|------------|-----------------|------------|------------|
| 2011/3/15 6:00  | 0.09     | 4589          | 93.2             | 137         | 97.9       | 258             | 5200       | 100        |
| 2011/3/15 6:30  | 0.09     | 4589          | 91.3             | 134         | 97.3       | 255             | 5200       | 100        |
| 2011/3/15 7:00  | 0.1      | 4589          | 90.3             | 133         | 97         | 254             | 5200       | 99         |
| 2011/3/15 7:30  | 0.09     | 4589          | 89.4             | 131         | 96.8       | 252             | 5200       | 98         |
| 2011/3/15 8:00  | 0.09     | 4589          | 88.6             | 130         | 96.4       | 250             | 5200       | 97         |
| 2011/3/15 8:30  | 0.11     | 4589          | 88.2             | 128         | 96.3       | 249             | 5200       | 97         |
| 2011/3/15 9:00  | 0.1      | 4589          | 87.2             | 127         | 96         | 247             | 5150       | 96         |
| 2011/3/15 9:30  | 0.1      | 4589          | 86.5             | 125         | 95.7       | 245             | 5200       | 95         |
| 2011/3/15 10:00 | 0.1      | 4589          | 85.9             | 123         | 95.5       | 243             | 5200       | 94         |
| 2011/3/15 10:30 | 0.1      | 4589          | 85.3             | 121         | 95.2       | 241             | 5200       | 93         |
| 2011/3/15 11:00 | 0.09     | 4589          | 84.6             | 119         | 94.8       | 240             | 5200       | 92         |
| 2011/3/15 11:30 | 0.1      | 4589          | 84.1             | 117         | 94.6       | 237             | 5200       | 91         |
| 2011/3/15 12:00 | 0.1      | 4589          | 82.6             | 114         | 94         | 234             | 5200       | 90         |
| 2011/3/15 12:30 | 0.1      | 4589          | 80.0             | 111         | 93.5       | 231             | 5150       | 89         |
| 2011/3/15 13:00 | 0.09     | 4589          | 78.6             | 109         | 93         | 229             | 5150       | 88         |
| 2011/3/15 13:30 | 0.1      | 4589          | 77.4             | 107         | 92.5       | 227             | 5150       | 87         |
| 2011/3/15 14:00 | 0.1      | 4589          | 76.1             | 104         | 92.2       | 224             | 5150       | 86         |
| 2011/3/15 14:30 | 0.1      | 4589          | 75.1             | 102         | 91.9       | 222             | 5150       | 85         |
| 2011/3/15 15:00 | 0.1      | 4589          | 74.1             | 101         | 91.6       | 220             | 5200       | 84         |
| 2011/3/15 15:30 | 0.1      | 4589          | 73.2             | 99          | 91.4       | 218             | 5150       | 82         |
| 2011/3/15 16:00 | 0.09     | 4589          | 72.4             | 97          | 91.2       | 217             | 5150       | 82         |
| 2011/3/15 16:30 | 0.1      | 4589          | 71.7             | 96          | 90.9       | 215             | 5100       | 81         |
| 2011/3/15 17:00 | 0.1      | 4589          | 70.7             | 94          | 90.6       | 213             | 5100       | 79         |
| 2011/3/15 17:30 | 0.1      | 4589          | 70.3             | 93          | 90.4       | 212             | 5050       | 78         |
| 2011/3/15 18:00 | 0.1      | 4589          | 69.7             | 92          | 90.1       | 211             | 5150       | 77         |
| 2011/3/15 18:30 | 0.1      | 4589          | 69.0             | 90          | 89.8       | 209             | 5150       | 76         |
| 2011/3/15 19:00 | 0.1      | 4589          | 68.5             | 89          | 89.5       | 208             | 5150       | 75         |
| 2011/3/15 19:30 | 0.1      | 4589          | 67.8             | 88          | 89.3       | 207             | 5100       | 75         |
| 2011/3/15 20:00 | 0.1      | 4589          | 67.1             | 87          | 89         | 206             | 5050       | 74         |
| 2011/3/15 20:30 | 0.05     | 3896          | 68.2             | 88          | 88.7       | 208             | 5200       | 73         |
| 2011/3/15 21:00 | 0.05     | 3951          | 73.3             | 89          | 88.3       | 209             | 5100       | 73         |
| 2011/3/15 21:30 | 0.06     | 3200          | 81.3             | 90          | 88         | 209             | 5150       | 73         |
| 2011/3/15 22:00 | 0.07     | 4190          | 87.4             | 88          | 87.7       | 205             | 5100       | 73         |
| 2011/3/15 22:30 | 0.12     | 4588          | 87.4             | 86          | 87.4       | 205             | 5100       | 73         |
| 2011/3/15 23:00 | 0.13     | 4588          | 93.2             | 88          | 87.7       | 207             | 5050       | 72         |
| 2011/3/15 23:30 |          |               |                  |             |            |                 |            |            |