

2F-1号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)	
2011/3/15 6:00	0.06	4488		86	118	89.7	250	5807	58	
2011/3/15 6:30	0.06	4437	アップセット 水位計	86	117	89.7	249	5803	58	
2011/3/15 7:00	0.06	4465		86	116	86.8	248	5803	57	
2011/3/15 7:30	0.06	4431		86	115	88.5	247	5804	56	
2011/3/15 8:00	0.06	4402		86	114	88.2	246	5805	56	
2011/3/15 8:30	0.06	4366		86	113	87.8	245	5806	55	
2011/3/15 9:00	0.06	4336		86	113	87.6	244	5808	55	
2011/3/15 9:30	0.06	4302		86	112	87.1	244	5809	54	
2011/3/15 10:00	0.09	4025		75	97	111	86.9	242	6821	54
2011/3/15 10:30	0.11	3868		73	103	108	86.6	241	5875	54
2011/3/15 11:00	0.14	4291		73	110	108	86.4	239	5768	53
2011/3/15 11:30	0.21	1900	停止時 水位計	72	122	103	86.0	233	5502	53
2011/3/15 12:00	0.17	6500		71.1	116	101	85.7	230	5330	52
2011/3/15 12:30	0.13	6100		68	108	97	85.3	227	5273	52
2011/3/15 13:00	0.13	5400		67.5	108	97	85.0	226	5233	51
2011/3/15 13:30	0.17	6300		67.1	116	94	84.5	223	5069	50
2011/3/15 14:00	0.13	6600		66.4	108	92	84.0	220	4933	49
2011/3/15 14:30	0.14	6400		65.8	110	89	83.7	218	4871	49
2011/3/15 15:00	0.13	6300		65.4	108	89	83.3	215	4785	48
2011/3/15 15:30	0.13	6400		64.9	108	86	83	213	4697	48
2011/3/15 16:00	0.04	3459	アップセット 水位計	64.7	76	88	83	216	4962	47
2011/3/15 16:30	0.09	3750		66.1	97	88	82.5	215	4977	47
2011/3/15 17:00	0.18	4588		68.3	117	85	82	212	4752	48
2011/3/15 17:30	0.2	4587		66.7	120	84	81.9	210	4496	48
2011/3/15 18:00	0.13	4586		64.4	108	84	81.5	208	4415	47
2011/3/15 18:30	0.12	4588		62.9	103	81	81.2	207	4376	47
2011/3/15 19:00	0.12	4587	停止時 水位計	62.2	103	80	80.8	205	4300	46
2011/3/15 19:30	0.12	4586		61.7	-	78	80.5	203	4212	46
2011/3/15 20:00	0.13	6600		61.3	-	77	80.3	201	4126	46
2011/3/15 20:30	0.12	7000		61	-	74	79.9	199	4013	46
2011/3/15 21:00	0.12	6900		60.4	-	73	79.7	197	3944	46
2011/3/15 21:30	0.12	6900		60	-	72	79.4	195	3870	46
2011/3/15 22:00	0.12	6900		59.6	-	70	79.1	193	3773	46
2011/3/15 22:30	0.11	7200		63.7	-	70	78.7	191	3702	43
2011/3/15 23:00	0.13	7200		59	-	69	78.5	189	3617	43
2011/3/15 23:30	0.12	7200		58.8	-	68	78.1	187	3617	42
2011/3/16 0:00	0.12	7200		58.6	-	67	77.9	186	3467	42
2011/3/16 0:30										
2011/3/16 1:00										
2011/3/16 1:30										

No. 4690 P. 1  
2011年 3月16日 0時30分  
原子力発電所 設備管理部

2F-2号機									
時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163		86	86.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.6	69	75.6	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38
2011/3/15 20:00	0.1	7080	60.8	-	64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37
2011/3/15 21:30	0.09	7100	58.3	-	59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36
2011/3/16 0:30									
2011/3/16 1:00									
2011/3/16 1:30									
2011/3/16 2:00									
2011/3/16 2:30									
2011/3/16 3:00									

アップセット  
水位計

アップセット  
水位計

停止時  
水位計

## 2F-3号機

時間	炉圧 (MPa)	炉水位 (mm) 777セット	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.04	3378	29.9	31	59.2	132	599	44
2011/3/15 6:30	0.04	3375	29.8	31	59.3	132	599	44
2011/3/15 7:00	0.04	3375	29.8	31	59.1	132	598	44
2011/3/15 7:30	0.03	3372	29.7	31	59.1	132	598	44
2011/3/15 8:00	0.04	3372	29.6	31	59.1	132	598	44
2011/3/15 8:30	0.04	3372	29.6	31	59.2	132	599	44
2011/3/15 9:00	0.04	3371	29.6	32	59.1	132	598	44
2011/3/15 9:30	0.04	3371	29.5	32	59.1	132	599	44
2011/3/15 10:00	0.04	3369	29.4	31	59.0	132	598	44
2011/3/15 10:30	0.04	3368	29.4	32	59.0	132	597	44
2011/3/15 11:00	0.04	3371	29.3	32	59.0	132	599	44
2011/3/15 11:30	0.04	3369	29.3	32	58.8	132	600	44
2011/3/15 12:00	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 12:30	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 13:00	0.04	3365	29.2	32	58.8	133	598	44
2011/3/15 13:30	0.04	3367	29.1	32	58.7	133	598	44
2011/3/15 14:00	0.04	3365	29.1	32	58.8	133	598	44
2011/3/15 14:30	0.04	3364	29.0	32	58.7	133	598	44
2011/3/15 15:00	0.04	3365	29.0	32	58.8	133	598	44
2011/3/15 15:30	0.04	3365	28.9	32	58.7	133	599	44
2011/3/15 16:00	0.04	3365	28.9	33	58.7	133	597	44
2011/3/15 16:30	0.04	3362	28.9	33	58.5	133	598	44
2011/3/15 17:00	0.04	3362	28.8	33	58.5	133	598	44
2011/3/15 17:30	0.04	3364	28.8	33	58.6	133	597	44
2011/3/15 18:00	0.04	3362	28.8	33	58.4	133	599	44
2011/3/15 18:30	0.04	3364	29.1	33	58.5	134	599	44
2011/3/15 19:00	0.04	3362	29.2	33	58.4	134	598	44
2011/3/15 19:30	0.04	3364	29.2	33	58.4	134	599	44
2011/3/15 20:00	0.04	3365	29.2	22	58.5	134	599	44
2011/3/15 20:30	0.04	3364	29.2	33	58.3	134	599	44
2011/3/15 21:00	0.04	3365	29.2	33	58.3	134	599	44
2011/3/15 21:30	0.04	3364	29.2	33	58.3	134	598	44
2011/3/15 22:00	0.04	3362	29.2	33	58.2	133	600	44
2011/3/15 22:30	0.04	3361	29.1	33	58.1	134	599	44
2011/3/15 23:00	0.04	3362	29.1	33	58.1	131	437	44
2011/3/15 23:30	0.04	3361	29.1	32	58.3	126	-34	44
2011/3/16 0:00	0.04	3361	29.0	32	58.1	126	-33	44
2011/3/16 0:30								
2011/3/16 1:00								
2011/3/16 1:30								





2F-2号機										
時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)	
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51	
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51	
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50	
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49	
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48	
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48	
2011/3/15 9:00	0.06	4163		86	86.6	90.7	204	5100	47	
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47	
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46	
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45	
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45	
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44	
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44	
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44	
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43	
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43	
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42	
2011/3/15 14:30	0.03	4233	65.6	69	75.6	87.6	194	5050	42	
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42	
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41	
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41	
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41	
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40	
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40	
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39	
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39	
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39	
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38	
2011/3/15 20:00	0.1	7000	60.8	-	64.7	84.1	178	4500	38	
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38	
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37	
2011/3/15 21:30	0.09	7100	58.3	-	59	83.5	170	4200	37	
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37	
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37	
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36	
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36	
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36	
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35	
2011/3/16 1:00										
2011/3/16 1:30										
2011/3/16 2:00										
2011/3/16 2:30										
2011/3/16 3:00										

アップセット  
水位計

アップセット  
水位計

停止時  
水位計







2F-1号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)	
2011/3/15 6:00	0.06	4488		86	118	89.7	250	5807	58	
2011/3/15 6:30	0.06	4437	アッソセット 水位計	86	117	89.7	249	5803	58	
2011/3/15 7:00	0.06	4465		86	116	88.8	248	5803	57	
2011/3/15 7:30	0.06	4431		86	115	88.5	247	5804	56	
2011/3/15 8:00	0.06	4402		86	114	88.2	246	5805	56	
2011/3/15 8:30	0.06	4366		86	113	87.8	245	5806	55	
2011/3/15 9:00	0.06	4336		86	113	87.6	244	5808	55	
2011/3/15 9:30	0.06	4302		86	112	87.1	244	5809	54	
2011/3/15 10:00	0.09	4025		75	97	111	86.9	242	6821	54
2011/3/15 10:30	0.11	3866		73	103	108	86.6	241	5875	54
2011/3/15 11:00	0.14	4291		73	110	108	86.4	239	5768	53
2011/3/15 11:30	0.21	1900	72	122	103	86.0	233	5502	53	
2011/3/15 12:00	0.17	6500	71.1	116	101	85.7	230	5330	52	
2011/3/15 12:30	0.13	6100	68	108	97	85.3	227	5273	52	
2011/3/15 13:00	0.13	5400	67.5	108	97	85.0	226	5233	51	
2011/3/15 13:30	0.17	6300	67.1	116	94	84.5	223	5069	50	
2011/3/15 14:00	0.13	6600	66.4	108	92	84.0	220	4933	49	
2011/3/15 14:30	0.14	6400	65.8	110	89	83.7	218	4871	49	
2011/3/15 15:00	0.13	6300	65.4	108	89	83.3	215	4785	48	
2011/3/15 15:30	0.13	6400	64.9	108	86	83	213	4697	48	
2011/3/15 16:00	0.04	3459	64.7	76	88	83	216	4962	47	
2011/3/15 16:30	0.09	3750	66.1	97	88	82.5	215	4977	47	
2011/3/15 17:00	0.18	4588	68.3	117	85	82	212	4752	48	
2011/3/15 17:30	0.2	4587	66.7	120	84	81.9	210	4496	48	
2011/3/15 18:00	0.13	4586	64.4	108	84	81.5	208	4415	47	
2011/3/15 18:30	0.12	4588	62.9	103	81	81.2	207	4376	47	
2011/3/15 19:00	0.12	4587	62.2	103	80	80.8	205	4300	46	
2011/3/15 19:30	0.12	4586	61.7	-	78	80.5	203	4212	46	
2011/3/15 20:00	0.13	6600	61.3	-	77	80.3	201	4126	46	
2011/3/15 20:30	0.12	7000	61	-	74	79.9	199	4013	46	
2011/3/15 21:00	0.12	6900	60.4	-	73	79.7	197	3944	46	
2011/3/15 21:30	0.12	6900	60	-	72	79.4	195	3870	46	
2011/3/15 22:00	0.12	6900	59.6	-	70	79.1	193	3773	46	
2011/3/15 22:30	0.11	7200	63.7	-	70	78.7	191	3702	43	
2011/3/15 23:00	0.13	7200	59	-	69	78.5	189	3617	43	
2011/3/15 23:30	0.12	7200	58.8	-	68	78.1	187	3617	42	
2011/3/16 0:00	0.12	7200	58.6	-	67	77.9	186	3467	42	
2011/3/16 0:30	0.12	7200	58.1	-	66	77.6	184	3392	41	
2011/3/16 1:00	0.12	7000	58	-	65	77.4	183	3308	41	
2011/3/16 1:30										

停止時  
水位計

アッソセット  
水位計

停止時  
水位計

2F-2号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163	アップセット 水位計	86	86.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.6	69	75.6	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38
2011/3/15 20:00	0.1	7000	60.8	-	64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37
2011/3/15 21:30	0.09	7100	58.3	-	59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	-	51.3	81.3	154	3500	35
2011/3/16 1:30									
2011/3/16 2:00									
2011/3/16 2:30									
2011/3/16 3:00									

停止時  
水位計







2F-2号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163		86	86.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.6	69	75.6	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38
2011/3/15 20:00	0.1	7000	60.8	-	64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37
2011/3/15 21:30	0.09	7100	58.3	-	59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	-	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	-	50	81.2	152	3400	35
2011/3/16 2:00									
2011/3/16 2:30									
2011/3/16 3:00									

アップセット  
水位計

アップセット  
水位計

停止時  
水位計

## 2F-3号機

時間	炉圧 (MPa)	炉水位 (mm) アッパセット	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.04	3378	29.9	31	59.2	132	599	44
2011/3/15 6:30	0.04	3375	29.8	31	59.3	132	599	44
2011/3/15 7:00	0.04	3375	29.8	31	59.1	132	598	44
2011/3/15 7:30	0.03	3372	29.7	31	59.1	132	598	44
2011/3/15 8:00	0.04	3372	29.6	31	59.1	132	598	44
2011/3/15 8:30	0.04	3372	29.6	31	59.2	132	599	44
2011/3/15 9:00	0.04	3371	29.6	32	59.1	132	598	44
2011/3/15 9:30	0.04	3371	29.5	32	59.1	132	599	44
2011/3/15 10:00	0.04	3369	29.4	31	59.0	132	598	44
2011/3/15 10:30	0.04	3368	29.4	32	59.0	132	597	44
2011/3/15 11:00	0.04	3371	29.3	32	59.0	132	599	44
2011/3/15 11:30	0.04	3369	29.3	32	58.8	132	600	44
2011/3/15 12:00	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 12:30	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 13:00	0.04	3365	29.2	32	58.8	133	598	44
2011/3/15 13:30	0.04	3367	29.1	32	58.7	133	598	44
2011/3/15 14:00	0.04	3365	29.1	32	58.8	133	598	44
2011/3/15 14:30	0.04	3364	29.0	32	58.7	133	598	44
2011/3/15 15:00	0.04	3365	29.0	32	58.8	133	598	44
2011/3/15 15:30	0.04	3365	28.9	32	58.7	133	599	44
2011/3/15 16:00	0.04	3365	26.9	33	58.7	133	597	44
2011/3/15 16:30	0.04	3362	26.9	33	58.5	133	598	44
2011/3/15 17:00	0.04	3362	28.8	33	58.5	133	598	44
2011/3/15 17:30	0.04	3364	28.8	33	58.6	133	597	44
2011/3/15 18:00	0.04	3362	28.8	33	58.4	133	599	44
2011/3/15 18:30	0.04	3364	29.1	33	58.5	134	599	44
2011/3/15 19:00	0.04	3362	29.2	33	58.4	134	598	44
2011/3/15 19:30	0.04	3364	29.2	33	58.4	134	599	44
2011/3/15 20:00	0.04	3365	29.2	22	58.5	134	599	44
2011/3/15 20:30	0.04	3364	29.2	33	58.3	134	599	44
2011/3/15 21:00	0.04	3365	29.2	33	58.3	134	599	44
2011/3/15 21:30	0.04	3364	29.2	33	58.3	134	598	44
2011/3/15 22:00	0.04	3362	29.2	33	58.2	133	600	44
2011/3/15 22:30	0.04	3361	29.1	33	58.1	134	599	44
2011/3/15 23:00	0.04	3362	29.1	33	58.1	131	437	44
2011/3/15 23:30	0.04	3361	29.1	32	58.3	126	-34	44
2011/3/16 0:00	0.04	3361	29.0	32	58.1	126	-33	44
2011/3/16 0:30	0.04	3361	29.0	32	58.1	126	-34	44
2011/3/16 1:00	0.04	3360	28.9	32	58.1	126	-34	44
2011/3/16 1:30	0.04	3360	28.9	32	58.0	126	-34	44
2011/3/16 2:00								
2011/3/16 2:30								
2011/3/16 3:00								
2011/3/16 3:30								
2011/3/16 4:00								







2F-2号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163		86	86.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.6	69	75.6	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38
2011/3/15 20:00	0.1	7000	60.8	-	64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37
2011/3/15 21:30	0.09	7100	58.3	-	59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	-	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	-	50	81.2	152	3400	35
2011/3/16 2:00	0.09	7300	54	-	48.8	80.8	149	3200	35
2011/3/16 2:30									
2011/3/16 3:00									

アップセット  
水位計

アップセット  
水位計

停止時  
水位計







## 2F-2号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/G圧力 (kPa abs)	S/G水位 (mm)	S/G温度 (°C)
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		85	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163		86	86.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.6	69	75.6	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38
2011/3/15 20:00	0.1	7000	60.8	-	64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37
2011/3/15 21:30	0.08	7100	58.3	-	59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	-	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	-	50	81.2	152	3400	35
2011/3/16 2:00	0.09	7300	54	-	48.8	80.8	149	3200	35
2011/3/16 2:30	0.08	7300	53.7	-	47.8	80.7	148	3100	35
2011/3/16 3:00									
2011/3/16 3:30									
2011/3/16 4:00									
2011/3/16 4:30									
2011/3/16 5:00									

アッパセト  
水位計停止時  
水位計







2F-1号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)	
2011/3/15 6:00	0.06	4488		86	118	89.7	250	5807	58	
2011/3/15 6:30	0.06	4437		86	117	89.7	249	5803	58	
2011/3/15 7:00	0.06	4465	アップセット 水位計	86	116	88.8	248	5803	57	
2011/3/15 7:30	0.08	4431		88	115	88.5	247	5804	56	
2011/3/15 8:00	0.05	4402		86	114	88.2	246	5805	56	
2011/3/15 8:30	0.06	4396		86	113	87.8	245	5805	55	
2011/3/15 9:00	0.05	4336		85	113	87.6	244	5808	55	
2011/3/15 9:30	0.06	4302		85	112	87.1	244	5809	54	
2011/3/15 10:00	0.09	4025		75	97	85.9	242	6821	54	
2011/3/15 10:30	0.11	3856		73	103	86.8	241	5875	54	
2011/3/15 11:00	0.14	4291		73	110	86.4	239	5768	53	
2011/3/15 11:30	0.21	1900	停止時 水位計	72	122	86.0	233	5502	53	
2011/3/15 12:00	0.17	6500		71.1	116	101	85.7	230	5330	52
2011/3/15 12:30	0.13	6100		68	108	97	85.3	227	5273	52
2011/3/15 13:00	0.13	5400		67.5	108	97	85.0	226	5233	51
2011/3/15 13:30	0.17	6300		67.1	116	94	84.5	223	5069	50
2011/3/15 14:00	0.13	6600		68.4	108	92	84.0	220	4931	49
2011/3/15 14:30	0.14	6400		65.8	110	89	83.7	218	4871	49
2011/3/15 15:00	0.13	6300		65.4	108	89	83.3	215	4785	48
2011/3/15 15:30	0.13	6400		64.9	108	86	83	213	4697	48
2011/3/15 16:00	0.04	3459	アップセット 水位計	64.7	76	88	83	216	4982	47
2011/3/15 16:30	0.09	3750		66.1	97	88	82.5	215	4977	47
2011/3/15 17:00	0.16	4588		68.3	117	85	82	212	4752	48
2011/3/15 17:30	0.2	4587		66.7	120	84	81.9	210	4496	48
2011/3/15 18:00	0.13	4588		64.4	108	84	81.5	208	4415	47
2011/3/15 18:30	0.12	4588		62.9	103	81	81.2	207	4376	47
2011/3/15 19:00	0.12	4587	停止時 水位計	62.2	103	80	80.8	205	4300	46
2011/3/15 19:30	0.12	4588		61.7	-	78	80.5	203	4212	46
2011/3/15 20:00	0.13	6600		61.3	-	77	80.3	201	4126	46
2011/3/15 20:30	0.12	7000		61	-	74	79.9	199	4013	46
2011/3/15 21:00	0.12	6900		60.4	-	73	79.7	197	3944	46
2011/3/15 21:30	0.12	6900		60	-	72	79.4	195	3870	46
2011/3/15 22:00	0.12	6900		59.6	-	70	79.1	193	3773	46
2011/3/15 22:30	0.11	7200		63.7	-	70	78.7	191	3702	43
2011/3/15 23:00	0.13	7200		59	-	69	78.5	189	3617	43
2011/3/15 23:30	0.12	7200		58.8	-	68	78.1	187	3817	42
2011/3/16 0:00	0.12	7200		58.6	-	67	77.9	186	3467	42
2011/3/16 0:30	0.12	7200		58.1	-	66	77.6	184	3392	41
2011/3/16 1:00	0.12	7000		58	-	65	77.4	183	3308	41
2011/3/16 1:30	0.12	7000		57.5	-	65	77.1	181	3222	41
2011/3/16 2:00	0.12	7000		57.1	-	64	77	179	3138	41
2011/3/16 2:30	0.12	7000		56.9	-	63	76.6	178	3059	41
2011/3/16 3:00	0.12	7000		56.6	-	62	76.2	176	2965	41
2011/3/16 3:30	0.12	7000		56.5	-	62	76.3	175	2902	41
2011/3/16 4:00	0.12	7000		56.5	-	62	76.3	175	2902	41
2011/3/16 4:30										
2011/3/16 5:00										
2011/3/16 5:30										
2011/3/16 6:00										
2011/3/16 6:30										
2011/3/16 7:00										
2011/3/16 7:30										
2011/3/16 8:00										

2011/3/15 10:00 2F-1号機 水位計







2F-1号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4488		85	118	89.7	250	5807	58
2011/3/15 6:30	0.06	4437		86	117	89.7	249	5803	58
2011/3/15 7:00	0.06	4465	アツアツ水位計	86	116	88.8	248	5803	57
2011/3/15 7:30	0.06	4431		86	115	88.5	247	5804	58
2011/3/15 8:00	0.06	4402		86	114	86.2	246	5806	58
2011/3/15 8:30	0.06	4366		86	113	87.8	245	5806	59
2011/3/15 9:00	0.08	4336		86	113	87.6	244	5808	55
2011/3/15 9:30	0.06	4302		86	112	87.1	244	5809	54
2011/3/15 9:30	0.06	4302		86	112	87.1	244	5809	54
2011/3/15 10:00	0.09	4025		75	97	86.9	242	6821	54
2011/3/15 10:30	0.11	3886		73	103	86.6	241	5875	54
2011/3/15 11:00	0.14	4291		73	110	86.4	239	5768	53
2011/3/15 11:30	0.21	1900	停止時水位計	72	122	86.0	233	5502	53
2011/3/15 12:00	0.17	6500		71.1	116	85.7	230	5330	52
2011/3/15 12:30	0.13	6100		88	100	85.3	227	5273	52
2011/3/15 13:00	0.13	5400		67.5	108	85.0	226	5233	51
2011/3/15 13:30	0.17	6300		67.1	110	84.5	223	5069	50
2011/3/15 14:00	0.13	6600		66.4	108	84.0	220	4933	49
2011/3/15 14:30	0.14	6400		65.8	110	83.7	218	4871	49
2011/3/15 15:00	0.13	6200		65.4	108	83.3	215	4785	48
2011/3/15 15:30	0.13	6400		64.9	108	83	213	4697	48
2011/3/15 16:00	0.04	3459	アツアツ水位計	64.7	78	83	216	4962	47
2011/3/15 16:30	0.09	3750		66.1	97	82.5	215	4977	47
2011/3/15 17:00	0.18	4588		68.3	117	82	212	4752	48
2011/3/15 17:30	0.2	4587		66.7	120	81.9	210	4496	48
2011/3/15 18:00	0.13	4586		66.7	100	81.5	208	4415	47
2011/3/15 18:30	0.12	4588		64.4	100	81.5	208	4415	47
2011/3/15 19:00	0.12	4587	停止時水位計	62.9	103	81.2	207	4376	47
2011/3/15 19:30	0.12	4586		62.2	103	80.8	205	4300	46
2011/3/15 20:00	0.13	6800		61.7	-	80.5	203	4212	46
2011/3/15 20:30	0.12	7000		61.3	-	80.3	201	4126	46
2011/3/15 21:00	0.12	6900		61	-	79.9	199	4013	46
2011/3/15 21:30	0.12	6900		60.4	-	79.7	197	3944	46
2011/3/15 22:00	0.12	6900		60	-	79.4	195	3870	46
2011/3/15 22:30	0.11	7200		59.6	-	79.1	193	3773	46
2011/3/15 23:00	0.13	7200		83.7	-	78.7	191	3702	43
2011/3/15 23:30	0.12	7200		59	-	78.5	189	3617	43
2011/3/16 0:00	0.12	7200		59.6	-	78.1	187	3617	42
2011/3/16 0:30	0.12	7200		58.8	-	77.9	188	3467	42
2011/3/16 1:00	0.12	7000		58.1	-	77.8	184	3392	41
2011/3/16 1:30	0.12	7000		58	-	77.4	183	3308	41
2011/3/16 2:00	0.12	7000		57.5	-	77.1	181	3222	41
2011/3/16 2:30	0.12	7000		57.1	-	77	179	3138	41
2011/3/16 3:00	0.12	7000		56.9	-	76.8	178	3059	41
2011/3/16 3:30	0.12	7000		56.6	-	76.2	176	2965	41
2011/3/16 4:00	0.12	7000		56.5	-	76.3	175	2902	41
2011/3/16 4:30	0.12	7000		56.1	-	75.9	172	2768	41
2011/3/16 5:00				56	-	75.7	171	2710	41
2011/3/16 5:30									
2011/3/16 6:00									
2011/3/16 6:30									
2011/3/16 7:00									
2011/3/16 7:30									
2011/3/16 8:00									

1/8

2/8

2F-2号機									
時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水/スル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		85	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163		86	85.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165		86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	70	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4169	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4199	89	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	88.7	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	70	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	68.9	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	67.7	69	-77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.5	69	75.0	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3690	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4296	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.8	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.03	4580	64.9	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.05	7400	64		65.9	84.6	179	4600	38
2011/3/15 20:00	0.2	7090	59.6		64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	60.8		61.5	83.9	174	4000	38
2011/3/15 21:00	0.1	7100	58.6		60.3	83.8	172	4300	37
2011/3/15 21:30	0.09	7100	58.3		59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	58.3		57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	57.3		57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.8		55.9	82	163	3900	36
2011/3/15 23:30	0.09	7100	56.1		54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.4		53.8	81.7	159	3700	36
2011/3/16 0:30	0.09	7200	56.1		52.2	81.4	156	3550	35
2011/3/16 1:00	0.08	7200	55.6		51.3	81.3	154	3500	35
2011/3/16 1:30	0.09	7200	55.1		50	81.2	152	3400	35
2011/3/16 2:00	0.08	7200	55.4		48.8	80.8	149	3200	35
2011/3/16 2:30	0.09	7300	54		47.8	80.7	148	3100	35
2011/3/16 3:00	0.08	7300	53.7		46.6	80.5	147	3000	36
2011/3/16 3:30	0.08	7400	52.7		45.6	80.4	147	3000	36
2011/3/16 4:00	0.09	7400	52.9		43.4	80.2	145	2800	36
2011/3/16 4:30	0.08	7400	52.9		43.4	80.2	145	2800	36
2011/3/16 5:00									
2011/3/16 5:30									
2011/3/16 6:00									
2011/3/16 6:30									
2011/3/16 7:00									
2011/3/16 7:30									
2011/3/16 8:00									

アップセット  
水位計

アップセット  
水位計

停止時  
水位計









5/8

# 2F-1号機




# 2F-2号機

6/8




# 2F-3号機

7/8



# 2F-4号機

8/8













2F-1号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)	
2011/3/15 6:00	0.06	4488		88	118	89.7	250	5807	58	
2011/3/15 6:30	0.06	4437		86	117	89.7	249	5803	58	
2011/3/15 7:00	0.06	4465	アップセット 水位計	86	116	88.8	248	5803	57	
2011/3/15 7:30	0.08	4431		86	115	88.5	247	5804	56	
2011/3/15 8:00	0.06	4402		86	114	88.2	246	5805	56	
2011/3/15 8:30	0.06	4366		86	113	87.8	245	5806	55	
2011/3/15 9:00	0.06	4336		86	113	87.6	244	5808	55	
2011/3/15 9:30	0.06	4302		86	112	87.1	244	5809	54	
2011/3/15 10:00	0.09	4025		97	111	86.9	242	6821	54	
2011/3/15 10:30	0.11	3866		73	103	86.6	241	5875	54	
2011/3/15 11:00	0.14	4291	停止時 水位計	73	110	86.4	239	5768	53	
2011/3/15 11:30	0.21	1900		72	122	86.0	233	5502	53	
2011/3/15 12:00	0.17	6500		71.1	116	85.7	230	5330	52	
2011/3/15 12:30	0.13	6100		68	108	85.3	227	5273	52	
2011/3/15 13:00	0.13	5400		67.5	108	85.0	226	5233	51	
2011/3/15 13:30	0.17	6300		67.1	116	84.5	223	5089	50	
2011/3/15 14:00	0.13	6600		66.4	108	84.0	220	4933	49	
2011/3/15 14:30	0.14	6400		65.8	110	83.7	218	4871	49	
2011/3/15 15:00	0.13	6300		65.4	108	83.3	215	4785	48	
2011/3/15 15:30	0.13	6400		64.9	108	86	83	213	4697	48
2011/3/15 16:00	0.04	3459	アップセット 水位計	64.7	76	88	83	216	4962	47
2011/3/15 16:30	0.09	3750		66.1	97	88	82.5	215	4977	47
2011/3/15 17:00	0.18	4588		68.3	117	85	82	212	4752	48
2011/3/15 17:30	0.2	4587		66.7	120	84	81.9	210	4496	48
2011/3/15 18:00	0.13	4586		64.4	108	84	81.5	208	4415	47
2011/3/15 18:30	0.12	4588		62.9	103	81	81.2	207	4376	47
2011/3/15 19:00	0.12	4587		62.2	103	80	80.8	205	4300	46
2011/3/15 19:30	0.12	4586		61.7	-	78	80.5	203	4212	46
2011/3/15 20:00	0.13	6600		61.3	-	77	80.3	201	4128	46
2011/3/15 20:30	0.12	7000		61	-	74	79.9	199	4013	46
2011/3/15 21:00	0.12	6900		60.4	-	73	79.7	197	3944	46
2011/3/15 21:30	0.12	6900		60	-	72	79.4	195	3870	46
2011/3/15 22:00	0.12	6900	停止時 水位計	59.6	-	70	79.1	193	3773	46
2011/3/15 22:30	0.11	7200		63.7	-	70	78.7	191	3702	43
2011/3/15 23:00	0.13	7200		59	-	69	78.5	189	3617	43
2011/3/15 23:30	0.12	7200		58.8	-	68	78.1	187	3617	42
2011/3/16 0:00	0.12	7200		58.6	-	67	77.9	186	3467	42
2011/3/16 0:30	0.12	7200		58.1	-	66	77.6	184	3392	41
2011/3/16 1:00	0.12	7000		58	-	65	77.4	183	3308	41
2011/3/16 1:30	0.12	7000		57.5	-	65	77.1	181	3222	41
2011/3/16 2:00	0.12	7000		57.1	-	64	77	179	3138	41
2011/3/16 2:30	0.12	7000		56.9	-	63	76.6	178	3059	41
2011/3/16 3:00	0.12	7000		56.6	-	62	76.2	176	2965	41
2011/3/16 3:30	0.12	7000		56.5	-	62	76.3	175	2902	41
2011/3/16 4:00	0.12	7000		56.1	-	59	75.9	172	2768	41
2011/3/16 4:30	0.12	7000		58	-	59	75.7	171	2710	41
2011/3/16 5:00	0.11	7000		55.8	-	58	75.4	170	2640	41
2011/3/16 5:30	0.12	6950		55.5	-	57	75.3	168	2553	41
2011/3/16 6:00										
2011/3/16 6:30										
2011/3/16 7:00										
2011/3/16 7:30										
2011/3/16 8:00										

NO. 1477

水島電機工業株式会社

LC/CAC 0014C 4111A7

2F-2号機									
時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.08	4163		86	92.2	92.5	210	5100	51
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48
2011/3/15 8:30	0.06	4165		86	87.5	91.0	205	5100	48
2011/3/15 9:00	0.06	4163		86	86.6	90.7	204	5100	47
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45
2011/3/15 11:30	0.06	4163	69	86	81.8	89.7	201	5050	44
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44
2011/3/15 12:30	0.05	4219	70	82	80.3	88.9	199	5050	44
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.6	198	5050	43
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42
2011/3/15 14:30	0.03	4233	65.8	69	75.6	87.6	194	5050	42
2011/3/15 15:00	0.03	4233	65.4	69	75.6	87.2	193	5050	42
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41
2011/3/15 16:00	0.03	4286	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40
2011/3/15 18:00	0.03	4247	64.9	69	71.0	85.1	189	5000	39
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39
2011/3/15 19:00	0.05	4590	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38
2011/3/15 20:00	0.1	7000	60.8	-	64.7	84.1	178	4500	38
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.6	172	4300	37
2011/3/15 21:30	-0.09	7100	58.3	-	59	83.5	170	4200	37
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	-	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	-	50	81.2	152	3400	35
2011/3/16 2:00	0.09	7300	54	-	49.8	80.8	149	3200	35
2011/3/16 2:30	0.08	7300	53.7	-	47.8	80.7	148	3100	35
2011/3/16 3:00	0.08	7400	52.7	-	46.6	80.5	147	3000	36
2011/3/16 3:30	0.08	7400	52.9	-	45.6	80.4	147	3000	36
2011/3/16 4:00	0.08	7400	52.9	-	43.4	80.2	145	2800	36
2011/3/16 4:30	0.08	7400	52.9	-	43.4	80.2	145	2800	36
2011/3/16 5:00	0.07	7450	52.3	-	41.8	79.7	144	2600	36
2011/3/16 5:30	0.07	7450	52.4	-	41.2	79.6	143	2500	36
2011/3/16 6:00									
2011/3/16 6:30									
2011/3/16 7:00									
2011/3/16 7:30									
2011/3/16 8:00									

アップセット  
水位計

アップセット  
水位計

停止時  
水位計

2F-3号機

時間	炉圧 (MPa)	炉水位 (mm) 777セット	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.04	3378	29.3	31	59.2	132	599	44
2011/3/15 6:30	0.04	3375	29.8	31	59.3	132	599	44
2011/3/15 7:00	0.04	3375	29.6	31	59.1	132	598	44
2011/3/15 7:30	0.03	3372	29.7	31	59.1	132	598	44
2011/3/15 8:00	0.04	3372	29.6	31	59.1	132	598	44
2011/3/15 8:30	0.04	3372	29.6	31	59.2	132	599	44
2011/3/15 9:00	0.04	3371	29.6	32	59.1	132	598	44
2011/3/15 9:30	0.04	3371	29.5	32	59.1	132	599	44
2011/3/15 10:00	0.04	3369	29.4	31	59.0	132	598	44
2011/3/15 10:30	0.04	3368	29.4	32	59.0	132	597	44
2011/3/15 11:00	0.04	3371	29.3	32	59.0	132	599	44
2011/3/15 11:30	0.04	3369	29.3	32	58.8	132	600	44
2011/3/15 12:00	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 12:30	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 13:00	0.04	3365	29.2	32	58.8	133	598	44
2011/3/15 13:30	0.04	3367	29.1	32	58.7	133	598	44
2011/3/15 14:00	0.04	3365	29.1	32	58.8	133	598	44
2011/3/15 14:30	0.04	3364	29.0	32	58.7	133	598	44
2011/3/15 15:00	0.04	3365	29.0	32	58.8	133	598	44
2011/3/15 15:30	0.04	3365	28.9	32	58.7	133	599	44
2011/3/15 16:00	0.04	3365	28.8	33	58.7	133	597	44
2011/3/15 16:30	0.04	3362	28.9	33	58.5	133	598	44
2011/3/15 17:00	0.04	3362	28.8	33	58.5	133	598	44
2011/3/15 17:30	0.04	3364	28.8	33	58.6	133	597	44
2011/3/15 18:00	0.04	3362	28.8	33	58.4	133	599	44
2011/3/15 18:30	0.04	3364	29.1	33	58.5	134	598	44
2011/3/15 19:00	0.04	3382	29.2	33	58.4	134	598	44
2011/3/15 19:30	0.04	3364	29.2	33	58.4	134	599	44
2011/3/15 20:00	0.04	3385	29.2	22	58.5	134	599	44
2011/3/15 20:30	0.04	3364	29.2	33	58.3	134	599	44
2011/3/15 21:00	0.04	3365	29.2	33	58.3	134	599	44
2011/3/15 21:30	0.04	3364	29.2	33	58.3	134	598	44
2011/3/15 22:00	0.04	3362	29.2	33	58.2	133	600	44
2011/3/15 22:30	0.04	3381	29.1	33	58.1	134	599	44
2011/3/15 23:00	0.04	3362	29.1	33	58.1	131	437	44
2011/3/15 23:30	0.04	3361	29.1	32	58.3	126	-34	44
2011/3/16 0:00	0.04	3361	29.0	32	58.1	126	-33	44
2011/3/16 0:30	0.04	3361	29.0	32	58.1	126	-34	44
2011/3/16 1:00	0.04	3369	28.9	32	58.1	126	-34	44
2011/3/16 1:30	0.04	3360	28.9	32	58.0	126	-34	44
2011/3/16 2:00	0.04	3358	28.8	32	58.1	126	-34	44
2011/3/16 2:30	0.04	3358	28.8	32	58.0	126	-34	44
2011/3/16 3:00	0.04	3358	28.6	32	58.0	126	-35	44
2011/3/16 3:30	0.04	3358	28.7	32	58.1	126	-34	44
2011/3/16 4:00	0.04	3358	28.7	32	58.0	125	-34	44
2011/3/16 4:30	0.04	3357	28.6	32	58.0	126	-34	44
2011/3/16 5:00	0.04	3357	28.6	32	57.9	125	-34	44
2011/3/16 5:30	0.04	3357	28.5	32	57.9	126	-34	44
2011/3/16 6:00								
2011/3/16 6:30								
2011/3/16 7:00								
2011/3/16 7:30								
2011/3/16 8:00								

11.11.11

水本電機 11/11/11 11:11

11.11.11 11:11



2F 7: 1 関車 (153x-7) 6:00 1/4

2F-1号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水/スル温度	炉水温度(°C) 炉圧換算温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.06	4488		86	118	89.7	250	5807	58
2011/3/15 6:30	0.06	4437		86	117	89.7	249	5803	58
2011/3/15 7:00	0.06	4465	アップセット 水位計	86	116	88.8	248	5803	57
2011/3/15 7:30	0.08	4431		86	115	88.5	247	5804	56
2011/3/15 8:00	0.09	4402		86	114	88.2	246	5805	56
2011/3/15 8:30	0.06	4366		86	113	87.8	245	5806	55
2011/3/15 9:00	0.06	4376		86	113	87.6	244	5808	55
2011/3/15 9:30	0.08	4302		86	112	87.1	244	5809	54
2011/3/15 10:00	0.09	4025		75	97	86.9	242	5821	54
2011/3/15 10:30	0.11	3856		73	103	86.6	241	5875	54
2011/3/15 11:00	0.14	4291		73	110	86.4	239	5768	53
2011/3/15 11:30	0.21	1900	停止時 水位計	72	122	86.0	233	5502	53
2011/3/15 12:00	0.17	6500		71.1	116	85.7	230	5330	52
2011/3/15 12:30	0.13	8100		68	108	85.3	227	5273	52
2011/3/15 13:00	0.13	5400		67.5	108	85.0	228	5233	51
2011/3/15 13:30	0.17	6300		67.1	116	84.5	223	5059	50
2011/3/15 14:00	0.13	8000		66.4	108	84.0	220	4933	49
2011/3/15 14:30	0.14	6400		65.8	110	83.7	218	4871	49
2011/3/15 15:00	0.13	6300		65.4	108	83.3	215	4785	48
2011/3/15 15:30	0.13	8400		64.9	108	83	213	4697	48
2011/3/15 16:00	0.04	3459	アップセット 水位計	64.7	78	83	216	4952	47
2011/3/15 16:30	0.09	3750		66.1	97	82.5	215	4977	47
2011/3/15 17:00	0.18	4588		68.3	117	82	212	4752	48
2011/3/15 17:30	0.2	4587		66.7	120	81.9	210	4496	48
2011/3/15 18:00	0.13	4586		64.4	108	81.5	208	4415	47
2011/3/15 18:30	0.12	4588		62.9	103	81.2	207	4376	47
2011/3/15 19:00	0.12	4587		62.2	103	80.8	205	4300	46
2011/3/15 19:30	0.12	4586		61.7	78	80.5	203	4212	46
2011/3/15 20:00	0.13	6600		61.3	77	80.3	201	4126	46
2011/3/15 20:30	0.12	7000		61	74	79.9	195	4013	46
2011/3/15 21:00	0.12	6900		60.4	73	79.7	197	3944	46
2011/3/15 21:30	0.12	6900		60	72	79.4	195	3870	46
2011/3/15 22:00	0.12	6900	停止時 水位計	59.6	70	79.1	193	3773	46
2011/3/15 22:30	0.11	7200		63.7	70	78.7	191	3702	43
2011/3/15 23:00	0.13	7200		59	69	78.5	189	3617	43
2011/3/15 23:30	0.12	7200		58.8	68	78.1	187	3617	42
2011/3/16 0:00	0.12	7200		58.6	67	77.9	186	3467	42
2011/3/16 0:30	0.12	7200		58.1	66	77.6	184	3392	41
2011/3/16 1:00	0.12	7000		58	65	77.4	183	3308	41
2011/3/16 1:30	0.12	7000		57.5	65	77.1	181	3222	41
2011/3/16 2:00	0.12	7000		57.1	64	77	179	3138	41
2011/3/16 2:30	0.12	7000		56.9	63	76.6	178	3059	41
2011/3/16 3:00	0.12	7000		56.6	62	76.2	176	2965	41
2011/3/16 3:30	0.12	7000		56.5	62	76.3	175	2902	41
2011/3/16 4:00	0.12	7000		56.1	59	75.9	172	2768	41
2011/3/16 4:30	0.12	7000		56	59	75.7	171	2710	41
2011/3/16 5:00	0.11	7000		55.8	58	75.4	170	2640	41
2011/3/16 5:30	0.12	6950		55.5	57	75.3	168	2553	41
2011/3/16 6:00	0.11	6950		55.3	56	74.8	166	2452	41
2011/3/16 6:30									
2011/3/16 7:00									
2011/3/16 7:30									
2011/3/16 8:00									

2011/3/16 10:00 2F-1号機

2F-2号機

時間	炉圧 (MPa)	炉水位 (mm)	炉水温度(°C) 給水ノズル温度	炉水温度(°C) 炉圧換算値	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)	
2011/3/15 6:00	0.06	4163		86	92.2	92.5	210	5100	51	
2011/3/15 6:30	0.06	4163		86	90.6	92.0	209	5100	51	
2011/3/15 7:00	0.06	4163		86	90.3	91.9	208	5100	50	
2011/3/15 7:30	0.06	4165		86	89.1	91.7	207	5100	49	
2011/3/15 8:00	0.06	4165		86	91.3	91.3	206	5100	48	
2011/3/15 8:30	0.08	4165		86	87.5	91.0	205	5100	48	
2011/3/15 9:00	0.06	4163	アップセット 水位計	86	86.6	90.7	204	5100	47	
2011/3/15 9:30	0.06	4165		86	85.6	90.2	203	5100	47	
2011/3/15 10:00	0.06	4165	70	86	84.7	90.0	202	5050	46	
2011/3/15 10:30	0.06	4165	70	86	83.1	89.9	202	5050	45	
2011/3/15 11:00	0.06	4165	69	86	83.4	89.7	201	5050	45	
2011/3/15 11:30	0.06	4168	69	86	81.8	89.7	201	5050	44	
2011/3/15 12:00	0.05	4109	68.7	82	82.2	89.3	200	5050	44	
2011/3/15 12:30	0.05	4219	70	82	80.3	89.9	199	5050	44	
2011/3/15 13:00	0.03	4224	68.9	69	80.0	88.8	198	5050	43	
2011/3/15 13:30	0.03	4227	67.7	69	78.8	88.3	197	5050	43	
2011/3/15 14:00	0.03	4230	66.5	69	77.5	87.9	195	5050	42	
2011/3/15 14:30	0.03	4233	65.6	69	75.8	87.6	194	5050	42	
2011/3/15 15:00	0.03	4233	65.4	69	75.8	87.2	193	5050	42	
2011/3/15 15:30	0.03	3600	64.9	69	74	87	193	5000	41	
2011/3/15 16:00	0.03	4286	アップセット 水位計	65.6	69	74	87	192	5000	41
2011/3/15 16:30	0.03	4258	65.1	69	73.4	86.3	191	5000	41	
2011/3/15 17:00	0.03	4255	64.6	69	72.5	86	191	5000	40	
2011/3/15 17:30	0.03	4255	64.5	69	72.2	85.7	190	5000	40	
2011/3/15 18:00	0.03	4247	64.9	69	71.6	85.1	189	5000	39	
2011/3/15 18:30	0.03	4247	64.9	69	70.3	85.1	187	4950	39	
2011/3/15 19:00	0.05	4590	アップセット 水位計	64	82	68.8	84.9	184	4800	39
2011/3/15 19:30	0.2	7400	59.6	-	65.9	84.6	179	4600	38	
2011/3/15 20:00	0.1	7080	60.8	-	64.7	84.1	178	4500	38	
2011/3/15 20:30	0.1	7100	58.6	-	61.5	83.9	174	4000	38	
2011/3/15 21:00	0.09	7100	58.3	-	60.3	83.8	172	4300	37	
2011/3/15 21:30	0.09	7100	58.3	-	59	83.5	170	4200	37	
2011/3/15 22:00	0.09	7100	57.3	-	57.4	82.9	168	4100	37	
2011/3/15 22:30	0.09	7100	56.8	-	57.2	82.6	165	4000	37	
2011/3/15 23:00	0.09	7100	56.1	-	55.9	82	163	3900	36	
2011/3/15 23:30	0.09	7200	56.4	-	54.7	82	160	3800	36	
2011/3/16 0:00	0.09	7200	56.1	-	53.8	81.7	159	3700	36	
2011/3/16 0:30	0.08	7200	55.6	-	52.2	81.4	156	3550	35	
2011/3/16 1:00	0.09	7200	55.1	-	51.3	81.3	154	3500	35	
2011/3/16 1:30	0.08	7200	55.4	-	50	81.2	152	3400	35	
2011/3/16 2:00	0.09	7300	54	-	48.8	80.8	149	3200	35	
2011/3/16 2:30	0.08	7300	53.7	-	47.8	80.7	148	3100	35	
2011/3/16 3:00	0.08	7400	52.7	-	46.6	80.5	147	3000	36	
2011/3/16 3:30	0.08	7400	52.9	-	45.8	80.4	147	3000	36	
2011/3/16 4:00	0.08	7400	52.9	-	43.4	80.2	145	2800	36	
2011/3/16 4:00	0.08	7400	52.9	-	43.4	80.2	145	2800	36	
2011/3/16 5:00	0.07	7450	52.3	-	41.8	79.7	144	2600	36	
2011/3/16 5:30	0.07	7450	52.4	-	41.2	79.6	143	2500	36	
2011/3/16 6:00	0.06	7450	54.2	-	40.6	79.4	142	2400	36	
2011/3/16 6:30										
2011/3/16 7:00										
2011/3/16 7:30										
2011/3/16 8:00										

2011/3/15 10:00 10:30 11:00 11:30 12:00 12:30 13:00 13:30 14:00 14:30 15:00 15:30 16:00 16:30 17:00 17:30 18:00 18:30 19:00 19:30 20:00 20:30 21:00 21:30 22:00 22:30 23:00 23:30 2011/3/16 0:00 0:30 1:00 1:30 2:00 2:30 3:00 3:30 4:00 4:00 5:00 5:30 6:00 6:30 7:00 7:30 8:00



4/4

2F-4号機

時間	炉圧 (MPa)	炉水位 (mm)- アップセット	炉水温度(°C) 給水/ズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.09	4589	93.2	137	97.9	258	5200	100
2011/3/15 6:30	0.09	4589	91.3	134	97.3	255	5200	100
2011/3/15 7:00	0.1	4589	90.3	133	97	254	5200	99
2011/3/15 7:30	0.09	4589	89.4	131	96.8	252	5200	98
2011/3/15 8:00	0.09	4589	88.6	130	96.4	250	5200	97
2011/3/15 8:30	0.11	4589	88.2	128	96.3	249	5200	97
2011/3/15 9:00	0.1	4589	87.2	127	96	247	5150	96
2011/3/15 9:30	0.1	4589	86.5	125	95.7	245	5200	95
2011/3/15 10:00	0.1	4589	85.9	123	95.5	243	5200	94
2011/3/15 10:30	0.1	4589	85.3	121	95.2	241	5200	93
2011/3/15 11:00	0.09	4589	84.6	119	94.8	240	5200	92
2011/3/15 11:30	0.1	4589	84.1	117	94.6	237	5200	91
2011/3/15 12:00	0.1	4589	82.6	114	94	234	5200	90
2011/3/15 12:30	0.1	4589	80.0	111	93.5	231	5150	89
2011/3/15 13:00	0.09	4589	78.6	109	93	229	5150	88
2011/3/15 13:30	0.1	4589	77.4	107	92.5	227	5150	87
2011/3/15 14:00	0.1	4589	76.1	104	92.2	224	5150	86
2011/3/15 14:30	0.1	4589	75.1	102	91.9	222	5150	85
2011/3/15 15:00	0.1	4589	74.1	101	91.6	220	5200	84
2011/3/15 15:30	0.1	4589	73.2	99	91.4	218	5150	82
2011/3/15 16:00	0.09	4589	72.4	97	91.2	217	5150	82
2011/3/15 16:30	0.1	4589	71.7	96	90.9	215	5100	81
2011/3/15 17:00	0.1	4589	70.7	94	90.6	213	5100	79
2011/3/15 17:30	0.1	4589	70.3	93	90.4	212	5050	78
2011/3/15 18:00	0.1	4589	69.7	92	90.1	211	5150	77
2011/3/15 18:30	0.1	4589	69.0	90	89.8	209	5150	76
2011/3/15 19:00	0.1	4589	68.5	89	89.5	208	5150	75
2011/3/15 19:30	0.1	4589	67.8	88	89.3	207	5100	75
2011/3/15 20:00	0.1	4589	67.1	87	89	206	5050	74
2011/3/15 20:30	0.05	3896	68.2	88	88.7	208	5200	73
2011/3/15 21:00	0.05	3951	73.3	89	88.3	209	5100	73
2011/3/15 21:30	0.06	3200	81.3	90	88	209	5150	73
2011/3/15 22:00	0.07	4190	87.4	88	87.7	205	5100	73
2011/3/15 22:30	0.12	4589	87.4	86	87.4	205	5100	73
2011/3/15 23:00	0.13	4589	93.2	88	87.7	207	5050	72
2011/3/15 23:30	0.11	4589	80.1	88	87.4	206	5050	72
2011/3/16 0:00	0.09	4253	73.1	86	87	205	5100	71
2011/3/16 0:30	0.1	4590	87.2	85	86.8	204	5050	70
2011/3/16 1:00	0.11	4590	85.8	85	86.6	203	5050	69
2011/3/16 1:30	0.1	4590	84.8	84	86.4	202	5050	69
2011/3/16 2:00	0.12	4590	84.2	83	86.2	201	5000	68
2011/3/16 2:30	0.1	4590	83.6	82	85.8	200	5000	67
2011/3/16 3:00	0.1	4590	83.3	81	85.3	200	5000	67
2011/3/16 3:30	0.1	4590	82.8	81	84.9	199	5000	66
2011/3/16 4:00	0.12	4590	82.4	80	84.7	198	5000	65
2011/3/16 4:30	0.11	4590	81.8	79	84.4	197	5000	65
2011/3/16 5:00	0.11	4590	81.4	79	84.2	197	5000	64
2011/3/16 5:30	0.1	4590	80.9	78	83.9	196	5000	64
2011/3/16 6:00	0.09	4590	80.6	78	83.9	196	5000	64
2011/3/16 6:30								
2011/3/16 7:00								
2011/3/16 7:30								
2011/3/16 8:00								

11107  
0時JVVJ  
水電/暖/冷/圧/電 環境









2F-4号機

時間	炉圧 (MPa)	炉水位 (mm) アップセット	炉水温度(°C) 給水/スル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.09	4589	93.2	137	97.9	258	5200	100
2011/3/15 6:30	0.09	4589	91.3	134	97.3	255	5200	100
2011/3/15 7:00	0.1	4589	90.3	133	97	254	5200	99
2011/3/15 7:30	0.09	4589	89.4	131	96.8	252	5200	98
2011/3/15 8:00	0.09	4589	88.6	130	96.4	250	5200	97
2011/3/15 8:30	0.11	4589	88.2	128	96.3	249	5200	97
2011/3/15 9:00	0.1	4589	87.2	127	96	247	5150	96
2011/3/15 9:30	0.1	4589	86.5	125	95.7	245	5200	95
2011/3/15 10:00	0.1	4589	85.9	123	95.5	243	5200	94
2011/3/15 10:30	0.1	4589	85.3	121	95.2	241	5200	93
2011/3/15 11:00	0.09	4589	84.6	119	94.8	240	5200	92
2011/3/15 11:30	0.1	4589	84.1	117	94.6	237	5200	91
2011/3/15 12:00	0.1	4589	82.6	114	94	234	5200	90
2011/3/15 12:30	0.1	4589	80.0	111	93.5	231	5150	89
2011/3/15 13:00	0.09	4589	78.6	109	93	229	5150	88
2011/3/15 13:30	0.1	4589	77.4	107	92.5	227	5150	87
2011/3/15 14:00	0.1	4589	76.1	104	92.2	224	5150	86
2011/3/15 14:30	0.1	4589	75.1	102	91.9	222	5150	85
2011/3/15 15:00	0.1	4589	74.1	101	91.6	220	5200	84
2011/3/15 15:30	0.1	4589	73.2	99	91.4	218	5150	82
2011/3/15 16:00	0.09	4589	72.4	97	91.2	217	5150	82
2011/3/15 16:30	0.1	4589	71.7	96	90.9	215	5100	81
2011/3/15 17:00	0.1	4589	70.7	94	90.6	213	5100	79
2011/3/15 17:30	0.1	4589	70.3	93	90.4	212	5050	78
2011/3/15 18:00	0.1	4589	69.7	92	90.1	211	5150	77
2011/3/15 18:30	0.1	4589	69.0	90	89.8	209	5150	76
2011/3/15 19:00	0.1	4589	68.5	89	89.5	208	5150	75
2011/3/15 19:30	0.1	4589	67.8	88	89.3	207	5100	75
2011/3/15 20:00	0.1	4589	67.1	87	89	206	5050	74
2011/3/15 20:30	0.05	3996	66.2	88	88.7	208	5200	73
2011/3/15 21:00	0.05	3951	73.3	89	88.3	209	5100	73
2011/3/15 21:30	0.06	3200	81.3	90	88	209	5150	73
2011/3/15 22:00	0.07	4190	87.4	88	87.7	205	5100	73
2011/3/15 22:30	0.12	4588	87.4	86	87.4	205	5100	73
2011/3/15 23:00	0.13	4588	93.2	88	87.7	207	5050	72
2011/3/15 23:30	0.11	4588	80.1	88	87.4	206	5050	72
2011/3/16 0:00	0.09	4253	73.1	86	87	205	5100	71
2011/3/16 0:30	0.1	4590	67.2	85	86.8	204	5050	70
2011/3/16 1:00	0.11	4590	65.8	85	86.6	203	5050	69
2011/3/16 1:30	0.1	4590	64.8	84	86.4	202	5050	69
2011/3/16 2:00	0.12	4590	64.2	83	86.2	201	5000	68
2011/3/16 2:30	0.1	4590	63.6	82	85.8	200	5000	67
2011/3/16 3:00	0.1	4590	63.3	81	85.3	200	5000	67
2011/3/16 3:30	0.1	4590	62.8	81	84.9	199	5000	66
2011/3/16 4:00	0.12	4590	62.4	80	84.7	198	5000	65
2011/3/16 4:30	0.11	4590	61.8	79	84.4	197	5000	65
2011/3/16 5:00	0.11	4590	61.4	79	84.2	197	5000	64
2011/3/16 5:30	0.1	4590	60.9	78	83.9	196	5000	64
2011/3/16 6:00	0.09	4590	60.6	78	83.9	196	5000	64
2011/3/16 6:30	0.09	4590	60.2	77	83.6	195	5050	62
2011/3/16 7:00								
2011/3/16 7:30								
2011/3/16 8:00								

2011年3月15日 2F-4号機 運転記録





2F-3号機

時間	炉圧 (MPa)	炉水位 (mm) 777セット	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/15 6:00	0.04	3378	29.9	31	59.2	132	598	44
2011/3/15 6:30	0.04	3375	29.8	31	59.2	132	599	44
2011/3/15 7:00	0.04	3375	29.8	31	59.1	132	598	44
2011/3/15 7:30	0.03	3372	29.7	31	59.1	132	598	44
2011/3/15 8:00	0.04	3372	29.8	31	59.1	132	598	44
2011/3/15 8:30	0.04	3372	29.6	31	59.2	132	599	44
2011/3/15 9:00	0.04	3371	29.6	32	59.1	132	598	44
2011/3/15 9:30	0.04	3371	29.5	32	59.1	132	599	44
2011/3/15 10:00	0.04	3368	29.4	31	59.0	132	598	44
2011/3/15 10:30	0.04	3368	29.4	32	59.0	132	597	44
2011/3/15 11:00	0.04	3371	29.3	32	59.0	132	599	44
2011/3/15 11:30	0.04	3369	29.3	32	58.8	132	600	44
2011/3/15 12:00	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 12:30	0.04	3367	29.2	32	58.8	133	598	44
2011/3/15 13:00	0.04	3365	29.2	32	58.8	133	598	44
2011/3/15 13:30	0.04	3367	29.1	32	58.7	133	598	44
2011/3/15 14:00	0.04	3365	29.1	32	58.8	133	598	44
2011/3/15 14:30	0.04	3364	29.0	32	58.7	133	598	44
2011/3/15 15:00	0.04	3365	29.0	32	58.8	133	598	44
2011/3/15 15:30	0.04	3365	28.9	32	58.7	133	599	44
2011/3/15 16:00	0.04	3365	28.9	33	58.7	133	597	44
2011/3/15 16:30	0.04	3362	28.9	33	58.5	133	598	44
2011/3/15 17:00	0.04	3362	28.8	33	58.5	133	598	44
2011/3/15 17:30	0.04	3364	28.8	33	58.6	133	597	44
2011/3/15 18:00	0.04	3362	28.8	33	58.4	133	598	44
2011/3/15 18:30	0.04	3364	29.1	33	58.5	134	599	44
2011/3/15 19:00	0.04	3362	29.2	33	58.4	134	598	44
2011/3/15 19:30	0.04	3364	29.2	33	58.4	134	599	44
2011/3/15 20:00	0.04	3365	29.2	22	58.5	134	599	44
2011/3/15 20:30	0.04	3364	29.2	33	58.3	134	599	44
2011/3/15 21:00	0.04	3365	29.2	33	58.3	134	599	44
2011/3/15 21:30	0.04	3364	29.2	33	58.3	134	598	44
2011/3/15 22:00	0.04	3362	29.2	33	58.2	133	600	44
2011/3/15 22:30	0.04	3361	29.1	33	58.1	134	599	44
2011/3/15 23:00	0.04	3362	29.1	33	58.1	131	437	44
2011/3/15 23:30	0.04	3361	29.1	32	59.3	128	-34	44
2011/3/16 0:00	0.04	3361	29.0	32	58.1	126	-34	44
2011/3/16 0:30	0.04	3361	29.0	32	58.1	126	-34	44
2011/3/16 1:00	0.04	3360	28.9	32	58.1	126	-34	44
2011/3/16 1:30	0.04	3360	28.9	32	58.0	126	-34	44
2011/3/16 2:00	0.04	3358	28.8	32	58.1	126	-34	44
2011/3/16 2:30	0.04	3359	28.8	32	58.0	128	-34	44
2011/3/16 3:00	0.04	3359	28.8	32	58.0	126	-35	44
2011/3/16 3:30	0.04	3358	28.7	32	58.1	126	-34	44
2011/3/16 4:00	0.04	3358	28.7	32	58.0	125	-34	44
2011/3/16 4:30	0.04	3357	28.6	32	58.0	128	-34	44
2011/3/16 5:00	0.04	3357	28.6	32	57.9	125	-34	44
2011/3/16 5:30	0.04	3357	28.5	32	57.9	128	-34	44
2011/3/16 6:00	0.04	3355	28.5	32	57.9	128	-35	44
2011/3/16 6:30	0.04	3357	28.4	32	57.7	128	-35	44
2011/3/16 7:00	0.04	3357	28.3	32	57.8	126	-36	44
2011/3/16 7:30								
2011/3/16 8:00								

2011/3/15 17:00 2F-3号機 2011/3/16 7:00





2F-1号機

時間	炉圧 (MPa)	炉水位 (mm) 停止時	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.12	7200	58.6	67	77.9	186	3467	42
2011/3/16 0:30	0.12	7200	58.1	66	77.6	184	3392	41
2011/3/16 1:00	0.12	7000	58	65	77.4	183	3308	41
2011/3/16 1:30	0.12	7000	57.5	65	77.1	181	3222	41
2011/3/16 2:00	0.12	7000	57.1	64	77	179	3138	41
2011/3/16 2:30	0.12	7000	56.9	63	76.6	178	3059	41
2011/3/16 3:00	0.12	7000	56.6	62	76.2	176	2965	41
2011/3/16 3:30	0.12	7000	56.5	62	76.3	175	2902	41
2011/3/16 4:00	0.12	7000	56.1	59	75.9	172	2768	41
2011/3/16 4:30	0.12	7000	56	59	75.7	171	2710	41
2011/3/16 5:00	0.11	7000	55.8	58	75.4	170	2640	41
2011/3/16 5:30	0.12	6950	55.5	57	75.3	168	2553	41
2011/3/16 6:00	0.11	6950	55.3	56	74.8	166	2452	41
2011/3/16 6:30	0.11	6950	55.2	56	74.9	166	2412	41
2011/3/16 7:00	0.11	6950	55	55	74.7	164	2326	41
2011/3/16 7:30	0.11	6950	54.8	54	74.4	162	2227	41
2011/3/16 8:00	0.11	6950	54.6	53	74.2	161	2148	41
2011/3/16 8:30								
2011/3/16 9:00								
2011/3/16 9:30								
2011/3/16 10:00								
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

「炉水温度」については、3月15日 19:30以降「給水ノズル温度」を採取しているため、採取していない「炉圧換算温度」の記載を削除します。

## 2F-2号機

時間	炉圧 (MPa)	炉水位 (mm) 停止時	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.09	7200	56.1	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	50	81.2	152	3400	35
2011/3/16 2:00	0.09	7300	54	48.8	80.8	149	3200	35
2011/3/16 2:30	0.08	7300	53.7	47.8	80.7	148	3100	35
2011/3/16 3:00	0.08	7400	52.7	46.6	80.5	147	3000	36
2011/3/16 3:30	0.08	7400	52.9	45.6	80.4	147	3000	36
2011/3/16 4:00	0.08	7400	52.9	43.4	80.2	145	2800	36
2011/3/16 4:30	0.07	7500	52.3	42.8	80	145	2700	36
2011/3/16 5:00	0.07	7450	52.3	41.8	79.7	144	2600	36
2011/3/16 5:30	0.07	7450	52.4	41.2	79.6	143	2500	36
2011/3/16 6:00	0.06	7450	54.2	40.6	79.4	142	2400	36
2011/3/16 6:30	0.06	7450	54	40.3	79.2	142	2400	36
2011/3/16 7:00	0.06	7450	54.5	39.6	78.8	142	2350	36
2011/3/16 7:30	0.06	7450	53.5	39.3	78.6	141	2300	36
<b>2011/3/16 8:00</b>	<b>0.06</b>	<b>7450</b>	<b>55.2</b>	<b>38.7</b>	<b>78.4</b>	<b>140</b>	<b>2250</b>	<b>36</b>
2011/3/16 8:30								
2011/3/16 9:00								
2011/3/16 9:30								
2011/3/16 10:00								
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

「炉水温度」については、3月15日 19:30以降「給水ノズル温度」を採取しているため、採取していない「炉圧換算温度」の記載を削除します。

2F-3号機

時間	炉圧 (MPa)	炉水位 (mm) アッパセット	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.04	3361	29.0	32	58.1	126	-33	44
2011/3/16 0:30	0.04	3361	29.0	32	58.1	126	-34	44
2011/3/16 1:00	0.04	3360	28.9	32	58.1	126	-34	44
2011/3/16 1:30	0.04	3360	28.9	32	58.0	126	-34	44
2011/3/16 2:00	0.04	3358	28.8	32	58.1	126	-34	44
2011/3/16 2:30	0.04	3358	28.8	32	58.0	126	-34	44
2011/3/16 3:00	0.04	3358	28.8	32	58.0	126	-35	44
2011/3/16 3:30	0.04	3358	28.7	32	58.1	126	-34	44
2011/3/16 4:00	0.04	3358	28.7	32	58.0	125	-34	44
2011/3/16 4:30	0.04	3357	28.6	32	58.0	126	-34	44
2011/3/16 5:00	0.04	3357	28.6	32	57.9	125	-34	44
2011/3/16 5:30	0.04	3357	28.5	32	57.9	126	-34	44
2011/3/16 6:00	0.04	3355	28.5	32	57.9	126	-35	44
2011/3/16 6:30	0.04	3357	28.4	32	57.7	126	-35	44
2011/3/16 7:00	0.04	3357	28.3	32	57.8	126	-36	44
2011/3/16 7:30	0.04	3355	28.3	32	57.7	125	-36	44
2011/3/16 8:00	0.04	3354	28.2	32	57.8	125	-36	44
2011/3/16 8:30								
2011/3/16 9:00								
2011/3/16 9:30								
2011/3/16 10:00								
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

NO. 1300

2011年3月16日 0時17分

2011年3月16日 0時17分

2F-4号機

時間	炉圧 (MPa)	炉水位 (mm) アッパセット	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.09	4253	73.1	86	87	205	5100	71
2011/3/16 0:30	0.1	4590	67.2	85	86.8	204	5050	70
2011/3/16 1:00	0.11	4590	65.8	85	86.6	203	5050	69
2011/3/16 1:30	0.1	4590	64.8	84	86.4	202	5050	69
2011/3/16 2:00	0.12	4590	64.2	83	86.2	201	5000	68
2011/3/16 2:30	0.1	4590	63.6	82	85.8	200	5000	67
2011/3/16 3:00	0.1	4590	63.3	81	85.3	200	5000	67
2011/3/16 3:30	0.1	4590	62.8	81	84.9	199	5000	66
2011/3/16 4:00	0.12	4590	62.4	80	84.7	198	5000	65
2011/3/16 4:30	0.11	4590	61.8	79	84.4	197	5000	65
2011/3/16 5:00	0.11	4590	61.4	79	84.2	197	5000	64
2011/3/16 5:30	0.1	4590	60.9	78	83.9	196	5000	64
2011/3/16 6:00	0.09	4590	60.6	78	83.9	196	5000	64
2011/3/16 6:30	0.09	4590	60.2	77	83.6	195	5050	62
2011/3/16 7:00	0.09	4590	59.8	77	83.5	195	5000	62
2011/3/16 7:30	0.07	4488	59.5	76	83.2	194	5050	61
<b>2011/3/16 8:00</b>	<b>0.07</b>	<b>4422</b>	<b>59.0</b>	<b>77</b>	<b>82.8</b>	<b>194</b>	<b>5050</b>	<b>61</b>
2011/3/16 8:30								
2011/3/16 9:00								
2011/3/16 9:30								
2011/3/16 10:00								
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

2011年3月16日 0時00分 2F-4号機

2F-1号機

時間	炉圧 (MPa)	炉水位 (mm) 停止時	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.12	7200	58.6	67	77.9	186	3467	42
2011/3/16 0:30	0.12	7200	58.1	66	77.6	184	3392	41
2011/3/16 1:00	0.12	7000	58	65	77.4	183	3308	41
2011/3/16 1:30	0.12	7000	57.5	65	77.1	181	3222	41
2011/3/16 2:00	0.12	7000	57.1	64	77	179	3138	41
2011/3/16 2:30	0.12	7000	56.9	63	76.6	178	3059	41
2011/3/16 3:00	0.12	7000	56.6	62	76.2	176	2965	41
2011/3/16 3:30	0.12	7000	56.5	62	76.3	175	2902	41
2011/3/16 4:00	0.12	7000	56.1	59	75.9	172	2768	41
2011/3/16 4:30	0.12	7000	56	59	75.7	171	2710	41
2011/3/16 5:00	0.11	7000	55.8	58	75.4	170	2640	41
2011/3/16 5:30	0.12	6950	55.5	57	75.3	168	2553	41
2011/3/16 6:00	0.11	6950	55.3	56	74.8	166	2452	41
2011/3/16 6:30	0.11	6950	55.2	56	74.9	166	2412	41
2011/3/16 7:00	0.11	6950	55	55	74.7	164	2326	41
2011/3/16 7:30	0.11	6950	54.8	54	74.4	162	2227	41
2011/3/16 8:00	0.11	6950	54.6	53	74.2	161	2148	41
2011/3/16 8:30	0.11	6950	54.3	52	73.9	158	2038	41
2011/3/16 9:00								
2011/3/16 9:30								
2011/3/16 10:00								
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

「炉水温度」については、3月15日 19:30以降「給水ノズル温度」を採取しているため、採取していない「炉圧換算温度」の記載を削除します。

2F-2号機

時間	炉圧 (MPa)	炉水位 (mm) 停止時	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.09	7200	56.1	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	50	81.2	152	3400	35
2011/3/16 2:00	0.09	7300	54	48.8	80.8	149	3200	35
2011/3/16 2:30	0.08	7300	53.7	47.8	80.7	148	3100	35
2011/3/16 3:00	0.08	7400	52.7	46.6	80.5	147	3000	36
2011/3/16 3:30	0.08	7400	52.9	45.6	80.4	147	3000	36
2011/3/16 4:00	0.08	7400	52.9	43.4	80.2	145	2800	36
2011/3/16 4:30	0.07	7500	52.3	42.8	80	145	2700	36
2011/3/16 5:00	0.07	7450	52.3	41.8	79.7	144	2600	36
2011/3/16 5:30	0.07	7450	52.4	41.2	79.6	143	2500	36
2011/3/16 6:00	0.06	7450	54.2	40.6	79.4	142	2400	36
2011/3/16 6:30	0.06	7450	54	40.3	79.2	142	2400	36
2011/3/16 7:00	0.06	7450	54.5	39.6	78.8	142	2350	36
2011/3/16 7:30	0.06	7450	53.5	39.3	78.6	141	2300	36
2011/3/16 8:00	0.06	7450	55.2	38.7	78.4	140	2250	36
<b>2011/3/16 8:30</b>	<b>0.06</b>	<b>7400</b>	<b>54.8</b>	<b>38.1</b>	<b>78</b>	<b>140</b>	<b>2200</b>	<b>36</b>
2011/3/16 9:00								
2011/3/16 9:30								
2011/3/16 10:00								
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

「炉水温度」については、3月15日 19:30以降「給水ノズル温度」を採取しているため、採取していない「炉圧換算温度」の記載を削除します。







2F-1号機

時間	炉圧 (MPa)	炉水位 (mm) 停止時	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.12	7200	58.6	67	77.9	186	3467	42
2011/3/16 0:30	0.12	7200	58.1	66	77.6	184	3392	41
2011/3/16 1:00	0.12	7000	58	65	77.4	183	3308	41
2011/3/16 1:30	0.12	7000	57.5	65	77.1	181	3222	41
2011/3/16 2:00	0.12	7000	57.1	64	77	179	3138	41
2011/3/16 2:30	0.12	7000	56.9	63	76.6	178	3059	41
2011/3/16 3:00	0.12	7000	56.6	62	76.2	176	2965	41
2011/3/16 3:30	0.12	7000	56.5	62	76.3	175	2902	41
2011/3/16 4:00	0.12	7000	56.1	59	75.9	172	2768	41
2011/3/16 4:30	0.12	7000	56	59	75.7	171	2710	41
2011/3/16 5:00	0.11	7000	55.8	58	75.4	170	2640	41
2011/3/16 5:30	0.12	6950	55.5	57	75.3	168	2553	41
2011/3/16 6:00	0.12	6950	55.3	56	74.8	166	2452	41
2011/3/16 6:30	0.11	6950	55.2	56	74.9	166	2412	41
2011/3/16 7:00	0.11	6950	55	55	74.7	164	2326	41
2011/3/16 7:30	0.11	6950	54.8	54	74.4	162	2227	41
2011/3/16 8:00	0.11	6950	54.6	53	74.2	161	2148	41
2011/3/16 8:30	0.11	6950	54.3	52	73.9	158	2038	41
2011/3/16 9:00	0.11	6950	54.2	51	73.7	157	1978	41
2011/3/16 9:30	0.11	6900	54	52	73.5	156	1908	41
2011/3/16 10:00	0.11	6900	53.8	51	73.3	154	1845	41
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

「炉水温度」については、3月15日 19:30以降「給水ノズル温度」を採取しているため、採取していない「炉圧換算温度」の記載を削除します。

2011年3月16日 10時14分 炉内温度計 2F-1号機

2F-2号機

時間	炉圧 (MPa)	炉水位 (mm) 停止時	炉水温度(°C) 給水ノズル温度	D/W圧力 (kPa)	D/W温度 (°C)	S/C圧力 (kPa abs)	S/C水位 (mm)	S/C温度 (°C)
2011/3/16 0:00	0.09	7200	56.1	53.8	81.7	159	3700	36
2011/3/16 0:30	0.08	7200	55.6	52.2	81.4	156	3550	35
2011/3/16 1:00	0.09	7200	55.1	51.3	81.3	154	3500	35
2011/3/16 1:30	0.08	7200	55.4	50	81.2	152	3400	35
2011/3/16 2:00	0.09	7300	54	48.8	80.8	149	3200	35
2011/3/16 2:30	0.08	7300	53.7	47.8	80.7	148	3100	35
2011/3/16 3:00	0.08	7400	52.7	46.6	80.5	147	3000	36
2011/3/16 3:30	0.08	7400	52.9	45.6	80.4	147	3000	36
2011/3/16 4:00	0.08	7400	52.9	43.4	80.2	145	2800	36
2011/3/16 4:30	0.07	7500	52.3	42.8	80	145	2700	36
2011/3/16 5:00	0.07	7450	52.3	41.8	79.7	144	2600	36
2011/3/16 5:30	0.07	7450	52.4	41.2	79.6	143	2500	36
2011/3/16 6:00	0.06	7450	54.2	40.6	79.4	142	2400	36
2011/3/16 6:30	0.06	7450	54	40.3	79.2	142	2400	36
2011/3/16 7:00	0.06	7450	54.5	39.6	78.8	142	2350	36
2011/3/16 7:30	0.06	7450	53.5	39.3	78.6	141	2300	36
2011/3/16 8:00	0.06	7450	55.2	38.7	78.4	140	2250	36
2011/3/16 8:30	0.06	7400	54.8	38.1	78	140	2200	36
2011/3/16 9:00	0.06	7350	54.2	37.8	77.6	140	2150	36
2011/3/16 9:30	0.05	7350	54	38.1	77.4	139	2050	36
2011/3/16 10:00	0.05	7400	54.5	36.8	77.1	139	2050	36
2011/3/16 10:30								
2011/3/16 11:00								
2011/3/16 11:30								
2011/3/16 12:00								
2011/3/16 12:30								
2011/3/16 13:00								
2011/3/16 13:30								
2011/3/16 14:00								
2011/3/16 14:30								
2011/3/16 15:00								
2011/3/16 15:30								
2011/3/16 16:00								
2011/3/16 16:30								
2011/3/16 17:00								
2011/3/16 17:30								

「炉水温度」については、3月15日 19:30以降「給水ノズル温度」を採取しているため、採取していない「炉圧換算温度」の記載を削除します。







# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 12:00	0.05	7350	53.1	37.2	75.9	138	2050	34
2011/3/16 12:30	0.05	7350	53.1	36.9	75.8	138	2050	34
2011/3/16 13:00	0.03	7200	52.3	36.6	75.6	137	2050	34
2011/3/16 13:30	0.03	7100	53.2	35.9	75.3	137	2000	34
2011/3/16 14:00	0.03	7100	52.5	35.3	75.1	137	1950	34
2011/3/16 14:30	0.03	7050	52.8	35.0	75.1	136	1900	33
2011/3/16 15:00	0.03	7050	52.1	34.7	74.7	135	1850	33
2011/3/16 15:30	0.03	7050	52.8	34.1	74.6	135	1800	33
2011/3/16 16:00	0.03	7050	52.3	33.4	74.4	134	1800	33
2011/3/16 16:30	0.03	7000	51.8	33.1	74.3	134	1750	33
2011/3/16 17:00	0.03	7000	52.2	32.5	73.9	133	1650	32
2011/3/16 17:30	0.03	7000	51.6	32.2	73.8	133	1600	32
<b>2011/3/16 18:00</b>	<b>0.03</b>	<b>7000</b>	<b>51.8</b>	<b>31.6</b>	<b>73.8</b>	<b>133</b>	<b>1600</b>	<b>32</b>
2011/3/16 18:30								
2011/3/16 19:00								
2011/3/16 19:30								
2011/3/16 20:00								
2011/3/16 20:30								
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								

NO. 1010

水素/酸素/空気/水

2011年 3月17日 10時17分

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 12:00	0.04	3350	27.9	32	57.6	125	-35	44
2011/3/16 12:30	0.04	3350	27.9	32	57.6	126	-35	44
2011/3/16 13:00	0.04	3351	27.9	32	57.5	126	-35	44
2011/3/16 13:30	0.04	3350	27.9	32	57.5	125	-35	44
2011/3/16 14:00	0.04	3350	27.9	32	57.4	125	-36	44
2011/3/16 14:30	0.04	3350	27.9	32	57.4	125	-36	44
2011/3/16 15:00	0.04	3350	27.8	32	57.4	125	-36	44
2011/3/16 15:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:00	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 17:00	0.04	3350	27.8	31	57.2	125	-38	41
2011/3/16 17:30	0.04	3348	27.7	31	57.0	125	-38	43
2011/3/16 18:00	0.04	3337	27.7	35	56.5	125	-21	43
2011/3/16 18:30								
2011/3/16 19:00								
2011/3/16 19:30								
2011/3/16 20:00								
2011/3/16 20:30								
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								

NO. 1010 R. 12

水素ガス供給装置

2011年3月17日

# 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アブセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 12:00	0.09	4589	55.9	72	81.2	190	5000	57
2011/3/16 12:30	0.08	4431	55.7	69	81.0	184	4700	56
2011/3/16 13:00	0.08	4419	55.4	64	80.9	174	4150	56
2011/3/16 13:30	0.09	4439	55.2	60	80.6	165	3600	56
2011/3/16 14:00	0.09	4447	55.1	59	80.5	163	3550	56
2011/3/16 14:30	0.10	4589	56.2	60	80.4	164	3550	55
2011/3/16 15:00	0.11	4829	57.1	59	80.3	163	3500	55
2011/3/16 15:30	0.15	4830	56.2	58	79.7	161	3400	55
2011/3/16 16:00	0.16	4830	54.8	57	79.5	160	3400	55
2011/3/16 16:30	0.16	4830	53.9	57	79.2	159	3350	55
2011/3/16 17:00	0.15	4830	53.4	55	79.0	157	3000	54
2011/3/16 17:30	0.13	4830	53.1	52	78.7	154	3000	54
2011/3/16 18:00	0.13	4830	51.8	52	78.6	153	3000	53
2011/3/16 18:30								
2011/3/16 19:00								
2011/3/16 19:30								
2011/3/16 20:00								
2011/3/16 20:30								
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								

No. 1010 1.13

水素/水素/水素/水素

2011年3月17日 10時17分



# 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.10	6750	51.8	42	71.4	144	1112	38
2011/3/16 15:30	0.10	6750	51.5	42	71.1	143	1032	38
2011/3/16 16:00	0.10	6750	51.3	41	71.0	143	960	37
2011/3/16 16:30	0.10	6750	51.1	40	70.7	142	889	37
2011/3/16 17:00	0.08	6600	50.9	38	70.5	140	895	37
2011/3/16 17:30	0.08	6600	50.8	38	70.4	139	896	37
2011/3/16 18:00	0.09	6600	50.6	37	70.3	139	896	37
2011/3/16 18:30	0.09	6600	50.5	37	70.0	139	895	36
2011/3/16 19:00	0.09	6600	50.3	37	69.8	138	893	36
2011/3/16 19:30	0.09	6600	50.1	36	69.6	138	893	36
2011/3/16 20:00	0.09	6600	49.9	36	69.4	138	897	36
2011/3/16 20:30								
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

No. 1632 P. 1

東京電力(株)原子力発電部

2011年3月17日 00:14:11

# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.03	7050	52.1	34.7	74.7	135	1850	33
2011/3/16 15:30	0.03	7050	52.8	34.1	74.6	135	1800	33
2011/3/16 16:00	0.03	7050	52.3	33.4	74.4	134	1800	33
2011/3/16 16:30	0.03	7000	51.8	33.1	74.3	134	1750	33
2011/3/16 17:00	0.03	7000	52.2	32.5	73.9	133	1650	32
2011/3/16 17:30	0.03	7000	51.6	32.2	73.8	133	1600	32
2011/3/16 18:00	0.03	7000	51.8	31.6	73.8	133	1600	32
2011/3/16 18:30	0.05	7200	51.2	31.3	73.5	132	1550	32
2011/3/16 19:00	0.04	7200	50.4	30.9	73.3	132	1550	32
2011/3/16 19:30	0.03	7000	50.4	30.3	73.1	132	1500	32
2011/3/16 20:00	0.03	7000	50.8	30.0	72.9	131	1450	32
2011/3/16 20:30								
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

NO. 1022

不明電圧/不明電圧/不明電圧

不明電圧/不明電圧/不明電圧

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.04	3350	27.8	32	57.4	125	-36	44
2011/3/16 15:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:00	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 17:00	0.04	3350	27.8	31	57.2	125	-38	41
2011/3/16 17:30	0.04	3348	27.7	31	57.0	125	-38	43
2011/3/16 18:00	0.04	3337	27.7	35	56.5	125	-21	43
2011/3/16 18:30	0.04	3338	27.7	35	56.2	126	-22	43
2011/3/16 19:00	0.04	3338	27.7	35	56.0	126	-22	43
2011/3/16 19:30	0.04	3338	27.6	34	55.9	126	-22	43
2011/3/16 20:00	0.04	3338	27.6	34	55.6	125	-24	43
2011/3/16 20:30								
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								



# 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.10	6750	51.8	42	71.4	144	1112	38
2011/3/16 15:30	0.10	6750	51.5	42	71.1	143	1032	38
2011/3/16 16:00	0.10	6750	51.3	41	71.0	143	960	37
2011/3/16 16:30	0.10	6750	51.1	40	70.7	142	889	37
2011/3/16 17:00	0.08	6600	50.9	38	70.5	140	895	37
2011/3/16 17:30	0.08	6600	50.8	38	70.4	139	896	37
2011/3/16 18:00	0.09	6600	50.6	37	70.3	139	896	37
2011/3/16 18:30	0.09	6600	50.5	37	70.0	139	895	36
2011/3/16 19:00	0.09	6600	50.3	37	69.8	138	893	36
2011/3/16 19:30	0.09	6600	50.1	36	69.6	138	893	36
2011/3/16 20:00	0.09	6600	49.9	36	69.4	138	897	36
2011/3/16 20:30	0.09	6600	49.8	36	69.3	138	895	36
2011/3/16 21:00								
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

2011/3/16 15:00 2011/3/16 15:30 2011/3/16 16:00 2011/3/16 16:30 2011/3/16 17:00 2011/3/16 17:30 2011/3/16 18:00 2011/3/16 18:30 2011/3/16 19:00 2011/3/16 19:30 2011/3/16 20:00 2011/3/16 20:30 2011/3/16 21:00 2011/3/16 21:30 2011/3/16 22:00 2011/3/16 22:30 2011/3/16 23:00 2011/3/16 23:30 2011/3/17 0:00 2011/3/17 0:30 2011/3/17 1:00 2011/3/17 1:30 2011/3/17 2:00 2011/3/17 2:30 2011/3/17 3:00 2011/3/17 3:30 2011/3/17 4:00 2011/3/17 4:30 2011/3/17 5:00 2011/3/17 5:30 2011/3/17 6:00 2011/3/17 6:30 2011/3/17 7:00 2011/3/17 7:30 2011/3/17 8:00









◎以後、1日2回の測定を予定

### 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.10	6750	51.8	42	71.4	144	1112	38
2011/3/16 15:30	0.10	6750	51.5	42	71.1	143	1032	38
2011/3/16 16:00	0.10	6750	51.3	41	71.0	143	960	37
2011/3/16 16:30	0.10	6750	51.1	40	70.7	142	889	37
2011/3/16 17:00	0.08	6600	50.9	38	70.5	140	895	37
2011/3/16 17:30	0.08	6600	50.8	38	70.4	139	896	37
2011/3/16 18:00	0.09	6600	50.6	37	70.3	139	896	37
2011/3/16 18:30	0.09	6600	50.5	37	70.0	139	895	36
2011/3/16 19:00	0.09	6600	50.3	37	69.8	138	893	36
2011/3/16 19:30	0.09	6600	50.1	36	69.6	138	893	36
2011/3/16 20:00	0.09	6600	49.9	36	69.4	138	897	36
2011/3/16 20:30	0.09	6600	49.8	36	69.3	138	895	36
2011/3/16 21:00	0.09	6600	49.7	35	69.1	137	892	36
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

2011年 3月10日 21時17分 東京電力(株) 原子力発電部 記録係

No. 1022

P. 1/4

# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.03	7050	52.1	34.7	74.7	135	1850	33
2011/3/16 15:30	0.03	7050	52.8	34.1	74.6	135	1800	33
2011/3/16 16:00	0.03	7050	52.3	33.4	74.4	134	1800	33
2011/3/16 16:30	0.03	7000	51.8	33.1	74.3	134	1750	33
2011/3/16 17:00	0.03	7000	52.2	32.5	73.9	133	1650	32
2011/3/16 17:30	0.03	7000	51.6	32.2	73.8	133	1600	32
2011/3/16 18:00	0.03	7000	51.8	31.6	73.8	133	1600	32
2011/3/16 18:30	0.05	7200	51.2	31.3	73.5	132	1550	32
2011/3/16 19:00	0.04	7200	50.4	30.9	73.3	132	1550	32
2011/3/16 19:30	0.03	7000	50.4	30.3	73.1	132	1500	32
2011/3/16 20:00	0.03	7000	50.8	30.0	72.9	131	1450	32
2011/3/16 20:30	0.03	7000	49.5	29.7	72.9	131	1400	31
2011/3/16 21:00	0.03	7000	50.2	29.4	72.6	130	1400	31
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アッセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.04	3350	27.8	32	57.4	125	-36	44
2011/3/16 15:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:00	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 17:00	0.04	3350	27.8	31	57.2	125	-38	41
2011/3/16 17:30	0.04	3348	27.7	31	57.0	125	-38	43
2011/3/16 18:00	0.04	3337	27.7	35	56.5	125	-21	43
2011/3/16 18:30	0.04	3338	27.7	35	56.2	126	-22	43
2011/3/16 19:00	0.04	3338	27.7	35	56.0	126	-22	43
2011/3/16 19:30	0.04	3338	27.6	34	55.9	126	-22	43
2011/3/16 20:00	0.04	3338	27.6	34	55.6	125	-24	43
2011/3/16 20:30	0.04	3338	27.6	34	55.5	125	-25	43
2011/3/16 21:00	0.04	3338	27.5	34	55.5	125	-25	43
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

# 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.11	4829	57.1	59	80.3	163	3500	55
2011/3/16 15:30	0.15	4830	56.2	58	79.7	161	3400	55
2011/3/16 16:00	0.16	4830	54.8	57	79.5	160	3400	55
2011/3/16 16:30	0.16	4830	53.9	57	79.2	159	3350	55
2011/3/16 17:00	0.15	4830	53.4	55	79.0	157	3000	54
2011/3/16 17:30	0.13	4830	53.1	52	78.7	154	3000	54
2011/3/16 18:00	0.13	4830	51.8	52	78.6	153	3000	53
2011/3/16 18:30	0.13	4830	51.0	51	78.6	153	3000	53
2011/3/16 19:00	0.13	4829	50.3	50	78.3	152	3000	52
2011/3/16 19:30	0.13	4829	49.9	50	78.2	152	3000	51
2011/3/16 20:00	0.13	4829	49.3	49	78.0	151	3000	51
2011/3/16 20:30	0.13	4830	48.9	49	77.9	151	3000	50
2011/3/16 21:00	0.13	4829	48.5	49	77.7	151	3000	50
2011/3/16 21:30								
2011/3/16 22:00								
2011/3/16 22:30								
2011/3/16 23:00								
2011/3/16 23:30								
2011/3/17 0:00								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

NO. 1077 1. 4/4

本表用紙(調) 東京電力 5000

2011年 3月16日 21時12分

# 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.10	6750	51.8	42	71.4	144	1112	38
2011/3/16 15:30	0.10	6750	51.5	42	71.1	143	1032	38
2011/3/16 16:00	0.10	6750	51.3	41	71.0	143	960	37
2011/3/16 16:30	0.10	6750	51.1	40	70.7	142	889	37
2011/3/16 17:00	0.08	6600	50.9	38	70.5	140	895	37
2011/3/16 17:30	0.08	6600	50.8	38	70.4	139	896	37
2011/3/16 18:00	0.09	6600	50.6	37	70.3	139	896	37
2011/3/16 18:30	0.09	6600	50.5	37	70.0	139	895	36
2011/3/16 19:00	0.09	6600	50.3	37	69.8	138	893	36
2011/3/16 19:30	0.09	6600	50.1	36	69.6	138	893	36
2011/3/16 20:00	0.09	6600	49.9	36	69.4	138	897	36
2011/3/16 20:30	0.09	6600	49.8	36	69.3	138	895	36
2011/3/16 21:00	0.09	6600	49.7	35	69.1	137	892	36
2011/3/16 21:30	0.09	6600	49.5	35	69.0	137	890	35
2011/3/16 22:30								
2011/3/16 23:30								
2011/3/17 0:30								
2011/3/17 1:00								
2011/3/17 1:30								
2011/3/17 2:00								
2011/3/17 2:30								
2011/3/17 3:00								
2011/3/17 3:30								
2011/3/17 4:00								
2011/3/17 4:30								
2011/3/17 5:00								
2011/3/17 5:30								
2011/3/17 6:00								
2011/3/17 6:30								
2011/3/17 7:00								
2011/3/17 7:30								
2011/3/17 8:00								

11.11.11

東京電力 原子力発電所 福島

2011年 3月16日 4時30分









22:00 2F.プラントパラメータ 1/4  
 2F-1号機 ※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.10	6750	51.8	42	71.4	144	1112	38
2011/3/16 15:30	0.10	6750	51.5	42	71.1	143	1032	38
2011/3/16 16:00	0.10	6750	51.3	41	71.0	143	960	37
2011/3/16 16:30	0.10	6750	51.1	40	70.7	142	889	37
2011/3/16 17:00	0.08	6600	50.9	38	70.5	140	895	37
2011/3/16 17:30	0.08	6600	50.8	38	70.4	139	896	37
2011/3/16 18:00	0.09	6600	50.6	37	70.3	139	896	37
2011/3/16 18:30	0.09	6600	50.5	37	70.0	139	895	36
2011/3/16 19:00	0.09	6600	50.3	37	69.8	138	893	36
2011/3/16 19:30	0.09	6600	50.1	36	69.6	138	893	36
2011/3/16 20:00	0.09	6600	49.9	36	69.4	138	897	36
2011/3/16 20:30	0.09	6600	49.8	36	69.3	138	895	36
2011/3/16 21:00	0.09	6600	49.7	35	69.1	137	892	36
2011/3/16 21:30	0.09	6600	49.5	35	69.0	137	890	35
2011/3/16 22:00	0.09	6600	49.4	35	68.7	137	889	35
2011/3/16 23:00								
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 5:00								
2011/3/17 6:00								
2011/3/17 7:00								
2011/3/17 8:00								
2011/3/17 9:00								
2011/3/17 10:00								
2011/3/17 11:00								
2011/3/17 12:00								
2011/3/17 13:00								
2011/3/17 14:00								
2011/3/17 15:00								



3/4

2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アッブセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.04	3350	27.8	32	57.4	125	-36	44
2011/3/16 15:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:00	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 17:00	0.04	3350	27.8	31	57.2	125	-38	41
2011/3/16 17:30	0.04	3348	27.7	31	57.0	125	-38	43
2011/3/16 18:00	0.04	3337	27.7	35	56.5	125	-21	43
2011/3/16 18:30	0.04	3338	27.7	35	56.2	126	-22	43
2011/3/16 19:00	0.04	3338	27.7	35	56.0	126	-22	43
2011/3/16 19:30	0.04	3338	27.6	34	55.9	126	-22	43
2011/3/16 20:00	0.04	3338	27.6	34	55.6	125	-24	43
2011/3/16 20:30	0.04	3338	27.6	34	55.5	125	-25	43
2011/3/16 21:00	0.04	3338	27.5	34	55.5	125	-25	43
2011/3/16 21:30	0.04	3338	27.5	34	55.3	125	-25	43
2011/3/16 22:00	0.04	3337	27.4	34	55.1	125	-26	43
2011/3/16 23:00								
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 4:59								
2011/3/17 5:59								
2011/3/17 6:59								
2011/3/17 7:59								
2011/3/17 8:59								
2011/3/17 9:59								
2011/3/17 10:59								
2011/3/17 11:59								
2011/3/17 12:59								
2011/3/17 13:59								
2011/3/17 14:59								

NO. 140Y

水素電圧計/原丁/出見 気流計

2011年 3月10日 22時7分

4/4

2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.11	4829	57.1	59	80.3	163	3500	55
2011/3/16 15:30	0.15	4830	56.2	58	79.7	161	3400	55
2011/3/16 16:00	0.16	4830	54.8	57	79.5	160	3400	55
2011/3/16 16:30	0.16	4830	53.9	57	79.2	159	3350	55
2011/3/16 17:00	0.15	4830	53.4	55	79.0	157	3000	54
2011/3/16 17:30	0.13	4830	53.1	52	78.7	154	3000	54
2011/3/16 18:00	0.13	4830	51.8	52	78.6	153	3000	53
2011/3/16 18:30	0.13	4830	51.0	51	78.6	153	3000	53
2011/3/16 19:00	0.13	4829	50.3	50	78.3	152	3000	52
2011/3/16 19:30	0.13	4829	49.9	50	78.2	152	3000	51
2011/3/16 20:00	0.13	4829	49.3	49	78.0	151	3000	51
2011/3/16 20:30	0.13	4830	48.9	49	77.9	151	3000	50
2011/3/16 21:00	0.13	4829	48.5	49	77.7	151	3000	50
2011/3/16 21:30	0.10	4829	48.0	50	77.4	151	3000	50
2011/3/16 22:00	0.10	4829	47.9	50	77.2	151	3000	49
2011/3/16 23:00								
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 5:00								
2011/3/17 6:00								
2011/3/17 7:00								
2011/3/17 8:00								
2011/3/17 9:00								
2011/3/17 10:00								
2011/3/17 11:00								
2011/3/17 12:00								
2011/3/17 13:00								
2011/3/17 14:00								
2011/3/17 15:00								

2011年3月16日 15時00分 2F-4号機 炉内水位測定記録表

# 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.10	6750	51.8	42	71.4	144	1112	38
2011/3/16 15:30	0.10	6750	51.5	42	71.1	143	1032	38
2011/3/16 16:00	0.10	6750	51.3	41	71.0	143	960	37
2011/3/16 16:30	0.10	6750	51.1	40	70.7	142	889	37
2011/3/16 17:00	0.08	6600	50.9	38	70.5	140	895	37
2011/3/16 17:30	0.08	6600	50.8	38	70.4	139	896	37
2011/3/16 18:00	0.09	6600	50.6	37	70.3	139	896	37
2011/3/16 18:30	0.09	6600	50.5	37	70.0	139	895	36
2011/3/16 19:00	0.09	6600	50.3	37	69.8	138	893	36
2011/3/16 19:30	0.09	6600	50.1	36	69.6	138	893	36
2011/3/16 20:00	0.09	6600	49.9	36	69.4	138	897	36
2011/3/16 20:30	0.09	6600	49.8	36	69.3	138	895	36
2011/3/16 21:00	0.09	6600	49.7	35	69.1	137	892	36
2011/3/16 21:30	0.09	6600	49.5	35	69.0	137	890	35
2011/3/16 22:00	0.09	6600	49.4	35	68.7	137	889	35
2011/3/16 23:00	0.09	6600	49.1	35	68.4	137	892	35
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 5:00								
2011/3/17 6:00								
2011/3/17 7:00								
2011/3/17 8:00								
2011/3/17 9:00								
2011/3/17 10:00								
2011/3/17 11:00								
2011/3/17 12:00								
2011/3/17 13:00								
2011/3/17 14:00								
2011/3/17 15:00								

# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.03	7050	52.1	34.7	74.7	135	1850	33
2011/3/16 15:30	0.03	7050	52.8	34.1	74.6	135	1800	33
2011/3/16 16:00	0.03	7050	52.3	33.4	74.4	134	1800	33
2011/3/16 16:30	0.03	7000	51.8	33.1	74.3	134	1750	33
2011/3/16 17:00	0.03	7000	52.2	32.5	73.9	133	1650	32
2011/3/16 17:30	0.03	7000	51.6	32.2	73.8	133	1600	32
2011/3/16 18:00	0.03	7000	51.8	31.6	73.8	133	1600	32
2011/3/16 18:30	0.05	7200	51.2	31.3	73.5	132	1550	32
2011/3/16 19:00	0.04	7200	50.4	30.9	73.3	132	1550	32
2011/3/16 19:30	0.03	7000	50.4	30.3	73.1	132	1500	32
2011/3/16 20:00	0.03	7000	50.8	30.0	72.9	131	1450	32
2011/3/16 20:30	0.03	7000	49.5	29.7	72.9	131	1400	31
2011/3/16 21:00	0.03	7000	50.2	29.4	72.6	130	1400	31
2011/3/16 21:30	0.03	6950	50.2	28.8	72.4	130	1350	31
2011/3/16 22:00	0.03	6950	49.0	28.4	72.2	129	1300	31
2011/3/16 23:00	0.03	6900	49.2	27.5	71.8	128	1200	31
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 4:59								
2011/3/17 5:59								
2011/3/17 6:59								
2011/3/17 7:59								
2011/3/17 8:59								
2011/3/17 9:59								
2011/3/17 10:59								
2011/3/17 11:59								
2011/3/17 12:59								
2011/3/17 13:59								
2011/3/17 14:59								

## 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アッパセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.04	3350	27.8	32	57.4	125	-36	44
2011/3/16 15:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:00	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 16:30	0.04	3350	27.8	32	57.3	125	-36	44
2011/3/16 17:00	0.04	3350	27.8	31	57.2	125	-38	41
2011/3/16 17:30	0.04	3348	27.7	31	57.0	125	-38	43
2011/3/16 18:00	0.04	3337	27.7	35	56.5	125	-21	43
2011/3/16 18:30	0.04	3338	27.7	35	56.2	126	-22	43
2011/3/16 19:00	0.04	3338	27.7	35	56.0	126	-22	43
2011/3/16 19:30	0.04	3338	27.6	34	55.9	126	-22	43
2011/3/16 20:00	0.04	3338	27.6	34	55.6	125	-24	43
2011/3/16 20:30	0.04	3338	27.6	34	55.5	125	-25	43
2011/3/16 21:00	0.04	3338	27.5	34	55.5	125	-25	43
2011/3/16 21:30	0.04	3338	27.5	34	55.3	125	-25	43
2011/3/16 22:00	0.04	3337	27.4	34	55.1	125	-26	43
<b>2011/3/16 23:00</b>	<b>0.04</b>	<b>3337</b>	<b>27.3</b>	<b>33</b>	<b>55.0</b>	<b>125</b>	<b>-29</b>	<b>43</b>
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 4:59								
2011/3/17 5:59								
2011/3/17 6:59								
2011/3/17 7:59								
2011/3/17 8:59								
2011/3/17 9:59								
2011/3/17 10:59								
2011/3/17 11:59								
2011/3/17 12:59								
2011/3/17 13:59								
2011/3/17 14:59								

## 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/16 15:00	0.11	4829	57.1	59	80.3	163	3500	55
2011/3/16 15:30	0.15	4830	56.2	58	79.7	161	3400	55
2011/3/16 16:00	0.16	4830	54.8	57	79.5	160	3400	55
2011/3/16 16:30	0.16	4830	53.9	57	79.2	159	3350	55
2011/3/16 17:00	0.15	4830	53.4	55	79.0	157	3000	54
2011/3/16 17:30	0.13	4830	53.1	52	78.7	154	3000	54
2011/3/16 18:00	0.13	4830	51.8	52	78.6	153	3000	53
2011/3/16 18:30	0.13	4830	51.0	51	78.6	153	3000	53
2011/3/16 19:00	0.13	4829	50.3	50	78.3	152	3000	52
2011/3/16 19:30	0.13	4829	49.9	50	78.2	152	3000	51
2011/3/16 20:00	0.13	4829	49.3	49	78.0	151	3000	51
2011/3/16 20:30	0.13	4830	48.9	49	77.9	151	3000	50
2011/3/16 21:00	0.13	4829	48.5	49	77.7	151	3000	50
2011/3/16 21:30	0.10	4829	48.0	50	77.4	151	3000	50
2011/3/16 22:00	0.10	4829	47.9	50	77.2	151	3000	49
2011/3/16 23:00	0.10	4829	47.6	50	77.1	151	3000	49
2011/3/17 0:00								
2011/3/17 1:00								
2011/3/17 2:00								
2011/3/17 3:00								
2011/3/17 4:00								
2011/3/17 5:00								
2011/3/17 6:00								
2011/3/17 7:00								
2011/3/17 8:00								
2011/3/17 9:00								
2011/3/17 10:00								
2011/3/17 11:00								
2011/3/17 12:00								
2011/3/17 13:00								
2011/3/17 14:00								
2011/3/17 15:00								