













2F-1号機







2F-2号機



2F-3号機



2F-4号機







2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]





時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/3 0:00	0.04	4100	28.5		29.6	102	2200	22
2011/11/3 2:00	0.04	4100	28.5		29.6	101	2200	22
2011/11/3 4:00	0.04	4100	28.5		29.6	101	2200	22
2011/11/3 6:00	0.04	4100	28.5		29.6	101	2200	22
2011/11/3 8:00	0.04	4150	28.4		29.6	101	2200	22
2011/11/3 10:00	0.04	4150	28.4		29.5	102	2200	22
2011/11/3 12:00	0.04	4150	28.5		29.5	102	2200	22
2011/11/3 14:00	0.04	4150	28.5		29.6	102	2200	22
2011/11/3 16:00	0.04	4150	28.5		29.6	102	2200	22
2011/11/3 18:00	0.04	4150	28.6		29.6	102	2200	22
2011/11/3 20:00	0.04	4150	28.6		29.6	102	2200	22
2011/11/3 22:00	0.04	4200	28.6		29.6	102	2200	22
2011/11/4 0:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 2:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 4:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 6:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 8:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 10:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 12:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 14:00	0.04	4000	28.7		29.6	102	2200	22
2011/11/4 16:00	0.04	4050	28.8		29.6	102	2200	22
2011/11/4 18:00	0.04	4050	28.8		29.5	102	2200	22
2011/11/4 20:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/4 22:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 0:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 2:00	0.03	4050	28.8		29.6	102	2200	22
2011/11/5 4:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 6:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 8:00								
2011/11/5 10:00								
2011/11/5 12:00								
2011/11/5 14:00								
2011/11/5 16:00								
2011/11/5 18:00								
2011/11/5 20:00								
2011/11/5 22:00								
2011/11/6 0:00								

D/W圧力について
 ・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず





2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/3 0:00	0.04	4100	28.5		29.6	102	2200	22
2011/11/3 2:00	0.04	4100	28.5		29.6	101	2200	22
2011/11/3 4:00	0.04	4100	28.5		29.6	101	2200	22
2011/11/3 6:00	0.04	4100	28.5		29.6	101	2200	22
2011/11/3 8:00	0.04	4150	28.4		29.6	101	2200	22
2011/11/3 10:00	0.04	4150	28.4		29.5	102	2200	22
2011/11/3 12:00	0.04	4150	28.5		29.5	102	2200	22
2011/11/3 14:00	0.04	4150	28.5		29.6	102	2200	22
2011/11/3 16:00	0.04	4150	28.5		29.6	102	2200	22
2011/11/3 18:00	0.04	4150	28.6		29.6	102	2200	22
2011/11/3 20:00	0.04	4150	28.6		29.6	102	2200	22
2011/11/3 22:00	0.04	4200	28.6		29.6	102	2200	22
2011/11/4 0:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 2:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 4:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 6:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 8:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 10:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 12:00	0.03	4000	28.7		29.6	102	2200	22
2011/11/4 14:00	0.04	4000	28.7		29.6	102	2200	22
2011/11/4 16:00	0.04	4050	28.8		29.6	102	2200	22
2011/11/4 18:00	0.04	4050	28.8		29.5	102	2200	22
2011/11/4 20:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/4 22:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 0:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 2:00	0.03	4050	28.8		29.6	102	2200	22
2011/11/5 4:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 6:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 8:00	0.03	4050	28.8		29.5	102	2200	22
2011/11/5 10:00	0.04	4100	28.8		29.6	101	2200	22
2011/11/5 12:00	0.04	4100	28.8		29.6	101	2200	22
2011/11/5 14:00								
2011/11/5 16:00								
2011/11/5 18:00								
2011/11/5 20:00								
2011/11/5 22:00								
2011/11/6 0:00								

D/W圧力について
 ・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず