


F1 Issues

As of 20 October, 2015
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Total Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
11 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	9.4
12 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	**< 3.0	-	**13	13
13 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	13
14 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	13	11
15 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	12
16 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	**< 3.0	-	**15	13
17 Oct.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	13

*Total Beta includes K-40 occurring naturally in seawater.
**Additional measurements in consideration of discharge of groundwater through Subdrain and Groundwater drain.



Concentrations of Cs-134, Cs-137, H-3 and total Beta remained low.
Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>