


# F1 Issues

As of 10 November, 2015  
Nuclear Regulation Authority (NRA), Japan

## Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Total Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
1 Nov.	< 1.0	**No samples	< 1.0	No samples	-	-	-	No samples
2 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	3.5	< 3.0	14	11
3 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	12
4 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	9.9
5 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	13
6 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	9.0
7 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	10

\*Total Beta includes K-40 occurring naturally in seawater.  
\*\*Due to bad weather unless otherwise specified.



Concentrations of Cs-134, Cs-137, H-3 and total Beta remained low.  
Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>