

# F1 Issues


As of 17 November, 2015  
Nuclear Regulation Authority (NRA), Japan

## Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Total Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
8 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	11
9 Nov.	< 1.0	**No samples	< 1.0	No samples	< 3.0	No samples	13	No samples
10 Nov.	< 1.0	No samples	< 1.0	No samples	-	No samples	-	No samples
11 Nov.	< 1.0	No samples	< 1.0	No samples	-	No samples	-	No samples
12 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	< 3.0	-	14
13 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	10
14 Nov.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	11

\*Total Beta includes K-40 occurring naturally in seawater.

\*\*Due to bad weather unless otherwise specified.



Concentrations of Cs-134, Cs-137, H-3 and total Beta remained low.  
Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>