

# F1 Issues


As of 1 December, 2015  
Nuclear Regulation Authority (NRA), Japan

## Current Information on Radioactivity in Seawater

| Sampling Date | Cs-134 (Bq/L) |              | Cs-137 (Bq/L) |            | H-3 (Bq/L) |       | *Total Beta (Bq/L) |            |
|---------------|---------------|--------------|---------------|------------|------------|-------|--------------------|------------|
|               | T-1           | T-2-1        | T-1           | T-2-1      | T-1        | T-2-1 | T-1                | T-2-1      |
| 22 Nov.       | < 1.0         | < 1.0        | < 1.0         | < 1.0      | -          | -     | -                  | 13         |
| 23 Nov.       | < 1.0         | < 1.0        | < 1.0         | < 1.0      | < 3.0      | < 3.0 | 12                 | 11         |
| 24 Nov.       | < 1.0         | < 1.0        | < 1.0         | < 1.0      | -          | -     | -                  | 10         |
| 25 Nov.       | < 1.0         | < 1.0        | < 1.0         | < 1.0      | -          | -     | -                  | 13         |
| 26 Nov.       | < 1.0         | **No samples | < 1.0         | No samples | -          | -     | -                  | No samples |
| 27 Nov.       | < 1.0         | No samples   | < 1.0         | No samples | -          | -     | -                  | No samples |
| 28 Nov.       | < 1.0         | < 1.0        | < 1.0         | < 1.0      | -          | -     | -                  | 11         |

\*Total Beta includes K-40 occurring naturally in seawater.

\*\*Due to bad weather unless otherwise specified.



Concentrations of Cs-134, Cs-137, H-3 and total Beta remained low.  
Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>