


F1 Issues

As of 5 April, 2016
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Total Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
27 Mar.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
28 Mar.	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	13	13
29 Mar.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	15
30 Mar.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
31 Mar.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
1 Apr.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
2 Apr.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	9.9

*Total Beta includes K-40 occurring naturally in seawater.



Concentrations of Cs-134, Cs-137, H-3 and total Beta remained low.
Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>