


F1 Issues

As of 5 July, 2016
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Gross Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
26 Jun.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	8.0
27 Jun.	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	12	9.4
28 Jun.	1.0	< 1.0	7.0	< 1.0	–	–	–	7.6
29 Jun.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	13
30 Jun.	< 1.0	< 1.0	2.1	< 1.0	–	–	–	10
1 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
2 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	14

*Gross Beta includes K-40 occurring naturally in seawater.



Concentrations of Cs-134, Cs-137, H-3 and Gross Beta remained low.

Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>