


F1 Issues

As of 12 July, 2016
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Gross Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
3 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
4 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	7.3	10
5 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	12
6 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	9.0
7 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	8.0
8 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	12
9 Jul.	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	12

*Gross Beta includes K-40 occurring naturally in seawater.



Concentrations of Cs-134, Cs-137, H-3 and Gross Beta remained low.
Details of monitoring results are indicated in the following URL:
<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>