


F1 Issues

As of 16 August, 2016
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Gross Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
7 Aug.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	11
8 Aug.	No samples due to bad weather							
9 Aug.	No samples due to bad weather							
10 Aug.	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	8.2	9.7
11 Aug.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	11
12 Aug.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	13
13 Aug.	< 1.0	< 1.0	< 1.0	< 1.0	-	-	-	9.2

*Gross Beta includes K-40 occurring naturally in seawater.



Concentrations of Cs-134, Cs-137, H-3 and Gross Beta remained low.
Details of monitoring results are indicated in the following URL:

<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>