


F1 Issues

As of 6 September, 2016
Nuclear Regulation Authority (NRA), Japan

Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Gross Beta (Bq/L)	
	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1	T-1	T-2-1
28 Aug.	< 1.0	**No samples	< 1.0	No samples	–	–	–	No samples
29 Aug.	< 1.0	< 1.0	< 1.0	1.3	< 3.0	< 3.0	9.7	10
30 Aug.	No samples due to bad weather							
31 Aug.	< 1.0	No samples	< 1.0	No samples	–	–	–	No samples
1 Sep.	< 1.0	No samples	< 1.0	No samples	–	–	–	No samples
2 Sep.	< 1.0	No samples	< 1.0	No samples	–	–	–	No samples
3 Sep.	< 1.0	No samples	< 1.0	No samples	–	–	–	No samples

*Gross Beta includes K-40 occurring naturally in seawater.
**Due to bad weather unless otherwise specified.



Concentrations of Cs-134, Cs-137, H-3 and Gross Beta remained low.
Details of monitoring results are indicated in the following URL:
<http://radioactivity.nsr.go.jp/en/list/295/list-1.html>