


# F1 Issues

As of 4 July 2017  
Nuclear Regulation Authority (NRA), Japan

## Current Information on Radioactivity in Seawater

Sampling Date	Cs-134 (Bq/L)		Cs-137 (Bq/L)		H-3 (Bq/L)		*Gross Beta (Bq/L)	
	T-1	T-2	T-1	T-2	T-1	T-2	T-1	T-2
25 June	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	10
26 June	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 3.0	8.9	12
27 June	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	9.2
28 June	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	11
29 June	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	15
30 June	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	9.1
1 July	< 1.0	< 1.0	< 1.0	< 1.0	–	–	–	8.1

\*Gross Beta includes K-40 occurring naturally in seawater.



Concentrations of Cs-134, Cs-137, H-3 and Gross Beta remained low.

Details of past monitoring results (updated monthly) are open to the public via the following URL.

URL: <http://radioactivity.nsr.go.jp/en/list/295/list-1.html>