



Reducing Risk at Fukushima Dai-ichi NPS

Toyoshi Fuketa
Nuclear Regulation Authority

Workshop on Decommissioning of Nuclear Power Plants

Hotel Grand Hill Ichigaya Tokyo, Japan


April 8, 2015



Introduction

- ✓ According to the amended Nuclear Regulation Act, the NRA designated the Fukushima Dai-ichi Nuclear Power Station as “Disaster-experienced Nuclear Power Plant” on November 7, 2012, which needs special measures to prevent further disaster and to ensure nuclear security.
- ✓ The NRA requested TEPCO to prepare an implementation plan regarding decommissioning processes for Units 1 thru 4, maintaining shut-down status for Units 5 and 6, monitoring plant status for Units 1 thru 6, physical protection, and others.
- ✓ In order to address risk concerns plainly, the NRA produced “Measures for Mid-term Risk Reduction” on February, 2015.

Measures for Mid-term Risk Reduction at TEPCO's Fukushima Daiichi NPS (as of February 2015)






This presentation covers;


- ✓ Most significant concerns are;
 - Water removal and stabilization in underground trenches connected to the reactor turbine buildings on the seaward side,
 - Fuel removal from spent fuel pool of Units 1 thru 4,
 - Water decontamination and management of processed water, and
 - Water levels management in order to reduce inflow of ground water into reactor and turbine buildings.
- ✓ Another several issues regarding the decommissioning.

① Underground Trenches



- ✓ The NRA considers that a risk of water leakage from underground trenches connected to the reactor turbine buildings on the seaward side is most significant.
- ✓ e.g., $\sim 10^{15}$ Bq of Cs-137 in Unit 2 trenches
(estimated in July 2013)



- ①立坑からの閉塞材料投入により、トンネルの閉塞開始。
- ②トンネルを閉塞後に、③立坑の閉塞を実施
- ④立坑B下部の砕石層を閉塞し、閉塞完了



※ポンプで汚染水が抜き取りきれず、残水する可能性が想定され、各立坑に抜き取り口が必要



※施工ステップで色分けをしているが同一材料により打設





Image of the work closing out with each material

Work Progress



as of Feb 6th

	Unit 2	Unit 3	Unit 4
Residual water	~1,890 m ³	~3,480 m ³	~440 m ³
Cemented	~2,610 m ³	~2,320 m ³	~460 m ³





② Spent Fuel Pool




- ✓ Fuel removal from spent fuel pool of Unit 4 was completed on December, 2014. This corresponds to ~49% reduction of spent fuel assemblies in spent fuel pools of Units 1 thru 4.

Unit	1	2	3	4
Capacity	900	1240	1220	1590
SFA	292	587	514	1331
FFA	100	28	52	202
Total	392	615	566	1533

Fuel-handling machine and crane for Unit 3 SFP




Fuel-handling machine and crane for Unit 3 SFP





Fuel removal from Unit 3 SFP

- ✓ To be made with remote-control fuel-handing machine and crane
- ✓ Setting up rail and girder requires manned operation, so precedent arrangements, debris removal, decontamination and additional shielding, are needed.




Relatively high dose rate

Unit 3 SFP Gate




3 Water decontamination

- Contaminated water in R/Bs & T/Bs is treated and injected back to RPVs.
- App. **400m³/day of groundwater** is intruding into R/Bs & T/Bs and it forces the capacity of tanks increase.
- Reactor cooling injection: App.300m³/day



Water decontamination process






Water decontamination system

ALPS	250m ³ /d x 3 units
Improved ALPS	250m ³ /d x 3 units
High-performance ALPS	500m ³ /d x 1 unit
R/O water treatment	500m ³ /d
Mobile Sr removal*	300m ³ /d x 2 units 480m ³ /d x 4 units
SARRY	600m ³ /d x 2 units
Kurion	300m ³ /d x 3 units

*Circulation processing




Water storage








March 12, 2015




Achieving less than 1 mSv/y at border




④ Reduction of groundwater inflow

- ✓ The water level in reactor/turbine buildings must be always lower than ambient groundwater level.
- ✓ The difference between the two levels, however, should be controlled at adequately small in order to reduce the inflow.






Sub-drain and sea-side impermeable wall




	in 314 days	Bq/day
Cs-137	3.8×10^{11}	1.2×10^9
Sr-90	8.5×10^{11}	2.7×10^9

Estimation for a period from 4/16/2014 to 2/23/2015

Land-side impermeable walls







Other issues


- ✓ Protection against earthquake and tsunami
- ✓ Drainage ditches
- ✓ Work environment
- ✓ Facility investigation



Earthquake and tsunami

- ✓ ~270gal and 3.122m; DB at initially licensed in 1966
- ✓ 600gal and OP+14.13m; aseismic design back-check in 2009 and re-evaluation in 2012 for outer-rise earthquake
- ✓ 900gal and OP+26.3m; under evaluation

Water in drainage ditches



Estimation for a period
from 4/16/2014 to 2/23/2015

Ditch "K"	in 314 days	Bq/day
Cs-137	1.5×10^{11}	4.8×10^8
Sr-90	1.5×10^{10}	4.7×10^7

Work environment



e.g., reduction of work area with full-face mask

Action to be made toward designating area colored with pink as an area in which wearing full-face mask is not necessary

- (1) Series of dust monitor equipment will be installed at appropriate spots and data from these monitors will be transmitted to the anti-earthquake building so as to monitor dust level in the building. (February or March 2015)
- (2) Get permission from the government after confirming that dust level is low enough. (March or April 2015)
- (3) Certain area is controlled as an area in which wearing full-face mask is not necessary. (In operation in May 2015)



In tank area, risk of taking concentrated salt water (highly contaminated with Sr) should be considered in addition to the risk regarding dust level.

-  Full-face mask unnecessary area
-  Future operation of Full-face mask unnecessary area is considered

- Equipment for monitoring dust level in an area in which wearing full-face mask is not necessary (5 spots)
- Equipment for monitoring dust level at vicinity of reactors (3 spots)
- Equipment to be installed additionally by Mach 2015 (2 spots)



Total of 10 areas are to be monitored

Examining Inside of the Facilities


- Understanding the inside of R/Bs, Primary Containment Vessels (PCVs) and Reactor Pressure Vessels (RPVs)
 - Investigation of the flow paths in R/Bs, etc.
 - Analysis of water passing through the reactors
 - Analysis of the contamination of the inside of R/Bs, etc.
 - Direct observation of the inside of PCVs and RPVs

Unit 1

Investigation of water leak location from PCV done by TEPCO



Surface boat



Leak flow



Source: TEPCO
handouts_131113_11-e.pdf



NRA's challenge

- ✓ In order to keep reducing the risk existing at the Fukushima Dai-ichi, the NRA should regulate and promote the decommissioning processes at the same time.
- ✓ The important challenge is to maintain harmonization between the implementation and acceleration of the decommissioning and the protection of people and the environment during the processes.