

# Japan's Nuclear Regulation against Natural Hazards after the Fukushima Daiichi Accident

**Akira ISHIWATARI**

Commissioner of Nuclear  
Regulation Authority,  
Japan (D.Sc., Geologist)

# Thanks

- ◆ Five years have passed since the March 2011 Fukushima Daiichi nuclear accident. To prevent recurrence of such a disaster, Nuclear Regulation Authority (NRA)\* was established in September 2012. NRA has worked hard for keeping nuclear safety and improving nuclear regulation. NRA expresses sincere thanks to IAEA and its member countries for their kind help in reconstructing Japan after the Fukushima Daiichi accident.

# Thanks


- ◆ I thank IAEA for giving me a chance of this presentation. I am glad to contribute to international nuclear safety by presenting our knowledge learned from experience of the Fukushima accident.
- ◆ Fukushima dictates that “perfect safety” or “ultimate preparedness” does not exist in nuclear safety. We keep going for further improvement of nuclear safety in Japan with international understanding.


# NRA's New Regulation Standards against Natural Hazards after the Fukushima accident (Contents of this Presentation)

- ◆ More stringent standards on **tsunami**
- ◆ Clarification of requirements for **fault** displacement
- ◆ More precise methods to define design basis ground motion (DBGM) by **earthquake**
- ◆ Assessment & monitoring of **volcanic activity**
- ◆ An **example**: Sendai Nuclear Power Plants (NPPs), Kyushu Electric Power Co.


# More stringent Standards on Tsunami

- ◆ Define “Design Basis Tsunami” that exceeds the largest in the historical records
- ◆ Requirements for multiple protective measures





## Sites affected by the Mar. 11, 2011 Tohoku Tsunamis



“Operational Status of Nuclear Facilities in Japan” by JNES (2013)

# Mar. 11 Tsunamis at NPPs

NPP	Tsunami Height (Mar. 11, 2011)	Input Tsunami (before Mar. 11)	Input Tsunami (after Mar. 11)
Higashidori	4 m [13 m]	6.5 m	11.7 m*
Onagawa	13 m [15 m]*	9.1 m	23.1 m*
Fukushima Daiichi	15 m [10 m]	5.4 – 5.7 m	26.3 m** (14.13 m)
Fukushima Daini	15 m [12 m]	5.1 – 5.2 m	27.5 m***
Tokai	5 m [8 m]	5.7 m	17.1 m*


Site caused  
severe accident  
Site affected by  
tsunami

[ ] Site elevation  
\*Site subsided 1 m  
by the earthquake  
(Elevation was 14  
m at tsunami input)

\*Currently under  
evaluation or not  
yet evaluated  
\*\*For consideration  
\*\*\*Proposed by  
TEPCO

# Clarification of requirements for fault displacement

- ◆ “Capable faults” need to be determined as those whose activities since the late Pleistocene (approx. 120,000 to 130,000 years ago or later) cannot be denied
- ◆ Important facilities have to be constructed on the ground without outcrop of capable faults




- Movement of the fault under important facilities like Reactor Building may result in the concentration of deadweight onto the spot and cause damage of the building.
- Even in case damage of the building is avoided, safety function can be lost due to the deformation of the facilities or damages of the internal equipment.



# How to find a capable fault?


## 1. Covering Bed Method

Geological age of bed




Capable Fault

“Capable fault” is the official term for “active fault” that is defined in IAEA Safety Standards Series No. SSG-9 “Seismic hazards in site evaluation for nuclear installations”. The “120-130 ka” is the base age of Upper Pleistocene.




Capable Fault




Not Capable Fault

## 2. Crossing Vein Method


— 120-130 ka dike or vein




Capable Fault



Not Capable Fault



# On-site Capable Fault Evaluation



“Operational Status of Nuclear Facilities in Japan” by JNES (2013)

# On-site capable fault evaluation

NPP	by Specialists or NRA	Evaluation Result
Higashidori	Specialists	Capable Fault*
Shika	Specialists	Capable Fault*
Tsuruga	Specialists	Capable Fault*
Monju	Specialists	Not Capable Fault
Mihama	Specialists and NRA	Not Capable Fault
Ohi	Specialists	Not Capable Fault
Takahama	NRA	Not Capable Fault
Ikata	NRA	Not Capable Fault
Sendai	NRA	Not Capable Fault

Site operation permitted  
(Ikata and Sendai are currently on operation)


Credit: NRA


\*Evaluation of fault(s) directly beneath the reactor is not fixed (on evaluation by NRA)

Note: Specialists' evaluation is (will be) taken as important information in the final NRA's judgment.


# More precise methods to define Design Basis Ground Motion (DBGGM)

- ◆ Survey 3D geological structure of the site
- ◆ Take into consideration of seismic ground motion predication





Sites experienced stronger seismic motions than the old DBGMs



“Operational Status of Nuclear Facilities in Japan” by JNES (2013)

# Sites experiencing earthquakes with strong motions larger than the old DBGMs<sup>3)</sup>

(gal = cm/s<sup>2</sup>) Credit: NRA

NPP site	Earthquake Name	Date	Magnitude M <sub>w</sub>	PGA basemat	Distance to site	Operation Status
Onagawa	Miyagi-Oki earthquake	August 16, 2005	7.1	316 gal <sup>1)</sup>	84km	SCRAM at Units #1, 2, 3
Shika	Noto Peninsula earthquake	March 25, 2007	6.7	226 gal <sup>1)</sup>	18km	Under periodical inspection
Kashiwazaki-Kariwa	Chuetsu-Oki earthquake	July 16, 2007	6.6	680 gal <sup>2)</sup>	16km	SCRAM at Units #3, 4, 7. Others; under periodical inspection
Onagawa	Tohoku earthquake	March 11, 2011	9.0	607 gal <sup>2)</sup>	125km	SCRAM at Units #1 & 3. Unit 2; under periodical inspection
Fukushima Daichi	Tohoku earthquake	March 11, 2011	9.0	550 gal <sup>2)</sup>	180km	SCRAM at Units #1, 2, 3. Others: under periodical inspection
Onagawa	Miyagi-Oki earthquake	April 7, 2011	7.1	398 gal <sup>1)</sup>	78km	Under periodical inspection

1) Response spectra exceeded the design basis ground motion (DBGM, S<sub>s</sub> or S<sub>2</sub>) at some periods

2) Peak ground acceleration (PGA) and response spectra (at some periods) exceeded the DBGM (S<sub>s</sub> or S<sub>2</sub>)

3) Design basis ground motions (DBGMs) before and after the March 11, 2011 Tohoku Earthquake (at 50 Hz):

Site	Onagawa	Shika	Kashiwazaki-Kariwa	Fukushima-Daichi
Before	580 gal	600 gal	450 gal*	600 gal (*Before back check)
After	1000 (on evaluation)	1000 (on evaluation)	1209-2300 (on eval.)	900 (for consideration)

4) SCRAM threshold ground acceleration at Kashiwazaki-Kariwa: horizontal = 120-185 gal, vertical = 100 gal

# Reassessment of Sendai Nuclear Power Plants (NPPs): an example



- Owned by Kyushu EPC
- 2 PWRs, 890,000kW each
- About 30 years operation
- Front onto East China Sea (not to plate boundary)



## Time sequence of reassessment

Jul. 8, 2013

Back-fit safety assessment completed

Jul. 16, 2013

Examination by NRA commissioners and secretariats started.

>60 times open-to-public meetings

~700 times closed meetings

Revision after public comments


Sep. 10, 2014

Permission for basic design decided.

Sep. 10, 2015 and Nov. 17, 2015

Commercial operation of Reactors #1 and #2 restarted, respectively. Both reactors are currently on operation.

# Tsunami sources



Copyright, Kyushu EPC

— Nagasaki spur fault  
(length:86km, Mw7.6)


↔ Northern and central part of  
Ryukyu trench  
(length:approx.900km, Mw9.1)

NRA required to estimate the tsunami height caused by northern and central part of Ryukyu trench\*

\* Any tsunami caused by this wide area have never been recorded, but the possibility to break several segment simultaneously, as in case of the Great East Japan Earthquake, should be considered.



# Tsunami protection



Design Basis Tsunami (DBT) of Sendai NPPs is calculated at the point 8 km offshore and 50 m water depth.

Input Tsunami Height is the maximum at the site waterfront.

Site Elevation is the ground height where reactors are placed.

NPPs	DBT	Input Tsunami	Site Elevation
Sendai	2.0m	7.0m	13m
Ikata	1.9m	8.7m	10m
Takahama	1.7m	6.7m	3.5m
Mihama	3.3m	4.2m	3.5m

# Capable faults on site?

## Geological Map of the Sendai Nuclear Power Plant site

Two reactors are built on the Cretaceous conglomerate bed. The longest and youngest faults (e.g. D-45 and D-48) are selected for detailed assessment.


Mar. 19, 2014, Assessment Meeting #95, Doc. 2-1, p. 81, Sendai NPPs, Fault (Kyushu EPC)

断層タイプ区分

断層タイプ	走向・傾斜	主な変位様式
A	NS系低角度	逆断層卓越
B	EW系低角度	正断層卓越
C	—	層面断層(地層境界)
D	NS系高角度	正断層(一部横ずれ断層)卓越
E	EW系高角度	正断層(一部横ずれ断層)卓越

East China Sea

Reactor #2  
Reactor #1



敷地内断層の一覧

断層番号	走向・傾斜	破砕幅
A-47	N10° E/35° NW	50~180cm
D-45	N13~16° W/84~88° NE	60~260cm
D-46	N25~45° W/54~84° SW	6~200cm
D-48	N1~8° W/68~75° SW	0.5~170cm


\* A-47断層はトレンチデータ、それ以外は3号炉調査試掘坑データによる

0 100 200 300(m) 300 m

敷地内断層平面図




地質時代	地層名	地質	
第四紀	盛土	礫、砂、シルト等	
	海浜堆積物	礫、砂等	
	沖積層	礫、砂、泥等	
	砂丘堆積物	砂等	
	段丘堆積物	礫、砂、シルト等	
	新生代	火砕流堆積物	溶結凝灰岩
		北礫火山岩類Ⅱ(輝石安山岩質)	安山岩凝灰岩、火山礫凝灰岩、凝灰岩
		みやま層	凝灰質シルト岩、凝灰質砂岩、凝灰質礫岩、軽石凝灰岩
		北礫火山岩類Ⅰ(角閃石安山岩質)	軽石質凝灰角礫岩、大火山礫岩、凝灰角礫岩、火山礫凝灰岩
	中生代	後期	凝灰岩
前部		凝灰質凝灰岩及び岩塊(砂岩、礫岩、石灰岩等)	
川内層		砂岩、礫岩、頁岩	
上部層		頁岩、砂岩、礫岩	
下部層		礫岩、砂岩、頁岩	
川内層		上部層 粘板岩、砂岩、礫岩 下部層 礫岩、砂岩、粘板岩	
ジュラ紀	変はんれい岩類	粘板岩メランジユ(変はんれい岩、角閃岩、粘板岩等)	

\* 1,2号炉周辺の枠内は、主に基礎掘削工事で確認した地質分布を表現(第四系及び土壌を除く)とする。標高は海抜メートルとする。






# Mineral veins cutting fault zones

D-45 fault zone is cut by a quartz vein including chlorite and illite (p.109)



The newest rupture planes of fault zones are indicated by red arrows.


D-48 fault zone is cut by calcite veins (p. 117)



Chlorite and illite are also present in the fault zones.


# Age of hydrothermal veins: 3 Ma in the Sendai-Kushikino area

○ 敷地内の熱水変質活動の年代については、井澤 (2004)\*に基づき、3~4Maと判断している。



On-site faults of Sendai NPPs formed before (or geologically at the same time with) the 3 Ma hydrothermal activity. Thus **they are not capable faults.**

# Capable faults (near site <30km)



Blue: Fault length assessed by Kyushu EPC




Red: Fault length assessed by the Headquarter for Earthquake Research Promotion (HERP)

NRA required to extend the length of faults to fit the length assessed by HERP


The nearest faults are used for calculation of Design Basis Ground Motion (DBGM)

(Mar. 12, 2014 Assessment Meeting #92. Copyright: Kyushu EPC)

# Design Basis Ground Motion of Sendai NPPs



Horizontal movement



Horizontal movement

Ss-1 and Ss-2 are DBGMs for Sendai NPPs.

The Ss-2 “hypocenters-unidentified” earthquake is assumed to occur in the earth’s crust just beneath the NPPs.


The Ss-2 is larger than the Ss-1 in some periods.

Seismic acceleration of DBGM: (gal =  $\text{cm/s}^2$ )

Sendai:	540 gal (Appl.) >>> 620 gal (Reassess.)
Ikata:	570 gal (Appl.) >>> 650 gal (Reassess.)
Takahama:	550 gal (Appl.) >>> 700 gal (Reassess.)
Mihama:	750 gal (Appl.) >>> 993 gal (Reassess.)

Calculation is based on Irikura and Miyake (2001; *J. Geogr.*, **110**, 849-; 2011; *Pure Appl. Geophys.*, **168**, 85-)

# Capable faults (near site <100km)



Kyushu EPC's evaluation of Futagawa-Hinagu Fault is 93 km long and M8.1, assuming a full-length rupture. Equivalent epicenter distance from Sendai NPPs is 104 km.

The Futagawa-Hinagu Fault caused M7.3 **Kumamoto earthquake** on Apr. 16, 2016 and associated numerous disastrous earthquakes.

(Mar. 12, 2014 Assessment Meeting #92. Copyright: Kyushu EPC)


# 2016 Kumamoto Earthquake

Apr. 14, M6.5 and Apr. 16, M7.3; 50 deaths, >2,000 injuries and >180,000 evacuees.

Surface Fault Rupture:  
Futagawa: 28 km  
Hinagu: 6 km

Fault Length by Satellite-based Ground Movement:  
Futagawa E: 5 km  
Futagawa W: 20 km  
Hinagu: 10 km  
(Data from Japan Meteorological Agency)

Kyushu EPC's evaluation of the Futagawa-Hinagu Fault in the Sendai NPP Reassessment:  
93 km, M8.1



Sendai NPP ●

Japan Meteorological Agency

原子力規制委員会  
Nuclear Regulation Authority




# Protection of NPPs from volcanic hazards

Utility companies should survey Quaternary volcanoes within 160 km from the NPP, and assess their eruption histories, geothermal activities, distribution of lavas, pyroclastic flows and ash, etc.

(Apr. 23, 2014 Assessment Meeting #107 Sendai NPPs, Kyushu EPC)

In case if a **pyroclastic flow** reached the NPP site in the geologic past, the company should conduct **seismic and geodetic monitoring of the source caldera volcano**. This is the case for Sendai NPPs.



Evaluation of volcanic ash to be deposited in the NPP site during its operation:

NPP	Ash
Sendai	15 cm
Ikata	15 cm
Takahama	10 cm
Mihama	10 cm

# Conclusion (Action Principles of NRA)

- ◆ Protect human life & environment – our goal
- ◆ Independent scientific & technical decisions
- ◆ Field-based, effective regulation
- ◆ Open & informed regulation processes
- ◆ Professional moral & ability by daily studies
- ◆ Immediate & organized action at crisis
- ◆ Enhance nuclear safety & security culture

*Thank you for your kind attention.*